

Salem Keizer School District
Salem Heights School
RADON TESTING SAMPLE REPORT

On-site: May 9-11, 2012

Report: May 21, 2012

PURPOSE

Additional radon testing was done in the Speech room, the Custodian's office and a basement storage room.

CONCLUSION

All of the tested rooms had radon levels below the EPA recommended action level at or above 4.0 pCi/L.

TESTING

Radon Air-Chek short-term test devices were used in 3 locations by suspending the device in each room. The testing occurred from Wednesday, May 9 to Friday, May 11, 2012 during normal and routine school ventilation system operation within increased volume of outside air.

Salem Heights Test Results Reported in pCi/L

Location	May 2012 RADON LEVELS	April 2012 RADON LEVELS
Staff lunch room		1.2
Custodian office	1.2	4.1
Basement storage room	0.8	
Staff Work room		1.2
Principal's office		2.7
Office		1.2
Corner Speech		0.9
Counseling		<0.3
Gym		1.6
Gym Office		2.4
Kitchen		<0.3
Multipurpose		1.4
Speech room	0.5	
Large Speech		1.0
Literacy coach		2.1
Media Center		0.6
Portable 23		<0.3
Portable 24		<0.3
Rm 1		1.7
Rm 2		1.8
Rm 3		1.5
Rm 4		1.2
Rm 5		<0.3
Rm 6		<0.3
Rm 11		1.1
Rm 12		0.6
Rm 13		1.3
Rm 14		1.0
Rm 15		1.0
Rm 16		1.6
Rm 17		1.8
Rm 18		2.1
Rm 19		2.0
Rm 20		1.4
Rm 21		1.7
Rm 22		1.9
EPA recommended Exposure		4.0