

Salem Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Auburn Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Limit
01-01A Faculty Work Room Sink Faucet	7/28/16 7:30	8/5/16 12:52	607291201	COPPER	0.2 PPM	1.3 PPM
01-02A Faculty Work Room Drinking Fountain	7/28/16 7:30	8/5/16 12:52	607291202	COPPER	0.1 PPM	1.3 PPM
01-03A Faculty Sink Faucet	7/28/16 7:32	8/5/16 12:52	607291203	COPPER	0.4 PPM	1.3 PPM
01-04A Faculty Lounge Drinking Fountain	7/28/16 7:32	8/5/16 12:52	607291204	COPPER	0.4 PPM	1.3 PPM
01-05A Main Hall by MP Room Drinking Fountain	7/28/16 7:34	8/5/16 12:52	607291205	COPPER	0.4 PPM	1.3 PPM
01-06A Kitchen Double Sink Faucet	7/28/16 7:36	8/5/16 12:52	607291206	COPPER	0.3 PPM	1.3 PPM
01-07A Kitchen Small Sink Faucet	7/28/16 7:38	8/5/16 12:53	607291207	COPPER	0.3 PPM	1.3 PPM
01-08A Classroom 1 Sink Faucet	7/28/16 7:51	8/5/16 12:53	607291208	COPPER	0.6 PPM	1.3 PPM
01-09A Classroom 1 Drinking Fountain	7/28/16 7:51	8/5/16 12:53	607291209	COPPER	0.6 PPM	1.3 PPM
01-10A Classroom 2 Sink Faucet	7/28/16 7:55	8/5/16 12:59	607291210	COPPER	0.4 PPM	1.3 PPM
01-12A AV Room Sink Faucet	7/28/16 9:15	8/5/16 12:59	607291211	COPPER	0.2 PPM	1.3 PPM
01-13A Room 44 (LRC) Sink Faucet	7/28/16 9:17	8/5/16 13:00	607291212	COPPER	0.3 PPM	1.3 PPM
01-14A Room 44 (LRC) Drinking Fountain	7/28/16 9:17	8/5/16 13:00	607291213	COPPER	0.4 PPM	1.3 PPM
01-15A Classroom 3 Sink Faucet	7/28/16 9:19	8/5/16 13:00	607291214	COPPER	0.3 PPM	1.3 PPM
01-16A Classroom 3 Drinking Fountain	7/28/16 9:19	8/5/16 13:00	607291215	COPPER	0.5 PPM	1.3 PPM
01-17A Classroom 4 Sink Faucet	7/28/16 9:21	8/5/16 13:00	607291216	COPPER	0.3 PPM	1.3 PPM
01-18A Classroom 4 Drinking Fountain	7/28/16 9:21	8/5/16 13:00	607291217	COPPER	0.5 PPM	1.3 PPM
01-19A Classroom 5 Sink Faucet	7/28/16 9:23	8/5/16 13:00	607291218	COPPER	0.4 PPM	1.3 PPM
01-20A Classroom 5 Drinking Fountain	7/28/16 9:23	8/5/16 13:00	607291219	COPPER	0.5 PPM	1.3 PPM
01-21A Classroom 6 Sink Faucet	7/28/16 9:25	8/5/16 13:00	607291220	COPPER	0.2 PPM	1.3 PPM
01-22A Classroom 6 Drinking Fountain	7/28/16 9:25	8/5/16 13:00	607291221	COPPER	0.4 PPM	1.3 PPM
01-23A Classroom 7 Sink Faucet	7/28/16 9:17	8/5/16 13:00	607291222	COPPER	0.4 PPM	1.3 PPM
01-24A Classroom 7 Drinking Fountain	7/28/16 9:17	8/5/16 13:00	607291223	COPPER	0.5 PPM	1.3 PPM
01-25A Hall across from Room 7 Drinking Fountain	7/28/16 9:19	8/5/16 13:00	607291224	COPPER	0.3 PPM	1.3 PPM
01-26A Classroom 8 Sink Faucet	7/28/16 9:21	8/5/16 13:00	607291225	COPPER	0.3 PPM	1.3 PPM
01-27A Classroom 8 Drinking Fountain	7/28/16 9:21	8/5/16 13:00	607291226	COPPER	0.5 PPM	1.3 PPM
01-28A Classroom 9 Sink Faucet	7/28/16 9:23	8/5/16 13:01	607291227	COPPER	0.5 PPM	1.3 PPM
01-29A Classroom 9 Drinking Fountain	7/28/16 9:23	8/5/16 13:01	607291228	COPPER	0.5 PPM	1.3 PPM
01-30A Classroom 10 Sink Faucet	7/28/16 9:25	8/5/16 13:01	607291229	COPPER	0.4 PPM	1.3 PPM
01-31A Classroom 10 Drinking Fountain	7/28/16 9:25	8/5/16 13:01	607291230	COPPER	0.4 PPM	1.3 PPM
01-32A Classroom 11 Sink Faucet	7/28/16 9:27	8/5/16 13:01	607291231	COPPER	0.3 PPM	1.3 PPM
01-33A Classroom 11 Drinking Fountain	7/28/16 9:27	8/5/16 13:01	607291232	COPPER	0.5 PPM	1.3 PPM
01-34A Classroom 12 Sink Faucet	7/28/16 9:29	8/5/16 13:01	607291233	COPPER	0.2 PPM	1.3 PPM
01-35A Classroom 12 Drinking Fountain	7/28/16 9:29	8/5/16 13:01	607291234	COPPER	0.3 PPM	1.3 PPM
01-36A Classroom 13 Sink Faucet	7/28/16 9:31	8/5/16 13:01	607291235	COPPER	0.5 PPM	1.3 PPM
01-37A Classroom 13 Drinking Fountain	7/28/16 9:31	8/5/16 13:01	607291236	COPPER	0.5 PPM	1.3 PPM
01-38A Room 22 (CFE) Sink Faucet	7/28/16 9:33	8/5/16 13:01	607291237	COPPER	0.2 PPM	1.3 PPM
01-39A Room 22 Drinking Fountain	7/28/16 9:33	8/5/16 13:01	607291238	COPPER	0.2 PPM	1.3 PPM
01-40A Classroom 15 Sink Faucet	7/28/16 9:35	8/5/16 13:01	607291239	COPPER	0.3 PPM	1.3 PPM
01-41A Classroom 15 Drinking Fountain	7/28/16 9:35	8/5/16 13:01	607291240	COPPER	0.5 PPM	1.3 PPM
01-42A Classroom 17 Sink Faucet	7/28/16 9:37	8/5/16 13:01	607291241	COPPER	0.7 PPM	1.3 PPM
01-43A Classroom 17 Drinking Fountain	7/28/16 9:37	8/5/16 13:02	607291242	COPPER	0.5 PPM	1.3 PPM
01-44A Hallway across Drinking Fountain from Room 15	7/28/16 9:39	8/5/16 13:02	607291243	COPPER	0.8 PPM	1.3 PPM
01-45A Classroom 14 Sink Faucet	7/28/16 9:41	8/5/16 13:02	607291244	COPPER	0.3 PPM	1.3 PPM
01-46A Classroom 14 Drinking Fountain	7/28/16 9:41	8/5/16 13:02	607291245	COPPER	0.4 PPM	1.3 PPM
01-47A Classroom 19 Sink Faucet	7/28/16 9:43	8/5/16 13:02	607291246	COPPER	0.4 PPM	1.3 PPM
01-48A Classroom 19 Drinking Fountain	7/28/16 9:43	8/5/16 13:02	607291247	COPPER	0.5 PPM	1.3 PPM
01-49A Classroom 21 Sink Faucet	7/28/16 9:45	8/5/16 13:02	607291248	COPPER	0.3 PPM	1.3 PPM
01-50A Classroom 21 Drinking Fountain	7/28/16 9:45	8/5/16 13:02	607291249	COPPER	0.5 PPM	1.3 PPM
01-51A Classroom 16 Sink Faucet	7/28/16 9:47	8/5/16 13:02	607291250	COPPER	0.3 PPM	1.3 PPM
01-52A Classroom 16 Drinking Fountain	7/28/16 9:47	8/5/16 13:02	607291251	COPPER	0.3 PPM	1.3 PPM
01-53A Classroom 23 Sink Faucet	7/28/16 9:49	8/5/16 13:02	607291252	COPPER	0.3 PPM	1.3 PPM
01-54A Classroom 23 Drinking Fountain	7/28/16 9:49	8/5/16 13:02	607291253	COPPER	0.5 PPM	1.3 PPM
01-55A East-most Portable Drinking Fountain #24 & #25	7/28/16 9:51	8/5/16 13:02	607291254	COPPER	1.0 PPM	1.3 PPM
01-56A Room 31 (CFE) Sink Faucet	7/28/16 9:53	8/5/16 13:02	607291255	COPPER	0.1 PPM	1.3 PPM

Salem Keizer Public Schools
 Copper Water Sampling Results
 First Draw (A) Sample Data
 Auburn Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Limit
01-57A South Portable Classroom 28 Sink Faucet	7/28/16 9:55	8/5/16 13:03	607291256	COPPER	0.1 PPM	1.3 PPM
01-58A South Portable Classroom 28 Drinking Fountain	7/28/16 9:57	8/5/16 13:02	607291257	COPPER	0.1 PPM	1.3 PPM
01-59A South Portable Classroom 29 Sink Faucet	7/28/16 9:58	8/5/16 13:02	607291258	COPPER	0.1 PPM	1.3 PPM
01-60A South Portable Classroom 29 Drinking Fountain	7/28/16 10:00	8/5/16 13:02	607291259	COPPER	0.0 PPM	1.3 PPM
01-61A Room 31 Drinking Fountain	7/28/16 9:53	8/5/16 13:02	607291260	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Auburn Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Limit
01-11A Classroom 2 Drinking Fountain	10/14/2016 5:22	10/18/2016	63251	COPPER	0.6 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
Flushed (B) Sample Data
Auburn Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
01-04B Faculty Lounge Drinking Fountain	7/28/16 7:33	8/26/16 11:32	608191601	COPPER	0.4 PPM	1.3 PPM
01-14B Room 44 (LRC) Drinking Fountain	7/28/16 9:18	8/26/16 11:32	608191602	COPPER	0.4 PPM	1.3 PPM
01-56B Room 31 (CFE) Sink Faucet	7/28/16 9:54	8/26/16 11:32	608191603	COPPER	0.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (C) Sample Data
Auburn Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Limit
01-04C Faculty Lounge Drinking Fountain	10/14/2016 5:31	10/18/2016	63245	COPPER	0.3 PPM	1.3 PPM
01-14C Room 44 (LRC) Drinking Fountain	10/14/2016 5:41	10/18/2016	63246	COPPER	0.4 PPM	1.3 PPM
01-56C Room 31 (CFE) Sink Faucet	10/14/2016 5:55	10/18/2016	63247	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Auburn Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Limit
01-62A Gym Drinking Fountain	1/20/2017 6:40	1/23/2017	3136	COPPER	0.5 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level