

Salem Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Auburn Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date/Time Analyzed | Container ID | Tested For | Results | Action Limit |
|---|-------------------|--------------------|--------------|------------|---------|--------------|
| 01-01A Faculty Work Room Sink Faucet | 7/28/16 7:30 | 8/5/16 12:52 | 607291201 | LEAD | 3 PPB | 15 PPB |
| 01-02A Faculty Work Room Drinking Fountain | 7/28/16 7:30 | 8/5/16 12:52 | 607291202 | LEAD | 14 PPB | 15 PPB |
| 01-03A Faculty Sink Faucet | 7/28/16 7:32 | 8/5/16 12:52 | 607291203 | LEAD | < 1 PPB | 15 PPB |
| 01-04A Faculty Lounge Drinking Fountain | 7/28/16 7:32 | 8/5/16 12:52 | 607291204 | LEAD | 18 PPB | 15 PPB |
| 01-05A Main Hall by MPRoom Drinking Fountain | 7/28/16 7:34 | 8/5/16 12:52 | 607291205 | LEAD | < 1 PPB | 15 PPB |
| 01-06A Kitchen Double Sink Faucet | 7/28/16 7:36 | 8/5/16 12:52 | 607291206 | LEAD | 2 PPB | 15 PPB |
| 01-07A Kitchen Small Sink Faucet | 7/28/16 7:38 | 8/5/16 12:53 | 607291207 | LEAD | 6 PPB | 15 PPB |
| 01-08A Classroom 1 Sink Faucet | 7/28/16 7:51 | 8/5/16 12:53 | 607291208 | LEAD | 10 PPB | 15 PPB |
| 01-09A Classroom 1 Drinking Fountain | 7/28/16 7:51 | 8/5/16 12:53 | 607291209 | LEAD | 3 PPB | 15 PPB |
| 01-10A Classroom 2 Sink Faucet | 7/28/16 7:55 | 8/5/16 12:59 | 607291210 | LEAD | 5 PPB | 15 PPB |
| 01-12A AV Room Sink Faucet | 7/28/16 9:15 | 8/5/16 12:59 | 607291211 | LEAD | 2 PPB | 15 PPB |
| 01-13A Room 44 (LRC) Sink Faucet | 7/28/16 9:17 | 8/5/16 13:00 | 607291212 | LEAD | 2 PPB | 15 PPB |
| 01-14A Room 44 (LRC) Drinking Fountain | 7/28/16 9:17 | 8/5/16 13:00 | 607291213 | LEAD | 15 PPB | 15 PPB |
| 01-15A Classroom 3 Sink Faucet | 7/28/16 9:19 | 8/5/16 13:00 | 607291214 | LEAD | 5 PPB | 15 PPB |
| 01-16A Classroom 3 Drinking Fountain | 7/28/16 9:19 | 8/5/16 13:00 | 607291215 | LEAD | 2 PPB | 15 PPB |
| 01-17A Classroom 4 Sink Faucet | 7/28/16 9:21 | 8/5/16 13:00 | 607291216 | LEAD | 6 PPB | 15 PPB |
| 01-18A Classroom 4 Drinking Fountain | 7/28/16 9:21 | 8/5/16 13:00 | 607291217 | LEAD | 1 PPB | 15 PPB |
| 01-19A Classroom 5 Sink Faucet | 7/28/16 9:23 | 8/5/16 13:00 | 607291218 | LEAD | 2 PPB | 15 PPB |
| 01-20A Classroom 5 Drinking Fountain | 7/28/16 9:23 | 8/5/16 13:00 | 607291219 | LEAD | < 1 PPB | 15 PPB |
| 01-21A Classroom 6 Sink Faucet | 7/28/16 9:25 | 8/5/16 13:00 | 607291220 | LEAD | 3 PPB | 15 PPB |
| 01-22A Classroom 6 Drinking Fountain | 7/28/16 9:25 | 8/5/16 13:00 | 607291221 | LEAD | < 1 PPB | 15 PPB |
| 01-23A Classroom 7 Sink Faucet | 7/28/16 9:17 | 8/5/16 13:00 | 607291222 | LEAD | 4 PPB | 15 PPB |
| 01-24A Classroom 7 Drinking Fountain | 7/28/16 9:17 | 8/5/16 13:00 | 607291223 | LEAD | 2 PPB | 15 PPB |
| 01-25A Hall across from Room 7 Drinking Fountain | 7/28/16 9:19 | 8/5/16 13:00 | 607291224 | LEAD | < 1 PPB | 15 PPB |
| 01-26A Classroom 8 Sink Faucet | 7/28/16 9:21 | 8/5/16 13:00 | 607291225 | LEAD | 4 PPB | 15 PPB |
| 01-27A Classroom 8 Drinking Fountain | 7/28/16 9:21 | 8/5/16 13:00 | 607291226 | LEAD | 1 PPB | 15 PPB |
| 01-28A Classroom 9 Sink Faucet | 7/28/16 9:23 | 8/5/16 13:01 | 607291227 | LEAD | 5 PPB | 15 PPB |
| 01-29A Classroom 9 Drinking Fountain | 7/28/16 9:23 | 8/5/16 13:01 | 607291228 | LEAD | 2 PPB | 15 PPB |
| 01-30A Classroom 10 Sink Faucet | 7/28/16 9:25 | 8/5/16 13:01 | 607291229 | LEAD | 13 PPB | 15 PPB |
| 01-31A Classroom 10 Drinking Fountain | 7/28/16 9:25 | 8/5/16 13:01 | 607291230 | LEAD | < 1 PPB | 15 PPB |
| 01-32A Classroom 11 Sink Faucet | 7/28/16 9:27 | 8/5/16 13:01 | 607291231 | LEAD | 2 PPB | 15 PPB |
| 01-33A Classroom 11 Drinking Fountain | 7/28/16 9:27 | 8/5/16 13:01 | 607291232 | LEAD | 1 PPB | 15 PPB |
| 01-34A Classroom 12 Sink Faucet | 7/28/16 9:29 | 8/5/16 13:01 | 607291233 | LEAD | 2 PPB | 15 PPB |
| 01-35A Classroom 12 Drinking Fountain | 7/28/16 9:29 | 8/5/16 13:01 | 607291234 | LEAD | 5 PPB | 15 PPB |
| 01-36A Classroom 13 Sink Faucet | 7/28/16 9:31 | 8/5/16 13:01 | 607291235 | LEAD | 4 PPB | 15 PPB |
| 01-37A Classroom 13 Drinking Fountain | 7/28/16 9:31 | 8/5/16 13:01 | 607291236 | LEAD | 3 PPB | 15 PPB |
| 01-38A Room 22 (CFE) Sink Faucet | 7/28/16 9:33 | 8/5/16 13:01 | 607291237 | LEAD | 5 PPB | 15 PPB |
| 01-39A Room 22 Drinking Fountain | 7/28/16 9:33 | 8/5/16 13:01 | 607291238 | LEAD | 9 PPB | 15 PPB |
| 01-40A Classroom 15 Sink Faucet | 7/28/16 9:35 | 8/5/16 13:01 | 607291239 | LEAD | 9 PPB | 15 PPB |
| 01-41A Classroom 15 Drinking Fountain | 7/28/16 9:35 | 8/5/16 13:01 | 607291240 | LEAD | 5 PPB | 15 PPB |
| 01-42A Classroom 17 Sink Faucet | 7/28/16 9:37 | 8/5/16 13:01 | 607291241 | LEAD | 4 PPB | 15 PPB |
| 01-43A Classroom 17 Drinking Fountain | 7/28/16 9:37 | 8/5/16 13:02 | 607291242 | LEAD | 3 PPB | 15 PPB |
| 01-44A Hallway across Drinking Fountain from Room 15 | 7/28/16 9:39 | 8/5/16 13:02 | 607291243 | LEAD | 3 PPB | 15 PPB |
| 01-45A Classroom 14 Sink Faucet | 7/28/16 9:41 | 8/5/16 13:02 | 607291244 | LEAD | 4 PPB | 15 PPB |
| 01-46A Classroom 14 Drinking Fountain | 7/28/16 9:41 | 8/5/16 13:02 | 607291245 | LEAD | 5 PPB | 15 PPB |
| 01-47A Classroom 19 Sink Faucet | 7/28/16 9:43 | 8/5/16 13:02 | 607291246 | LEAD | 4 PPB | 15 PPB |
| 01-48A Classroom 19 Drinking Fountain | 7/28/16 9:43 | 8/5/16 13:02 | 607291247 | LEAD | < 1 PPB | 15 PPB |
| 01-49A Classroom 21 Sink Faucet | 7/28/16 9:45 | 8/5/16 13:02 | 607291248 | LEAD | 4 PPB | 15 PPB |
| 01-50A Classroom 21 Drinking Fountain | 7/28/16 9:45 | 8/5/16 13:02 | 607291249 | LEAD | 1 PPB | 15 PPB |
| 01-51A Classroom 16 Sink Faucet | 7/28/16 9:47 | 8/5/16 13:02 | 607291250 | LEAD | 3 PPB | 15 PPB |
| 01-52A Classroom 16 Drinking Fountain | 7/28/16 9:47 | 8/5/16 13:02 | 607291251 | LEAD | 6 PPB | 15 PPB |
| 01-53A Classroom 23 Sink Faucet | 7/28/16 9:49 | 8/5/16 13:02 | 607291252 | LEAD | 4 PPB | 15 PPB |
| 01-54A Classroom 23 Drinking Fountain | 7/28/16 9:49 | 8/5/16 13:02 | 607291253 | LEAD | 3 PPB | 15 PPB |
| 01-55A East-most Portable Drinking Fountain #24 & #25 | 7/28/16 9:51 | 8/5/16 13:02 | 607291254 | LEAD | < 1 PPB | 15 PPB |
| 01-56A Room 31 (CFE) Sink Faucet | 7/28/16 9:53 | 8/5/16 13:02 | 607291255 | LEAD | 17 PPB | 15 PPB |
| 01-57A South Portable Classroom 28 Sink Faucet | 7/28/16 9:55 | 8/5/16 13:03 | 607291256 | LEAD | 3 PPB | 15 PPB |

Salem Keizer Public Schools
 Lead Water Sampling Results
 First Draw (A) Sample Data
 Auburn Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date/Time Analyzed | Container ID | Tested For | Results | Action Limit |
|--|-------------------|--------------------|--------------|------------|---------|--------------|
| 01-58A South Portable Classroom 28 Drinking Fountain | 7/28/16 9:57 | 8/5/16 13:02 | 607291257 | LEAD | < 1 PPB | 15 PPB |
| 01-59A South Portable Classroom 29 Sink Faucet | 7/28/16 9:58 | 8/5/16 13:02 | 607291258 | LEAD | 5 PPB | 15 PPB |
| 01-60A South Portable Classroom 29 Drinking Fountain | 7/28/16 10:00 | 8/5/16 13:02 | 607291259 | LEAD | < 1 PPB | 15 PPB |
| 01-61A Room 31 Drinking Fountain | 7/28/16 9:53 | 8/5/16 13:02 | 607291260 | LEAD | 3 PPB | 15 PPB |

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Auburn Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Limit |
|--------------------------------------|-------------------|---------------|--------------|------------|---------|--------------|
| 01-11A Classroom 2 Drinking Fountain | 10/14/2016 5:22 | 10/18/2016 | 63251 | LEAD | 2 PPB | 15 PPB |

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
Auburn Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date/Time Analyzed | Container ID | Tested For | Results | Action Level |
|---|-------------------|--------------------|--------------|------------|---------|--------------|
| 01-04B Faculty Lounge Drinking Fountain | 7/28/16 7:33 | 8/26/16 11:32 | 608191601 | LEAD | 5 PPB | 15 PPB |
| 01-14B Room 44 (LRC) Drinking Fountain | 7/28/16 9:18 | 8/26/16 11:32 | 608191602 | LEAD | 4 PPB | 15 PPB |
| 01-56B Room 31 (CFE) Sink Faucet | 7/28/16 9:54 | 8/26/16 11:32 | 608191603 | LEAD | < 1 PPB | 15 PPB |

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (C) Sample Data
Auburn Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Limit |
|---|-------------------|---------------|--------------|------------|---------|--------------|
| 01-04C Faculty Lounge Drinking Fountain | 10/14/2016 5:31 | 10/18/2016 | 63245 | LEAD | 1 PPB | 15 PPB |
| 01-14C Room 44 (LRC) Drinking Fountain | 10/14/2016 5:41 | 10/18/2016 | 63246 | LEAD | 7 PPB | 15 PPB |
| 01-56C Room 31 (CFE) Sink Faucet | 10/14/2016 5:55 | 10/18/2016 | 63247 | LEAD | <1 PPB | 15 PPB |

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Auburn Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Limit |
|--------------------------------------|-------------------|---------------|--------------|------------|---------|--------------|
| 01-62A Gym Drinking Fountain | 1/20/2017 6:40 | 1/23/2017 | 3136 | LEAD | 5 PPB | 15 PPB |

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level