

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Battle Creek Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
02-01A Kitchen Food Prep Sink Faucet	8/13/16 10:20	8/22/16 11:00	608151601	LEAD	5 PPB	15 PPB
02-02A Cafeteria Drinking Fountain #1	8/13/16 10:24	8/22/16 11:00	608151602	LEAD	2 PPB	15 PPB
02-03A Cafeteria Drinking Fountain #2	8/13/16 10:24	8/22/16 11:00	608151603	LEAD	2 PPB	15 PPB
02-04A Gymnasium Drinking Fountain #1	8/13/16 10:30	8/22/16 11:00	608151604	LEAD	< 1 PPB	15 PPB
02-05A Gymnasium Drinking Fountain #2	8/13/16 10:30	8/22/16 11:00	608151605	LEAD	< 1 PPB	15 PPB
02-06A Classroom 186 Sink Faucet	8/13/16 10:33	8/22/16 11:00	608151606	LEAD	3 PPB	15 PPB
02-07A Classroom 186 Drinking Fountain #1	8/13/16 10:33	8/22/16 11:01	608151607	LEAD	3 PPB	15 PPB
02-08A Classroom 186 Drinking Fountain #2	8/13/16 10:35	8/23/16 9:11	608151608	LEAD	< 1 PPB	15 PPB
02-09A Classroom 186 Drinking Fountain #3	8/13/16 10:35	8/23/16 9:11	608151609	LEAD	1 PPB	15 PPB
02-10A Bathroom 191/192 Drinking Fountain #1	8/13/16 10:40	8/22/16 11:02	608151610	LEAD	< 1 PPB	15 PPB
02-11A Bathroom 191/192 Drinking Fountain #2	8/13/16 10:40	8/22/16 11:02	608151611	LEAD	< 1 PPB	15 PPB
02-12A Staff Lounge Sink Faucet	8/13/16 10:51	8/22/16 11:02	608151612	LEAD	3 PPB	15 PPB
02-13A Room (PLC) 113 Sink Faucet	8/13/16 10:49	8/22/16 11:02	608151613	LEAD	< 1 PPB	15 PPB
02-14A Classroom 101 Sink Faucet	8/13/16 10:55	8/22/16 11:02	608151614	LEAD	1 PPB	15 PPB
02-15A Classroom 101 Drinking Fountain	8/13/16 10:55	8/22/16 11:02	608151615	LEAD	2 PPB	15 PPB
02-16A Classroom 102 Sink Faucet	8/13/16 10:57	8/22/16 11:02	608151616	LEAD	< 1 PPB	15 PPB
02-17A Classroom 102 Drinking Fountain	8/13/16 10:57	8/22/16 11:03	608151617	LEAD	< 1 PPB	15 PPB
02-18A Classroom 103 Sink Faucet	8/13/16 11:00	8/22/16 11:03	608151618	LEAD	1 PPB	15 PPB
02-19A Classroom 103 Drinking Fountain	8/13/16 11:00	8/22/16 11:03	608151619	LEAD	< 1 PPB	15 PPB
02-20A Classroom 104 Sink Faucet	8/13/16 11:02	8/22/16 11:03	608151620	LEAD	1 PPB	15 PPB
02-21A Classroom 104 Drinking Fountain	8/13/16 11:02	8/22/16 11:03	608151621	LEAD	< 1 PPB	15 PPB
02-22A Classroom 105 Sink Faucet	8/13/16 11:05	8/22/16 11:03	608151622	LEAD	< 1 PPB	15 PPB
02-23A Classroom 105 Drinking Fountain	8/13/16 11:05	8/22/16 11:03	608151623	LEAD	< 1 PPB	15 PPB
02-24A Classroom 106 Sink Faucet	8/13/16 11:07	8/22/16 11:03	608151624	LEAD	< 1 PPB	15 PPB
02-25A Classroom 106 Drinking Fountain	8/13/16 11:07	8/22/16 11:04	608151625	LEAD	< 1 PPB	15 PPB
02-26A Classroom 107 Sink Faucet	8/13/16 11:19	8/22/16 11:04	608151626	LEAD	2 PPB	15 PPB
02-27A Classroom 107 Drinking Fountain	8/13/16 11:19	8/22/16 11:05	608151627	LEAD	< 1 PPB	15 PPB
02-28A Classroom 108 Sink Faucet	8/13/16 11:22	8/22/16 11:05	608151628	LEAD	< 1 PPB	15 PPB
02-29A Classroom 108 Drinking Fountain	8/13/16 11:22	8/22/16 11:05	608151629	LEAD	< 1 PPB	15 PPB
02-30A Classroom 109 Sink Faucet	8/13/16 11:24	8/22/16 11:05	608151630	LEAD	< 1 PPB	15 PPB
02-31A Classroom 109 Drinking Fountain	8/13/16 11:24	8/22/16 11:05	608151631	LEAD	< 1 PPB	15 PPB
02-32A Hallway Drinking Fountain #1	8/13/16 11:27	8/22/16 11:05	608151632	LEAD	< 1 PPB	15 PPB
02-33A Hallway Drinking Fountain #2	8/13/16 11:22	8/22/16 11:05	608151633	LEAD	< 1 PPB	15 PPB
02-34A Classroom 110 Sink Faucet	8/13/16 11:29	8/22/16 11:05	608151634	LEAD	< 1 PPB	15 PPB
02-35A Classroom 110 Drinking Fountain	8/13/16 11:29	8/22/16 11:05	608151635	LEAD	< 1 PPB	15 PPB
02-36A Classroom 111 Sink Faucet	8/13/16 11:32	8/22/16 11:05	608151636	LEAD	< 1 PPB	15 PPB
02-37A Classroom 111 Drinking Fountain	8/13/16 11:32	8/22/16 11:06	608151637	LEAD	< 1 PPB	15 PPB
02-38A Wet Lab Sink Faucet #1	8/13/16 11:45	8/22/16 11:06	608151638	LEAD	1 PPB	15 PPB
02-39A Wet Lab Sink Faucet #2	8/13/16 11:46	8/22/16 11:06	608151639	LEAD	2 PPB	15 PPB
02-40A Wet Lab Sink Faucet #3	8/13/16 11:46	8/22/16 11:06	608151640	LEAD	3 PPB	15 PPB
02-41A Wet Lab Sink Faucet #4	8/13/16 11:47	8/22/16 11:06	608151641	LEAD	8 PPB	15 PPB
02-42A Wet Lab Sink Faucet #5	8/13/16 11:47	8/22/16 11:06	608151642	LEAD	2 PPB	15 PPB
02-43A Wet Lab Sink Faucet #6	8/13/16 11:48	8/22/16 11:06	608151643	LEAD	2 PPB	15 PPB
02-44A Wet Lab Sink Faucet #7	8/13/16 11:48	8/22/16 11:06	608151644	LEAD	2 PPB	15 PPB
02-45A Bathroom Drinking Fountain 239/240	8/13/16 11:38	8/22/16 11:06	608151645	LEAD	2 PPB	15 PPB
02-46A Classroom (LRC) 200 Sink Faucet	8/13/16 11:53	8/22/16 11:06	608151646	LEAD	3 PPB	15 PPB
02-47A Classroom (LRC) 200 Drinking Fountain	8/13/16 11:53	8/22/16 11:10	608151647	LEAD	1 PPB	15 PPB
02-48A Classroom 212 Sink Faucet	8/13/16 11:56	8/22/16 11:10	608151648	LEAD	1 PPB	15 PPB
02-49A Classroom 212 Drinking Fountain	8/13/16 11:56	8/22/16 11:10	608151649	LEAD	< 1 PPB	15 PPB
02-50A Room (PLC) 213 Sink Faucet	8/13/16 12:01	8/22/16 11:10	608151650	LEAD	< 1 PPB	15 PPB
02-51A Classroom 201 Sink Faucet	8/13/16 12:03	8/22/16 11:10	608151651	LEAD	1 PPB	15 PPB
02-52A Classroom 201 Drinking Fountain	8/13/16 12:03	8/22/16 11:10	608151652	LEAD	2 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Battle Creek Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
02-53A Classroom 202 Sink Faucet	8/13/16 12:07	8/22/16 11:10	608151653	LEAD	3 PPB	15 PPB
02-54A Classroom 202 Drinking Fountain	8/13/16 12:07	8/22/16 11:11	608151654	LEAD	3 PPB	15 PPB
02-55A Classroom 203 Sink Faucet	8/13/16 12:12	8/22/16 11:11	608151655	LEAD	2 PPB	15 PPB
02-56A Classroom 203 Drinking Fountain	8/13/16 12:12	8/22/16 11:11	608151656	LEAD	2 PPB	15 PPB
02-57A Classroom 204 Sink Faucet	8/13/16 12:15	8/22/16 11:12	608151657	LEAD	1 PPB	15 PPB
02-58A Classroom 204 Drinking Fountain	8/13/16 12:15	8/22/16 11:12	608151658	LEAD	< 1 PPB	15 PPB
02-59A Classroom 205 Sink Faucet	8/13/16 12:17	8/22/16 11:12	608151659	LEAD	1 PPB	15 PPB
02-60A Classroom 205 Drinking Fountain	8/13/16 12:17	8/22/16 11:12	608151660	LEAD	1 PPB	15 PPB
02-61A Classroom 206 Sink Faucet	8/13/16 12:19	8/22/16 11:12	608151661	LEAD	1 PPB	15 PPB
02-62A Classroom 206 Drinking Fountain	8/13/16 12:19	8/22/16 11:12	608151662	LEAD	3 PPB	15 PPB
02-63A Room (PHC) 215 Sink Faucet	8/13/16 12:24	8/22/16 11:12	608151663	LEAD	1 PPB	15 PPB
02-64A Classroom 207 Sink Faucet	8/13/16 12:27	8/22/16 11:12	608151664	LEAD	1 PPB	15 PPB
02-65A Classroom 207 Drinking Fountain	8/13/16 12:27	8/22/16 11:12	608151665	LEAD	< 1 PPB	15 PPB
02-66A Classroom 208 Sink Faucet	8/13/16 12:28	8/22/16 11:12	608151666	LEAD	1 PPB	15 PPB
02-67A Classroom 208 Drinking Fountain	8/13/16 12:28	8/22/16 11:13	608151667	LEAD	< 1 PPB	15 PPB
02-68A Classroom 209 Sink Faucet	8/13/16 12:30	8/22/16 11:13	608151668	LEAD	2 PPB	15 PPB
02-69A Classroom 209 Drinking Fountain	8/13/16 12:30	8/22/16 11:13	608151669	LEAD	< 1 PPB	15 PPB
02-70A Hallway Drinking Fountain #3	8/13/16 12:33	8/22/16 11:13	608151670	LEAD	< 1 PPB	15 PPB
02-71A Hallway Drinking Fountain #4	8/13/16 12:33	8/22/16 11:13	608151671	LEAD	< 1 PPB	15 PPB
02-72A Classroom 210 Sink Faucet	8/13/16 12:35	8/22/16 11:13	608151672	LEAD	< 1 PPB	15 PPB
02-73A Classroom 210 Drinking Fountain	8/13/16 12:35	8/22/16 11:13	608151673	LEAD	2 PPB	15 PPB
02-74A Classroom 211 Sink Faucet	8/13/16 12:38	8/22/16 11:13	608151674	LEAD	2 PPB	15 PPB
02-75A Classroom 211 Drinking Fountain	8/13/16 12:38	8/22/16 11:13	608151675	LEAD	< 1 PPB	15 PPB
02-76A Health Room Office Sink Faucet	8/13/16 11:38	8/22/16 11:13	608151676	LEAD	< 1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level