

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Bush Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
004-01A Gymnasium Drinking Fountain 1	7/26/16 11:40	7/29/16 12:49	607271301	COPPER	0.5 PPM	1.3 PPM
004-02A Gymnasium Drinking Fountain 2	7/26/16 11:42	7/29/16 12:49	607271302	COPPER	0.6 PPM	1.3 PPM
004-03A Hallway Drinking Fountain 1	7/26/16 11:45	7/29/16 12:49	607271303	COPPER	0.6 PPM	1.3 PPM
004-04A Hallway Drinking Fountain 2	7/26/16 11:47	7/29/16 12:49	607271304	COPPER	0.5 PPM	1.3 PPM
004-05A Kitchen Food Prep Sink Faucet	7/26/16 11:56	7/29/16 12:49	607271305	COPPER	0.3 PPM	1.3 PPM
004-06A Kitchen Counter Sink Faucet	7/26/16 11:58	7/29/16 12:49	607271306	COPPER	0.5 PPM	1.3 PPM
004-07A Pre-school Room 12 Sink Faucet (Left)	7/26/16 12:02	7/29/16 12:49	607271307	COPPER	0.3 PPM	1.3 PPM
004-08A Pre-school Room 12 Sink Faucet (Right)	7/26/16 12:02	7/29/16 12:50	607271308	COPPER	0.3 PPM	1.3 PPM
004-09A Staff Lounge Sink Faucet	7/26/16 12:04	8/1/16 9:29	607271309	COPPER	0.4 PPM	1.3 PPM
004-10A Nurse/Health Sink Faucet	7/26/16 12:06	8/1/16 9:32	607271310	COPPER	0.4 PPM	1.3 PPM
004-11A Nurse/Health Drinking Fountain	7/26/16 12:06	8/1/16 9:32	607271311	COPPER	0.4 PPM	1.3 PPM
004-12A ERC Room 5 Sink Faucet	7/26/16 12:09	8/1/16 9:32	607271312	COPPER	0.3 PPM	1.3 PPM
004-13A LRC Room 4 Sink Faucet	7/26/16 12:11	8/1/16 9:32	607271313	COPPER	0.4 PPM	1.3 PPM
004-14A LRC Room 4 Drinking Fountain	7/26/16 12:12	8/1/16 9:33	607271314	COPPER	0.4 PPM	1.3 PPM
004-15A Hallway Drinking Fountain 3 (Left)	7/26/16 12:15	8/1/16 9:33	607271315	COPPER	0.5 PPM	1.3 PPM
004-16A Hallway Drinking Fountain 4 (Right)	7/26/16 12:15	8/2/16 15:21	607271316	COPPER	0.5 PPM	1.3 PPM
004-17A Classroom 3 Sink Faucet	7/26/16 12:17	8/2/16 15:29	607271317	COPPER	0.3 PPM	1.3 PPM
004-18A Classroom 3 Drinking Fountain	7/26/16 12:17	8/2/16 15:29	607271318	COPPER	0.3 PPM	1.3 PPM
004-19A Classroom 9 Sink Faucet	7/26/16 12:19	8/2/16 15:29	607271319	COPPER	0.3 PPM	1.3 PPM
004-20A Classroom 9 Drinking Fountain	7/26/16 12:20	8/2/16 15:29	607271320	COPPER	0.4 PPM	1.3 PPM
004-21A Classroom 7 Sink Faucet	7/26/16 12:22	8/2/16 15:29	607271321	COPPER	0.3 PPM	1.3 PPM
004-22A Classroom 7 Drinking Fountain	7/26/16 12:23	8/2/16 15:29	607271322	COPPER	0.5 PPM	1.3 PPM
004-23A Classroom 6 Sink Faucet	7/26/16 12:24	8/2/16 15:29	607271323	COPPER	0.4 PPM	1.3 PPM
004-24A Classroom 6 Drinking Fountain	7/26/16 12:24	8/2/16 15:29	607271324	COPPER	0.5 PPM	1.3 PPM
004-25A Classroom 1 Sink Faucet	7/26/16 12:26	8/2/16 15:29	607271325	COPPER	0.4 PPM	1.3 PPM
004-26A Classroom 1 Drinking Fountain	7/26/16 12:26	8/2/16 15:34	607271326	COPPER	0.5 PPM	1.3 PPM
004-27A Classroom 2 Sink Faucet	7/26/16 12:28	8/2/16 15:35	607271327	COPPER	0.4 PPM	1.3 PPM
004-28A Classroom 2 Drinking Fountain	7/26/16 12:28	8/2/16 15:35	607271328	COPPER	0.4 PPM	1.3 PPM
004-29A Classroom 20 Sink Faucet	7/26/16 12:33	8/2/16 15:35	607271329	COPPER	0.3 PPM	1.3 PPM
004-30A Classroom 20 Drinking Fountain	7/26/16 12:33	8/2/16 15:35	607271330	COPPER	0.4 PPM	1.3 PPM
004-31A Hallway Drinking Fountain 5	7/26/16 12:35	8/2/16 15:35	607271331	COPPER	0.5 PPM	1.3 PPM
004-32A Hallway Drinking Fountain 6	7/26/16 12:35	8/2/16 15:35	607271332	COPPER	0.4 PPM	1.3 PPM
004-33A Classroom 27 Sink Faucet	7/26/16 12:37	8/2/16 15:35	607271333	COPPER	0.3 PPM	1.3 PPM
004-34A Classroom 27 Drinking Fountain	7/26/16 12:37	8/2/16 15:36	607271334	COPPER	0.4 PPM	1.3 PPM
004-35A Classroom 28 Sink Faucet	7/26/16 12:39	8/2/16 15:36	607271335	COPPER	0.3 PPM	1.3 PPM
004-36A Classroom 28 Drinking Fountain	7/26/16 12:39	8/2/16 15:42	607271336	COPPER	0.3 PPM	1.3 PPM
004-37A Classroom 21 Sink Faucet	7/26/16 12:41	8/2/16 15:42	607271337	COPPER	0.4 PPM	1.3 PPM
004-38A Classroom 21 Drinking Fountain	7/26/16 12:41	8/2/16 15:43	607271338	COPPER	0.4 PPM	1.3 PPM
004-39A Classroom 25 Sink Faucet	7/26/16 12:43	8/2/16 15:43	607271339	COPPER	0.3 PPM	1.3 PPM
004-40A Classroom 25 Drinking Fountain	7/26/16 12:43	8/2/16 15:43	607271340	COPPER	0.5 PPM	1.3 PPM
004-41A Classroom 29 Sink Faucet	7/26/16 12:45	8/2/16 15:43	607271341	COPPER	0.3 PPM	1.3 PPM
004-42A Classroom 29 Drinking Fountain	7/26/16 12:45	8/2/16 15:43	607271342	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level