

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Bush Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
004-01A Gymnasium Drinking Fountain 1	7/26/16 11:40	7/29/16 12:49	607271301	LEAD	< 1 PPB	15 PPB
004-02A Gymnasium Drinking Fountain 2	7/26/16 11:42	7/29/16 12:49	607271302	LEAD	< 1 PPB	15 PPB
004-03A Hallway Drinking Fountain 1	7/26/16 11:45	7/29/16 12:49	607271303	LEAD	< 1 PPB	15 PPB
004-04A Hallway Drinking Fountain 2	7/26/16 11:47	7/29/16 12:49	607271304	LEAD	< 1 PPB	15 PPB
004-05A Kitchen Food Prep Sink Faucet	7/26/16 11:56	7/29/16 12:49	607271305	LEAD	2 PPB	15 PPB
004-06A Kitchen Counter Sink Faucet	7/26/16 11:58	7/29/16 12:49	607271306	LEAD	7 PPB	15 PPB
004-07A Pre-school Room 12 Sink Faucet (Left)	7/26/16 12:02	7/29/16 12:49	607271307	LEAD	2 PPB	15 PPB
004-08A Pre-school Room 12 Sink Faucet (Right)	7/26/16 12:02	7/29/16 12:50	607271308	LEAD	< 1 PPB	15 PPB
004-09A Staff Lounge Sink Faucet	7/26/16 12:04	8/1/16 9:29	607271309	LEAD	< 1 PPB	15 PPB
004-10A Nurse/Health Sink Faucet	7/26/16 12:06	8/1/16 9:32	607271310	LEAD	1 PPB	15 PPB
004-11A Nurse/Health Drinking Fountain	7/26/16 12:06	8/1/16 9:32	607271311	LEAD	< 1 PPB	15 PPB
004-12A ERC Room 5 Sink Faucet	7/26/16 12:09	8/1/16 9:32	607271312	LEAD	1 PPB	15 PPB
004-13A LRC Room 4 Sink Faucet	7/26/16 12:11	8/1/16 9:32	607271313	LEAD	3 PPB	15 PPB
004-14A LRC Room 4 Drinking Fountain	7/26/16 12:12	8/1/16 9:33	607271314	LEAD	3 PPB	15 PPB
004-15A Hallway Drinking Fountain 3 (Left)	7/26/16 12:15	8/1/16 9:33	607271315	LEAD	< 1 PPB	15 PPB
004-16A Hallway Drinking Fountain 4 (Right)	7/26/16 12:15	8/2/16 15:21	607271316	LEAD	< 1 PPB	15 PPB
004-17A Classroom 3 Sink Faucet	7/26/16 12:17	8/2/16 15:29	607271317	LEAD	2 PPB	15 PPB
004-18A Classroom 3 Drinking Fountain	7/26/16 12:17	8/2/16 15:29	607271318	LEAD	< 1 PPB	15 PPB
004-19A Classroom 9 Sink Faucet	7/26/16 12:19	8/2/16 15:29	607271319	LEAD	< 1 PPB	15 PPB
004-20A Classroom 9 Drinking Fountain	7/26/16 12:20	8/2/16 15:29	607271320	LEAD	< 1 PPB	15 PPB
004-21A Classroom 7 Sink Faucet	7/26/16 12:22	8/2/16 15:29	607271321	LEAD	1 PPB	15 PPB
004-22A Classroom 7 Drinking Fountain	7/26/16 12:23	8/2/16 15:29	607271322	LEAD	2 PPB	15 PPB
004-23A Classroom 6 Sink Faucet	7/26/16 12:24	8/2/16 15:29	607271323	LEAD	< 1 PPB	15 PPB
004-24A Classroom 6 Drinking Fountain	7/26/16 12:24	8/2/16 15:29	607271324	LEAD	3 PPB	15 PPB
004-25A Classroom 1 Sink Faucet	7/26/16 12:26	8/2/16 15:29	607271325	LEAD	2 PPB	15 PPB
004-26A Classroom 1 Drinking Fountain	7/26/16 12:26	8/2/16 15:34	607271326	LEAD	< 1 PPB	15 PPB
004-27A Classroom 2 Sink Faucet	7/26/16 12:28	8/2/16 15:35	607271327	LEAD	2 PPB	15 PPB
004-28A Classroom 2 Drinking Fountain	7/26/16 12:28	8/2/16 15:35	607271328	LEAD	2 PPB	15 PPB
004-29A Classroom 20 Sink Faucet	7/26/16 12:33	8/2/16 15:35	607271329	LEAD	1 PPB	15 PPB
004-30A Classroom 20 Drinking Fountain	7/26/16 12:33	8/2/16 15:35	607271330	LEAD	< 1 PPB	15 PPB
004-31A Hallway Drinking Fountain 5	7/26/16 12:35	8/2/16 15:35	607271331	LEAD	< 1 PPB	15 PPB
004-32A Hallway Drinking Fountain 6	7/26/16 12:35	8/2/16 15:35	607271332	LEAD	< 1 PPB	15 PPB
004-33A Classroom 27 Sink Faucet	7/26/16 12:37	8/2/16 15:35	607271333	LEAD	2 PPB	15 PPB
004-34A Classroom 27 Drinking Fountain	7/26/16 12:37	8/2/16 15:36	607271334	LEAD	< 1 PPB	15 PPB
004-35A Classroom 28 Sink Faucet	7/26/16 12:39	8/2/16 15:36	607271335	LEAD	1 PPB	15 PPB
004-36A Classroom 28 Drinking Fountain	7/26/16 12:39	8/2/16 15:42	607271336	LEAD	< 1 PPB	15 PPB
004-37A Classroom 21 Sink Faucet	7/26/16 12:41	8/2/16 15:42	607271337	LEAD	1 PPB	15 PPB
004-38A Classroom 21 Drinking Fountain	7/26/16 12:41	8/2/16 15:43	607271338	LEAD	< 1 PPB	15 PPB
004-39A Classroom 25 Sink Faucet	7/26/16 12:43	8/2/16 15:43	607271339	LEAD	< 1 PPB	15 PPB
004-40A Classroom 25 Drinking Fountain	7/26/16 12:43	8/2/16 15:43	607271340	LEAD	3 PPB	15 PPB
004-41A Classroom 29 Sink Faucet	7/26/16 12:45	8/2/16 15:43	607271341	LEAD	1 PPB	15 PPB
004-42A Classroom 29 Drinking Fountain	7/26/16 12:45	8/2/16 15:43	607271342	LEAD	< 1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**