

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Candalaria Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result	Action Level	
05-01A	Hall Corridor D Drinking Fountain 1	7/14/16 10:21	7/24/2016	1607817-01A	Copper	0.7 PPM	1.3 PPM
05-02A	Room 1 Drinking Fountain	7/14/16 10:23	7/24/2016	1607817-02A	Copper	0.4 PPM	1.3 PPM
05-03A	Room 1 Sink Faucet	7/14/16 10:25	7/24/2016	1607817-03A	Copper	0.3 PPM	1.3 PPM
05-04A	Room 2 Drinking Fountain	7/14/16 10:27	7/24/2016	1607817-04A	Copper	0.4 PPM	1.3 PPM
05-05A	Room 2 Sink Faucet	7/14/16 10:29	7/24/2016	1607817-05A	Copper	0.2 PPM	1.3 PPM
05-06A	Room 3 Drinking Fountain	7/14/16 10:32	7/24/2016	1607817-06A	Copper	0.4 PPM	1.3 PPM
05-07A	Room 3 Sink Faucet	7/14/16 10:34	7/24/2016	1607817-07A	Copper	0.4 PPM	1.3 PPM
05-08A	Room 4 Drinking Fountain	7/14/16 10:36	7/24/2016	1607817-08A	Copper	0.5 PPM	1.3 PPM
05-09A	Room 4 Sink Faucet	7/14/16 10:38	7/24/2016	1607817-09A	Copper	0.3 PPM	1.3 PPM
05-10A	Room 5 Sink Faucet	7/14/16 10:40	7/24/2016	1607817-10A	Copper	0.2 PPM	1.3 PPM
05-11A	Room 5 Drinking Fountain	7/14/16 10:42	7/24/2016	1607817-11A	Copper	0.3 PPM	1.3 PPM
05-12A	Hall Corridor D Drinking Fountain 2	7/14/16 10:53	7/24/2016	1607817-12A	Copper	0.2 PPM	1.3 PPM
05-13A	Staff Lounge Sink Faucet	7/14/16 10:55	7/25/2016	1607817-13A	Copper	0.5 PPM	1.3 PPM
05-14A	Room 16 Drinking Fountain	7/14/16 10:47	7/25/2016	1607817-14A	Copper	0.2 PPM	1.3 PPM
05-15A	Room 16 Sink Faucet	7/14/16 10:49	7/25/2016	1607817-15A	Copper	0.2 PPM	1.3 PPM
05-16A	Room 17 Drinking Fountain	7/14/16 10:53	7/25/2016	1607817-16A	Copper	0.2 PPM	1.3 PPM
05-17A	Room 17 Sink Faucet	7/14/16 10:55	7/25/2016	1607817-17A	Copper	0.2 PPM	1.3 PPM
05-18A	Room 10 Sink Faucet	7/14/16 11:00	7/25/2016	1607817-18A	Copper	0.3 PPM	1.3 PPM
05-19A	Room 11 Sink Faucet	7/14/16 11:04	7/25/2016	1607817-19A	Copper	0.1 PPM	1.3 PPM
05-20A	Room 11 Drinking Fountain	7/14/16 11:06	7/25/2016	1607817-20A	Copper	0.3 PPM	1.3 PPM
05-21A	Room 12 Drinking Fountain	7/14/16 11:08	7/25/2016	1607817-21A	Copper	0.3 PPM	1.3 PPM
05-22A	Room 12 Sink Faucet	7/14/16 11:10	7/25/2016	1607817-22A	Copper	0.2 PPM	1.3 PPM
05-23A	Room 9 Drinking Fountain	7/14/16 11:15	7/25/2016	1607817-23A	Copper	0.4 PPM	1.3 PPM
05-24A	Room 9 Sink Faucet	7/14/16 11:17	7/25/2016	1607817-24A	Copper	0.2 PPM	1.3 PPM
05-25A	Room 13 Drinking Fountain	7/14/16 11:21	7/25/2016	1607817-25A	Copper	0.2 PPM	1.3 PPM
05-26A	Room 13 Sink Faucet	7/14/16 11:23	7/25/2016	1607817-26A	Copper	0.3 PPM	1.3 PPM
05-27A	Room 8 Sink Faucet	7/14/16 11:25	7/25/2016	1607817-27A	Copper	0.2 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Candalaria Elementary School

05-28A	Room 14 Drinking Fountain	7/14/16 11:29	7/25/2016	1607817-28A	Copper	0.2 PPM	1.3 PPM
05-29A	Room 14 Sink Faucet	7/14/16 11:31	7/25/2016	1607817-29A	Copper	0.1 PPM	1.3 PPM
05-30A	Room 15 Drinking Fountain	7/14/16 11:34	7/25/2016	1607817-30A	Copper	0.2 PPM	1.3 PPM
05-31A	Room 15 Sink Faucet	7/14/16 11:36	7/25/2016	1607817-31A	Copper	0.1 PPM	1.3 PPM
05-32A	Hall Corridor J Drinking Fountain 3	7/14/16 11:39	7/25/2016	1607817-32A	Copper	0.3 PPM	1.3 PPM
05-33A	Nurse/Health Room Sink Faucet	7/14/16 11:41	7/24/2016	1607817-33A	Copper	0.0 PPM	1.3 PPM
05-34A	Drinking Fountain Hall 4	7/14/16 10:15	7/24/2016	1607817-34A	Copper	0.3 PPM	1.3 PPM
05-35A	Mulit-Purpose Room Drinking Fountain	7/14/16 10:17	7/24/2016	1607817-35A	Copper	0.3 PPM	1.3 PPM
05-36A	Kitchen Food Prep Sink Faucet	7/14/16 10:19	7/24/2016	1607817-36A	Copper	0.2 PPM	1.3 PPM
05-37A	Room 10 Drinking Fountain	7/14/16 11:02	7/24/2016	1607817-37A	Copper	0.4 PPM	1.3 PPM
05-38A	Room 8 Drinking Fountain	7/14/16 11:27	7/24/2016	1607817-38A	Copper	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level