

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Candalaria Elementary School

Sample Identification # and Location		Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
05-01A	Hall Corridor D Drinking Fountain 1	7/14/16 10:21	7/24/2016	1607817-01A	LEAD	1 PPB	15 PPB
05-02A	Room 1 Drinking Fountain	7/14/16 10:23	7/24/2016	1607817-02A	LEAD	<1.0 PPB	15 PPB
05-03A	Room 1 Sink Faucet	7/14/16 10:25	7/24/2016	1607817-03A	LEAD	1 PPB	15 PPB
05-04A	Room 2 Drinking Fountain	7/14/16 10:27	7/24/2016	1607817-04A	LEAD	<1.0 PPB	15 PPB
05-05A	Room 2 Sink Faucet	7/14/16 10:29	7/24/2016	1607817-05A	LEAD	<1.0 PPB	15 PPB
05-06A	Room 3 Drinking Fountain	7/14/16 10:32	7/24/2016	1607817-06A	LEAD	1 PPB	15 PPB
05-07A	Room 3 Sink Faucet	7/14/16 10:34	7/24/2016	1607817-07A	LEAD	3 PPB	15 PPB
05-08A	Room 4 Drinking Fountain	7/14/16 10:36	7/24/2016	1607817-08A	LEAD	<1.0 PPB	15 PPB
05-09A	Room 4 Sink Faucet	7/14/16 10:38	7/24/2016	1607817-09A	LEAD	2 PPB	15 PPB
05-10A	Room 5 Sink Faucet	7/14/16 10:40	7/24/2016	1607817-10A	LEAD	3 PPB	15 PPB
05-11A	Room 5 Drinking Fountain	7/14/16 10:42	7/24/2016	1607817-11A	LEAD	9 PPB	15 PPB
05-12A	Hall Corridor D Drinking Fountain 2	7/14/16 10:53	7/24/2016	1607817-12A	LEAD	<1.0 PPB	15 PPB
05-13A	Staff Lounge Sink Faucet	7/14/16 10:55	7/25/2016	1607817-13A	LEAD	2 PPB	15 PPB
05-14A	Room 16 Drinking Fountain	7/14/16 10:47	7/25/2016	1607817-14A	LEAD	2 PPB	15 PPB
05-15A	Room 16 Sink Faucet	7/14/16 10:49	7/25/2016	1607817-15A	LEAD	2 PPB	15 PPB
05-16A	Room 17 Drinking Fountain	7/14/16 10:53	7/25/2016	1607817-16A	LEAD	<1.0 PPB	15 PPB
05-17A	Room 17 Sink Faucet	7/14/16 10:55	7/25/2016	1607817-17A	LEAD	<1.0 PPB	15 PPB
05-18A	Room 10 Sink Faucet	7/14/16 11:00	7/25/2016	1607817-18A	LEAD	1 PPB	15 PPB
05-19A	Room 11 Sink Faucet	7/14/16 11:04	7/25/2016	1607817-19A	LEAD	<1.0 PPB	15 PPB
05-20A	Room 11 Drinking Fountain	7/14/16 11:06	7/25/2016	1607817-20A	LEAD	3 PPB	15 PPB
05-21A	Room 12 Drinking Fountain	7/14/16 11:08	7/25/2016	1607817-21A	LEAD	1 PPB	15 PPB
05-22A	Room 12 Sink Faucet	7/14/16 11:10	7/25/2016	1607817-22A	LEAD	1 PPB	15 PPB
05-23A	Room 9 Drinking Fountain	7/14/16 11:15	7/25/2016	1607817-23A	LEAD	1 PPB	15 PPB
05-24A	Room 9 Sink Faucet	7/14/16 11:17	7/25/2016	1607817-24A	LEAD	2 PPB	15 PPB
05-25A	Room 13 Drinking Fountain	7/14/16 11:21	7/25/2016	1607817-25A	LEAD	<1.0 PPB	15 PPB
05-26A	Room 13 Sink Faucet	7/14/16 11:23	7/25/2016	1607817-26A	LEAD	3 PPB	15 PPB
05-27A	Room 8 Sink Faucet	7/14/16 11:25	7/25/2016	1607817-27A	LEAD	5 PPB	15 PPB
05-28A	Room 14 Drinking Fountain	7/14/16 11:29	7/25/2016	1607817-28A	LEAD	1 PPB	15 PPB
05-29A	Room 14 Sink Faucet	7/14/16 11:31	7/25/2016	1607817-29A	LEAD	3 PPB	15 PPB
05-30A	Room 15 Drinking Fountain	7/14/16 11:34	7/25/2016	1607817-30A	LEAD	2 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Candalaria Elementary School

05-31A	Room 15 Sink Faucet	7/14/16 11:36	7/25/2016	1607817-31A	LEAD	3	PPB	15 PPB
05-32A	Hall Corridor J Drinking Fountain 3	7/14/16 11:39	7/25/2016	1607817-32A	LEAD	1	PPB	15 PPB
05-33A	Nurse/Health Room Sink Faucet	7/14/16 11:41	7/24/2016	1607817-33A	LEAD	<1.0	PPB	15 PPB
05-34A	Drinking Fountain Hall 4	7/14/16 10:15	7/24/2016	1607817-34A	LEAD	<1.0	PPB	15 PPB
05-35A	Mult-Purpose Room Drinking Fountain	7/14/16 10:17	7/24/2016	1607817-35A	LEAD	<1.0	PPB	15 PPB
05-36A	Kitchen Food Prep Sink Faucet	7/14/16 10:19	7/24/2016	1607817-36A	LEAD	<1.0	PPB	15 PPB
05-37A	Room 10 Drinking Fountain	7/14/16 11:02	7/24/2016	1607817-37A	LEAD	<1.0	PPB	15 PPB
05-38A	Room 8 Drinking Fountain	7/14/16 11:27	7/24/2016	1607817-38A	LEAD	2	PPB	15 PPB

EPA Action Level for Copper in Schools is 20 PPB

SKPS Action Level for Copper is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level