

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Cesar Chavez Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
007-01A Kitchen Food Prep Sink Faucet	7/26/16 8:11	8/1/2016	1607C83-01A	LEAD	<1.0 PPB	15 PPB
007-02A Cafeteria Drinking Fountain (1)	7/27/16 8:00	8/2/2016	1607C83-02A	LEAD	<1.0 PPB	15 PPB
007-03A Cafeteria Drinking Fountain (1)	7/27/16 8:03	8/2/2016	1607C83-03A	LEAD	<1.0 PPB	15 PPB
007-04A Music Room Sink Faucet	7/27/16 8:23	8/1/2016	1607C83-04A	LEAD	1 PPB	15 PPB
007-05A Music Room Drinking Fountain (1)	7/27/16 8:25	8/1/2016	1607C83-05A	LEAD	<1.0 PPB	15 PPB
007-06A Music Room Drinking Fountain (2)	7/27/16 8:17	8/2/2016	1607C83-06A	LEAD	7 PPB	15 PPB
007-07A Music Room Drinking Fountain (3)	7/27/16 8:19	8/2/2016	1607C83-07A	LEAD	4 PPB	15 PPB
007-08A Hall Drinking Fountain 1	7/27/16 7:27	8/1/2016	1607C83-08A	LEAD	<1.0 PPB	15 PPB
007-09A Hall Drinking Fountain 2	7/27/16 7:32	8/1/2016	1607C83-09A	LEAD	<1.0 PPB	15 PPB
007-10A Staff Lounge Refrigerator Ice Maker 1	7/27/16 9:05	8/1/2016	1607C83-10A	LEAD	10 PPB	15 PPB
007-11A Staff Lounge Refrigerator Ice Maker 2	7/27/16 9:00	8/1/2016	1607C83-11A	LEAD	8 PPB	15 PPB
007-12A Staff Lounge Sink Faucet	7/27/16 7:36	8/1/2016	1607C83-12A	LEAD	<1.0 PPB	15 PPB
007-13A Health Room Sink Faucet	7/27/16 7:37	8/1/2016	1607C83-13A	LEAD	<1.0 PPB	15 PPB
007-15A Gymnasium Drinking Fountain	7/27/16 8:53	8/1/2016	1607C83-14A	LEAD	<1.0 PPB	15 PPB
007-16A Gymnasium Drinking Fountain	7/27/16 8:54	8/1/2016	1607C83-15A	LEAD	<1.0 PPB	15 PPB
007-17A Room 101 Sink Faucet	7/27/16 7:29	8/1/2016	1607C83-16A	LEAD	1 PPB	15 PPB
007-18A Room 101 Drinking Fountain	7/27/16 7:29	8/1/2016	1607C83-17A	LEAD	<1.0 PPB	15 PPB
007-19A Room 102 Sink Faucet	7/27/16 7:31	8/1/2016	1607C83-18A	LEAD	2 PPB	15 PPB
007-20A Room 102 Drinking Fountain	7/27/16 7:31	8/1/2016	1607C83-19A	LEAD	<1.0 PPB	15 PPB
007-21A Room 112 Sink Faucet	7/27/16 7:33	8/1/2016	1607C83-20A	LEAD	2 PPB	15 PPB
007-22A Room 112 Drinking Fountain	7/27/16 7:33	8/1/2016	1607C83-21A	LEAD	<1.0 PPB	15 PPB
007-24A PLC 118 Sink Faucet	7/27/16 7:35	8/1/2016	1607C83-22A	LEAD	<1.0 PPB	15 PPB
007-25A Hall Drinking Fountain 3	7/27/16 7:38	8/1/2016	1607C83-23A	LEAD	1 PPB	15 PPB
007-26A Hall Drinking Fountain 4	7/27/16 7:39	8/1/2016	1607C83-24A	LEAD	<1.0 PPB	15 PPB
007-27A Room 103 Sink Faucet	7/27/16 7:41	8/1/2016	1607C83-25A	LEAD	1 PPB	15 PPB
007-28A Room 103 Drinking Fountain	7/27/16 7:41	8/1/2016	1607C83-26A	LEAD	<1.0 PPB	15 PPB
007-29A Room 104 Sink Faucet	7/27/16 7:47	8/1/2016	1607C83-27A	LEAD	1 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Cesar Chavez Elementary School

007-30A	Room 104 Drinking Fountain	7/27/16 7:47	8/2/2016	1607C83-28A	LEAD	<1.0 PPB	15 PPB
007-31A	Room 110 Sink Faucet	7/27/16 7:44	8/1/2016	1607C83-29A	LEAD	<1.0 PPB	15 PPB
007-32A	Room 110 Drinking Fountain	7/27/16 7:44	8/2/2016	1607C83-30A	LEAD	<1.0 PPB	15 PPB
007-33A	Room 109 Sink Faucet	7/27/16 7:49	8/1/2016	1607C83-31A	LEAD	<1.0 PPB	15 PPB
007-34A	Room 109 Drinking Fountain	7/27/16 7:49	8/2/2016	1607C83-32A	LEAD	<1.0 PPB	15 PPB
007-35A	Room 105 Sink Faucet	7/27/16 7:52	8/1/2016	1607C83-33A	LEAD	<1.0 PPB	15 PPB
007-36A	Room 105 Drinking Fountain	7/27/16 7:52	8/2/2016	1607C83-34A	LEAD	<1.0 PPB	15 PPB
007-37A	Room 108 Sink Faucet	7/27/16 7:54	8/1/2016	1607C83-35A	LEAD	2 PPB	15 PPB
007-38A	Room 108 Drinking Fountain	7/27/16 7:54	8/2/2016	1607C83-36A	LEAD	<1.0 PPB	15 PPB
007-39A	Room 106 Sink Faucet	7/27/16 8:00	8/1/2016	1607C83-37A	LEAD	<1.0 PPB	15 PPB
007-40A	Room 106 Drinking Fountain	7/27/16 8:00	8/2/2016	1607C83-38A	LEAD	<1.0 PPB	15 PPB
007-41A	Room 107 Sink Faucet	7/27/16 7:57	8/1/2016	1607C83-39A	LEAD	<1.0 PPB	15 PPB
007-42A	Room 108 Drinking Fountain	7/27/16 7:57	8/2/2016	1607C83-40A	LEAD	<1.0 PPB	15 PPB
007-43A	Room 210 Sink Faucet	7/27/16 8:40	8/1/2016	1607C83-41A	LEAD	<1.0 PPB	15 PPB
007-44A	Room 210 Drinking Fountain	7/27/16 8:40	8/2/2016	1607C83-42A	LEAD	<1.0 PPB	15 PPB
007-45A	Room 209 Sink Faucet	7/27/16 8:42	8/1/2016	1607C83-43A	LEAD	<1.0 PPB	15 PPB
007-46A	Room 209 Drinking Fountain	7/27/16 8:42	8/2/2016	1607C83-44A	LEAD	<1.0 PPB	15 PPB
007-47A	Room 211 Sink Faucet	7/27/16 8:45	8/1/2016	1607C83-45A	LEAD	<1.0 PPB	15 PPB
007-48A	Room 211 Drinking Fountain	7/27/16 8:45	8/2/2016	1607C83-46A	LEAD	<1.0 PPB	15 PPB
007-49A	Room 208 Drinking Fountain	7/27/16 8:48	8/1/2016	1607C83-47A	LEAD	1 PPB	15 PPB
007-50A	Room 208 Sink Faucet	7/27/16 8:48	8/2/2016	1607C83-48A	LEAD	<1.0 PPB	15 PPB
007-51A	PLC 211 Refrigerator Ice Maker	7/27/16 8:50	8/2/2016	1607C83-49A	LEAD	5 PPB	15 PPB
007-52A	PLC 211 Sink Faucet	7/27/16 8:50	8/1/2016	1607C83-50A	LEAD	1 PPB	15 PPB
007-53A	Room 212 Sink Faucet	7/27/16 8:54	8/1/2016	1607C83-51A	LEAD	2 PPB	15 PPB
007-54A	Room 212 Drinking Fountain	7/27/16 8:54	8/2/2016	1607C83-52A	LEAD	<1.0 PPB	15 PPB
007-55A	Room 213 Sink Faucet	7/27/16 8:56	8/1/2016	1607C83-53A	LEAD	2 PPB	15 PPB
007-56A	Room 213 Drinking Fountain	7/27/16 8:56	8/2/2016	1607C83-54A	LEAD	<1.0 PPB	15 PPB
007-57A	Room 207 Sink Faucet	7/27/16 8:58	8/1/2016	1607C83-55A	LEAD	1 PPB	15 PPB
007-58A	Room 207 Drinking Fountain	7/27/16 8:58	8/2/2016	1607C83-56A	LEAD	<1.0 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Cesar Chavez Elementary School

007-59A	Room 206 Sink Faucet	7/27/16 9:02	8/1/2016	1607C83-57A	LEAD	3	PPB	15 PPB
007-60A	Room 206 Drinking Fountain	7/27/16 9:02	8/2/2016	1607C83-58A	LEAD	<1.0	PPB	15 PPB
007-61A	PLC 206 Refrigerator Ice Maker	7/27/16 9:07	8/2/2016	1607C83-59A	LEAD	14	PPB	15 PPB
007-62A	PLC 206 Sink Faucet	7/27/16 9:07	8/1/2016	1607C83-60A	LEAD	<1.0	PPB	15 PPB
007-63A	Hall Drinking Fountain 5	7/27/16 9:04	8/1/2016	1607C83-61A	LEAD	<1.0	PPB	15 PPB
007-64A	Hall Drinking Fountain 6	7/27/16 9:05	8/2/2016	1607C83-62A	LEAD	<1.0	PPB	15 PPB
007-65A	Room 214 Sink Faucet	7/27/16 9:12	8/1/2016	1607C83-63A	LEAD	2	PPB	15 PPB
007-66A	Room 244 Drinking Fountain	7/27/16 9:12	8/2/2016	1607C83-64A	LEAD	<1.0	PPB	15 PPB
007-67A	Room 215 Sink Faucet	7/27/16 9:15	8/1/2016	1607C83-65A	LEAD	<1.0	PPB	15 PPB
007-68A	Room 215 Drinking Fountain	7/27/16 9:15	8/1/2016	1607C83-66A	LEAD	<1.0	PPB	15 PPB
007-69A	Room 205 Sink Faucet	7/27/16 9:14	8/1/2016	1607C83-67A	LEAD	2	PPB	15 PPB
007-70A	Room 205 Drinking Fountain	7/27/16 9:14	8/1/2016	1607C83-68A	LEAD	<1.0	PPB	15 PPB
007-71A	Room 204 Sink Faucet	7/27/16 9:17	8/2/2016	1607C83-69A	LEAD	<1.0	PPB	15 PPB
007-72A	Room 204 Drinking Fountain	7/27/16 9:17	8/2/2016	1607C83-70A	LEAD	<1.0	PPB	15 PPB
007-73A	LRC 203 Sink Faucet	7/27/16 9:20	8/1/2016	1607C83-71A	LEAD	<1.0	PPB	15 PPB
007-74A	LRC 203 Drinking Fountain	7/27/16 9:20	8/1/2016	1607C83-72A	LEAD	<1.0	PPB	15 PPB
007-75A	Hall Drinking Fountain 7	7/27/16 9:23	8/1/2016	1607C83-73A	LEAD	<1.0	PPB	15 PPB
007-76A	Hall Drinking Fountain 8	7/27/16 9:24	8/1/2016	1607C83-74A	LEAD	2	PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Cesar Chavez Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
007-23A PLC 118 Refrigerator Ice Maker	9/30/2016 6:20	10/3/2016	59711	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
Cesar Chavez Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
007-06B Music Room Drinking Fountain (2)	7/27/16 8:18	8/23/2016	1607C84-06A	LEAD	2 PPB	15 PPB
007-07B Music Room Drinking Fountain (3)	7/27/16 8:20	8/23/2016	1607C84-07A	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level