

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Crossler Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
044-01A Music 121 Drinking Fountain (Left)	7/28/16 11:44	8/3/16 12:26	607291301	LEAD	< 1 PPB	15 PPB
044-02A Music 121 Drinking Fountain (Right)	7/28/16 11:46	8/3/16 12:26	607291302	LEAD	< 1 PPB	15 PPB
044-03A Shop 123 Drinking Fountain (Left)	7/28/16 11:48	8/3/16 12:27	607291303	LEAD	< 1 PPB	15 PPB
044-04A Shop 123 Drinking Fountain (Right)	7/28/16 11:50	8/3/16 12:27	607291304	LEAD	< 1 PPB	15 PPB
044-05A Classroom 122 Sink Faucet	7/28/16 11:51	8/3/16 12:27	607291305	LEAD	4 PPB	15 PPB
044-06A Classroom 122 Drinking Fountain	7/28/16 11:51	8/3/16 12:27	607291306	LEAD	2 PPB	15 PPB
044-07A Choir 120 Drinking Fountain (Left)	7/28/16 11:55	8/3/16 12:27	607291307	LEAD	< 1 PPB	15 PPB
044-08A Choir 120 Drinking Fountain (Right)	7/28/16 11:57	8/3/16 12:30	607291308	LEAD	< 1 PPB	15 PPB
044-09A Main Gymnasium Drinking Fountain (Left)	7/28/16 11:59	8/3/16 12:31	607291309	LEAD	< 1 PPB	15 PPB
044-10A Main Gymnasium Drinking Fountain (Right)	7/28/16 12:00	8/3/16 12:31	607291310	LEAD	2 PPB	15 PPB
044-11A Auxillary Gymnasium Drinking Fountain (Left)	7/28/16 12:03	8/3/16 12:31	607291311	LEAD	< 1 PPB	15 PPB
044-12A Auxillary Gymnasium Drinking Fountain (Right)	7/28/16 12:04	8/3/16 12:31	607291312	LEAD	2 PPB	15 PPB
044-13A Girls Lockers Drinking Fountain (Left)	7/28/16 12:06	8/3/16 12:32	607291313	LEAD	1 PPB	15 PPB
044-14A Girls Lockers Drinking Fountain (Right)	7/28/16 12:07	8/3/16 12:32	607291314	LEAD	1 PPB	15 PPB
044-15A Boys Lockers Drinking Fountain (Left)	7/28/16 12:10	8/3/16 12:32	607291315	LEAD	1 PPB	15 PPB
044-16A Boys Lockers Drinking Fountain (Right)	7/28/16 12:11	8/3/16 12:34	607291316	LEAD	1 PPB	15 PPB
044-17A Home Economics Sink Faucet 1	7/28/16 12:21	8/3/16 12:34	607291317	LEAD	4 PPB	15 PPB
044-18A Home Economics Sink Faucet 2	7/28/16 14:29	8/3/16 12:43	607291318	LEAD	4 PPB	15 PPB
044-19A Home Economics Sink Faucet 3	7/28/16 12:23	8/3/16 12:44	607291319	LEAD	4 PPB	15 PPB
044-20A Home Economics Sink Faucet 4	7/28/16 12:24	8/3/16 12:44	607291320	LEAD	3 PPB	15 PPB
044-21A Home Economics Sink Faucet 5	7/28/16 12:25	8/3/16 12:44	607291321	LEAD	5 PPB	15 PPB
044-22A Home Economics Sink Faucet 6	7/28/16 12:26	8/3/16 12:44	607291322	LEAD	3 PPB	15 PPB
044-23A Home Economics Refrigerator Ice Maker 1	7/28/16 12:28	8/3/16 12:45	607291323	LEAD	< 1 PPB	15 PPB
044-24A Home Economics Refrigerator Ice Maker 2	7/28/16 12:30	8/3/16 12:45	607291324	LEAD	< 1 PPB	15 PPB
044-27A Student Store Sink Faucet	7/28/16 12:36	8/3/16 12:49	607291325	LEAD	4 PPB	15 PPB
044-28A Hallway Drinking Fountain 1	7/28/16 12:39	8/3/16 12:49	607291326	LEAD	< 1 PPB	15 PPB
044-29A Hallway Drinking Fountain 2	7/28/16 12:40	8/3/16 12:49	607291327	LEAD	< 1 PPB	15 PPB
044-30A Commons Drinking Fountain (Left)	7/28/16 12:43	8/3/16 12:52	607291328	LEAD	< 1 PPB	15 PPB
044-31A Commons Drinking Fountain (Right)	7/28/16 12:44	8/3/16 12:53	607291329	LEAD	< 1 PPB	15 PPB
044-32A Kitchen Ice Maker	7/28/16 12:49	8/3/16 12:53	607291330	LEAD	< 1 PPB	15 PPB
044-33A Kitchen Food Prep Sink Faucet	7/28/16 12:52	8/3/16 12:53	607291331	LEAD	3 PPB	15 PPB
044-34A Hallway Drinking Fountain 3	7/28/16 12:57	8/3/16 12:53	607291332	LEAD	< 1 PPB	15 PPB
044-35A Hallway Drinking Fountain 4	7/28/16 12:58	8/3/16 12:53	607291333	LEAD	< 1 PPB	15 PPB
044-36A Hallway Drinking Fountain 5	7/28/16 13:01	8/3/16 12:54	607291334	LEAD	< 1 PPB	15 PPB
044-37A Hallway Drinking Fountain 6	7/28/16 13:02	8/3/16 12:54	607291335	LEAD	< 1 PPB	15 PPB
044-38A Room 116 Sink Faucet	7/28/16 13:04	8/3/16 12:54	607291336	LEAD	8 PPB	15 PPB
044-39A Room 115 Sink Faucet	7/28/16 13:06	8/3/16 12:54	607291337	LEAD	7 PPB	15 PPB
044-40A Room 115 Drinking Fountain	7/28/16 13:06	8/3/16 12:57	607291338	LEAD	3 PPB	15 PPB
044-41A Room 114 Sink Faucet	7/28/16 13:09	8/3/16 12:57	607291339	LEAD	2 PPB	15 PPB
044-42A Room 114 Drinking Fountain	7/28/16 13:09	8/3/16 12:58	607291340	LEAD	3 PPB	15 PPB
044-43A Room 113 Sink Faucet	7/28/16 13:13	8/3/16 12:58	607291341	LEAD	< 1 PPB	15 PPB
044-44A Room 113 Drinking Fountain	7/28/16 13:13	8/3/16 13:00	607291342	LEAD	< 1 PPB	15 PPB
044-45A Room 112 Sink Faucet	7/28/16 13:16	8/3/16 13:00	607291343	LEAD	4 PPB	15 PPB
044-46A Room 112 Drinking Fountain	7/28/16 13:16	8/3/16 13:00	607291344	LEAD	1 PPB	15 PPB
044-47A Room 111 Drinking Fountain	7/28/16 13:20	8/3/16 13:00	607291345	LEAD	1 PPB	15 PPB
044-48A Room 111 Sink Faucet	7/28/16 13:20	8/3/16 13:01	607291346	LEAD	3 PPB	15 PPB
044-49A Room 110 Sink Faucet	7/28/16 13:23	8/3/16 13:04	607291347	LEAD	< 1 PPB	15 PPB
044-50A Room 110 Drinking Fountain	7/28/16 13:24	8/3/16 13:48	607291348	LEAD	2 PPB	15 PPB
044-51A Hallway Drinking Fountain 7	7/28/16 13:30	8/3/16 13:49	607291349	LEAD	< 1 PPB	15 PPB
044-52A Hallway Drinking Fountain 8	7/28/16 13:30	8/3/16 13:49	607291350	LEAD	< 1 PPB	15 PPB
044-53A Classroom 108 Drinking Fountain	7/28/16 13:34	8/3/16 13:49	607291351	LEAD	1 PPB	15 PPB
044-54A Classroom 108 Sink Faucet	7/28/16 13:33	8/3/16 13:49	607291352	LEAD	2 PPB	15 PPB
044-55A Classroom 101 Sink Faucet	7/28/16 13:38	8/3/16 13:49	607291353	LEAD	6 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Crossler Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
044-56A Classroom 101 Drinking Fountain	7/28/16 13:38	8/3/16 13:50	607291354	LEAD	7 PPB	15 PPB
044-57A Classroom 103 Sink Faucet	7/28/16 13:48	8/3/16 13:50	607291355	LEAD	6 PPB	15 PPB
044-58A Classroom 103 Drinking Fountain	7/28/16 13:42	8/3/16 13:50	607291356	LEAD	< 1 PPB	15 PPB
044-59A Classroom 104 Drinking Fountain	7/28/16 13:45	8/3/16 13:50	607291357	LEAD	4 PPB	15 PPB
044-60A Classroom 104 Sink Faucet	7/28/16 13:45	8/5/16 13:03	607291358	LEAD	1 PPB	15 PPB
044-61A Classroom 105 Sink Faucet	7/28/16 13:49	8/5/16 13:04	607291359	LEAD	64 PPB	15 PPB
044-62A Classroom 105 Drinking Fountain	7/28/16 13:56	8/5/16 13:04	607291360	LEAD	3 PPB	15 PPB
044-63A Staff Lounge Sink Faucet	7/28/16 12:55	8/5/16 13:04	607291361	LEAD	6 PPB	15 PPB
044-64A Hallway Drinking Fountain 9	7/28/16 12:42	8/5/16 13:04	607291362	LEAD	1 PPB	15 PPB
044-65A Hallway Drinking Fountain 10	7/28/16 12:44	8/5/16 13:04	607291363	LEAD	1 PPB	15 PPB
044-66A Classroom 209 Drinking Fountain	7/28/16 12:49	8/5/16 13:04	607291364	LEAD	6 PPB	15 PPB
044-67A Classroom 209 Sink Faucet	7/28/16 12:51	8/5/16 13:04	607291365	LEAD	4 PPB	15 PPB
044-68A Room 207 Sink Faucet	7/28/16 12:55	8/5/16 13:04	607291366	LEAD	6 PPB	15 PPB
044-69A Classroom 206 Sink Faucet	7/28/16 12:58	8/5/16 13:04	607291367	LEAD	4 PPB	15 PPB
044-70A Classroom 206 Drinking Fountain	7/28/16 13:00	8/5/16 13:04	607291368	LEAD	3 PPB	15 PPB
044-71A Classroom 201 Sink Faucet	7/28/16 13:02	8/5/16 13:04	607291369	LEAD	4 PPB	15 PPB
044-72A Classroom 201 Drinking Fountain	7/28/16 13:04	8/5/16 13:04	607291370	LEAD	< 1 PPB	15 PPB
044-73A Classroom 202 Sink Faucet	7/28/16 13:05	8/5/16 13:04	607291371	LEAD	3 PPB	15 PPB
044-74A Classroom 202 Drinking Fountain	7/28/16 13:07	8/5/16 13:04	607291372	LEAD	< 1 PPB	15 PPB
044-75A Classroom 203 Drinking Fountain	7/28/16 13:09	8/5/16 13:04	607291373	LEAD	3 PPB	15 PPB
044-76A Classroom 203 Sink Faucet	7/28/16 13:11	8/5/16 13:04	607291374	LEAD	3 PPB	15 PPB
044-77A Classroom 204 Sink Faucet	7/28/16 13:13	8/5/16 13:04	607291375	LEAD	5 PPB	15 PPB
044-78A Classroom 204 Drinking Fountain	7/28/16 13:15	8/5/16 13:04	607291376	LEAD	2 PPB	15 PPB
044-79A Classroom 205 Drinking Fountain	7/28/16 13:17	8/5/16 13:04	607291377	LEAD	< 1 PPB	15 PPB
044-80A Classroom 205 Sink Faucet	7/28/16 13:19	8/5/16 13:04	607291378	LEAD	3 PPB	15 PPB
044-81A Hallway Drinking Fountain 11	7/28/16 13:20	8/5/16 13:05	607291379	LEAD	< 1 PPB	15 PPB
044-82A Hallway Drinking Fountain 12	7/28/16 13:22	8/5/16 13:05	607291380	LEAD	< 1 PPB	15 PPB
044-83A Classroom 200 Sink Faucet	7/28/16 12:46	8/5/16 13:05	607291381	LEAD	7 PPB	15 PPB
044-84A Classroom 200 Drinking Fountain	7/28/16 12:48	8/5/16 13:06	6072913101	LEAD	3 PPB	15 PPB
044-85A Classroom 218 Drinking Fountain	7/28/16 13:24	8/5/16 13:05	607291382	LEAD	3 PPB	15 PPB
044-86A Classroom 218 Sink Faucet	7/28/16 13:26	8/5/16 13:05	607291383	LEAD	2 PPB	15 PPB
044-87A Room 216 Sink Faucet	7/28/16 13:30	8/5/16 13:05	607291384	LEAD	< 1 PPB	15 PPB
044-88A Classroom 215 Sink Faucet	7/28/16 13:32	8/5/16 13:05	607291385	LEAD	5 PPB	15 PPB
044-89A Classroom 215 Drinking Fountain	7/28/16 13:34	8/5/16 13:05	607291386	LEAD	2 PPB	15 PPB
044-90A Classroom 210 Sink Faucet	7/28/16 13:38	8/5/16 13:05	607291387	LEAD	5 PPB	15 PPB
044-91A Classroom 210 Drinking Fountain	7/28/16 13:38	8/5/16 13:05	607291388	LEAD	2 PPB	15 PPB
044-92A Classroom 211 Sink Faucet	7/28/16 13:40	8/5/16 13:05	607291389	LEAD	1 PPB	15 PPB
044-93A Classroom 211 Drinking Fountain	7/28/16 13:42	8/5/16 13:05	607291390	LEAD	2 PPB	15 PPB
044-94A Classroom 212 Drinking Fountain	7/28/16 13:45	8/5/16 13:05	607291391	LEAD	6 PPB	15 PPB
044-95A Classroom 212 Sink Faucet	7/28/16 13:47	8/5/16 13:05	607291392	LEAD	3 PPB	15 PPB
044-96A Classroom 213 Sink Faucet	7/28/16 13:50	8/5/16 13:05	607291393	LEAD	2 PPB	15 PPB
044-97A Classroom 213 Drinking Fountain	7/28/16 13:52	8/5/16 13:05	607291394	LEAD	1 PPB	15 PPB
044-98A Classroom 214 Drinking Fountain	7/28/16 13:56	8/5/16 13:05	607291395	LEAD	2 PPB	15 PPB
044-99A Classroom 214 Sink Faucet	7/28/16 13:58	8/5/16 13:05	607291396	LEAD	3 PPB	15 PPB
044-100A Classroom 219 Drinking Fountain	7/28/16 14:02	8/5/16 13:05	607291397	LEAD	8 PPB	15 PPB
044-101A Classroom 215 Sink Faucet	7/28/16 14:04	8/5/16 13:05	607291398	LEAD	8 PPB	15 PPB
044-102A Hallway Drinking Fountain 12	7/28/16 14:00	8/5/16 13:06	607291399	LEAD	5 PPB	15 PPB
044-103A Hallway Drinking Fountain 13	7/28/16 14:04	8/5/16 13:06	6072913100	LEAD	4 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Crossler Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
044-25A Home Economics Refrigerator Ice Maker #3	9/22/2016 5:50	9/26/2016	57951	LEAD	<1 PPB	15 PPB
044-26A Home Economics Refrigerator Ice Maker #4	9/22/2016 5:51	9/26/2016	57952	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
Crossler Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
044-61B Classroom 105 Sink Faucet	7/28/16 13:50	8/24/16 12:48	608173901	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (C) Sample Data
Crossler Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
044-61C Classroom 105 Sink Faucet	10/27/16 4:27	10/28/16 0:00	65867	LEAD	13 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level