

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Cummings Elementary School

| Sample Identification # and Location            | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results    | Action Level |
|---|-------------------|---------------|--------------|------------|------------|--------------|
| 11-01A Drinking Fountain Corridor 32 at Room 9  | 7/28/2016 9:22    | 8/17/2016     | 47538        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-02A Media Center Office Sink Faucet          | 7/28/2016 9:26    | 8/17/2016     | 47539        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-03A LRC Office Sink Faucet                   | 7/28/2016 9:30    | 8/17/2016     | 47540        | COPPER     | 0.1 PPM    | 1.3 PPM      |
| 11-04A Classroom 8 Sink Faucet                  | 7/28/2016 9:37    | 8/17/2016     | 47541        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-05A Classroom 8 Drinking Fountain            | 7/28/2016 9:39    | 8/17/2016     | 47542        | COPPER     | <0.005 PPM | 1.3 PPM      |
| 11-06A Classroom 9 Sink Faucet                  | 7/28/2016 9:41    | 8/17/2016     | 47543        | COPPER     | 0.1 PPM    | 1.3 PPM      |
| 11-07A Classroom 9 Drinking Fountain            | 7/28/2016 9:41    | 8/17/2016     | 47544        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-08A Classroom 7 Sink Faucet                  | 7/28/2016 9:49    | 8/17/2016     | 47545        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-09A Classroom 7 Drinking Fountain            | 7/28/2016 9:49    | 8/17/2016     | 47546        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-10A Classroom 1 Sink Faucet                  | 7/28/2016 9:54    | 8/17/2016     | 47547        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-11A Classroom 1 Drinking Fountain            | 7/28/2016 9:54    | 8/17/2016     | 47548        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-12A Corridor 32A Drinking Fountain at Room 6 | 7/28/2016 9:57    | 8/17/2016     | 47549        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-13A Classroom 2 Sink Faucet                  | 7/28/2016 10:02   | 8/17/2016     | 47550        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-14A Classroom 2 Drinking Fountain            | 7/28/2016 10:02   | 8/17/2016     | 47551        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-15A Classroom 6 Sink Faucet                  | 7/28/2016 10:05   | 8/17/2016     | 47552        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-16A Classroom 6 Drinking Fountain            | 7/28/2016 10:05   | 8/17/2016     | 47553        | COPPER     | <0.005 PPM | 1.3 PPM      |
| 11-17A Classroom 5 Sink Faucet                  | 7/28/2016 10:09   | 8/17/2016     | 47554        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-18A Classroom 5 Drinking Fountain            | 7/28/2016 10:09   | 8/17/2016     | 47555        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-19A Classroom 3 Sink Faucet                  | 7/28/2016 10:13   | 8/17/2016     | 47556        | COPPER     | 0.1 PPM    | 1.3 PPM      |
| 11-20A Classroom 3 Drinking Fountain            | 7/28/2016 10:13   | 8/17/2016     | 47557        | COPPER     | <0.005 PPM | 1.3 PPM      |
| 11-21A Classroom 4 Sink Faucet                  | 7/28/2016 10:17   | 8/17/2016     | 47558        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-22A Classroom 4 Drinking Fountain            | 7/28/2016 10:17   | 8/17/2016     | 47559        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-23A Corridor 32C Drinking Fountain at Room 9 | 7/28/2016 10:23   | 8/17/2016     | 47560        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-24A Staff Room Sink Faucet                   | 7/28/2016 12:26   | 8/17/2016     | 47561        | COPPER     | 0.1 PPM    | 1.3 PPM      |
| 11-25A Staff Room Drinking Fountain             | 7/28/2016 10:26   | 8/17/2016     | 47562        | COPPER     | 0.1 PPM    | 1.3 PPM      |
| 11-26A Main Office Sink Faucet                  | 7/28/2016 10:32   | 8/17/2016     | 47563        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-27A Main Office Drinking Fountain            | 7/28/2016 10:32   | 8/17/2016     | 47564        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-28A Classroom 18 Sink Faucet                 | 7/28/2016 10:39   | 8/17/2016     | 47565        | COPPER     | 0.1 PPM    | 1.3 PPM      |
| 11-29A Corridor 49 Drinking Fountain            | 7/28/2016 10:43   | 8/17/2016     | 47566        | COPPER     | <0.005 PPM | 1.3 PPM      |
| 11-30A Classroom 10 Sink Faucet                 | 7/28/2016 10:46   | 8/17/2016     | 47567        | COPPER     | 0.0 PPM    | 1.3 PPM      |

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Cummings Elementary School

| Sample Identification # and Location            | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results    | Action Level |
|---|-------------------|---------------|--------------|------------|------------|--------------|
| 11-31A Classroom 10 Drinking Fountain           | 7/28/2016 10:46   | 8/17/2016     | 47568        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-32A Classroom 11 Sink Faucet                 | 7/28/2016 10:49   | 8/17/2016     | 47569        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-33A Classroom 11 Drinking Fountain           | 7/28/2016 10:49   | 8/17/2016     | 47570        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-34A Classroom 12 Sink Faucet                 | 7/28/2016 10:53   | 8/17/2016     | 47571        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-35A Classroom 12 Drinking Fountain           | 7/28/2016 10:53   | 8/17/2016     | 47572        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-36A Classroom 17 Sink Faucet                 | 7/28/2016 10:57   | 8/17/2016     | 47573        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-37A Classroom 17 Drinking Fountain           | 7/28/2016 10:57   | 8/17/2016     | 47574        | COPPER     | 0.1 PPM    | 1.3 PPM      |
| 11-38A Classroom 16 Sink Faucet                 | 7/28/2016 11:01   | 8/17/2016     | 47575        | COPPER     | 0.1 PPM    | 1.3 PPM      |
| 11-39A Classroom 16 Drinking Fountain           | 7/28/2016 11:01   | 8/17/2016     | 47576        | COPPER     | 0.1 PPM    | 1.3 PPM      |
| 11-40A Classroom 13 Sink Faucet                 | 7/28/2016 11:05   | 8/17/2016     | 47577        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-41A Classroom 13 Drinking Fountain           | 7/28/2016 11:05   | 8/17/2016     | 47578        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-42A Classroom 14 Sink Faucet                 | 7/28/2016 11:09   | 8/17/2016     | 47579        | COPPER     | 0.1 PPM    | 1.3 PPM      |
| 11-43A Classroom 14 Drinking Fountain           | 7/28/2016 11:09   | 8/17/2016     | 47580        | COPPER     | 0.1 PPM    | 1.3 PPM      |
| 11-44A Classroom 15 Sink Faucet                 | 7/28/2016 11:12   | 8/17/2016     | 47581        | COPPER     | 0.1 PPM    | 1.3 PPM      |
| 11-45A Classroom 15 Drinking Fountain           | 7/28/2016 11:12   | 8/17/2016     | 47582        | COPPER     | 0.1 PPM    | 1.3 PPM      |
| 11-46A Hall Outside M.P Room Drinking Fountain  | 7/28/2016 11:15   | 8/17/2016     | 47583        | COPPER     | 0.2 PPM    | 1.3 PPM      |
| 11-47A M.P Room by Door 1-C Drinking Fountain   | 7/28/2016 11:22   | 8/17/2016     | 47584        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-48A M.P Room Boys Restroom Utility Sink      | 7/28/2016 11:24   | 8/17/2016     | 47585        | COPPER     | <0.005 PPM | 1.3 PPM      |
| 11-49A Kitchen Utility Sink                     | 7/28/2016 11:27   | 8/17/2016     | 47586        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-50A Kitchen Small Sink with Eye Wash Station | 7/28/2016 11:27   | 8/17/2016     | 47587        | COPPER     | 0.0 PPM    | 1.3 PPM      |
| 11-51A Drinking Fountain LRC                    | 7/28/2016 9:33    | 8/17/2016     | 47588        | COPPER     | 0.0 PPM    | 1.3 PPM      |

EPA Action Level for Copper in Schools is 1.3 PPM

**SKPS Action Level for Copper is 1.3 PPM**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (C) Sample Data  
Cummings Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|--------------------------------------|-------------------|---------------|--------------|------------|---------|--------------|
| 11-17C Classroom 5 Sink Faucet       | 10/21/2016 6:03   | 10/25/2016    | 64843        | COPPER     | 0.1 PPM | 1.3 PPM      |
| 11-18C Classroom 5 Drinking Fountain | 10/21/2016 6:05   | 10/25/2016    | 64844        | COPPER     | 0.0 PPM | 1.3 PPM      |

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level