

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Cummings Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
11-01A Drinking Fountain Corridor 32 at Room 9	7/28/2016 9:22	8/17/2016	47538	LEAD	1 PPB	15 PPB
11-02A Media Center Office Sink Faucet	7/28/2016 9:26	8/17/2016	47539	LEAD	2 PPB	15 PPB
11-03A LRC Office Sink Faucet	7/28/2016 9:30	8/17/2016	47540	LEAD	1 PPB	15 PPB
11-04A Classroom 8 Sink Faucet	7/28/2016 9:37	8/17/2016	47541	LEAD	1 PPB	15 PPB
11-05A Classroom 8 Drinking Fountain	7/28/2016 9:39	8/17/2016	47542	LEAD	2 PPB	15 PPB
11-06A Classroom 9 Sink Faucet	7/28/2016 9:41	8/17/2016	47543	LEAD	3 PPB	15 PPB
11-07A Classroom 9 Drinking Fountain	7/28/2016 9:41	8/17/2016	47544	LEAD	5 PPB	15 PPB
11-08A Classroom 7 Sink Faucet	7/28/2016 9:49	8/17/2016	47545	LEAD	5 PPB	15 PPB
11-09A Classroom 7 Drinking Fountain	7/28/2016 9:49	8/17/2016	47546	LEAD	5 PPB	15 PPB
11-10A Classroom 1 Sink Faucet	7/28/2016 9:54	8/17/2016	47547	LEAD	1 PPB	15 PPB
11-11A Classroom 1 Drinking Fountain	7/28/2016 9:54	8/17/2016	47548	LEAD	11 PPB	15 PPB
11-12A Corridor 32A Drinking Fountain at Room 6	7/28/2016 9:57	8/17/2016	47549	LEAD	5 PPB	15 PPB
11-13A Classroom 2 Sink Faucet	7/28/2016 10:02	8/17/2016	47550	LEAD	2 PPB	15 PPB
11-14A Classroom 2 Drinking Fountain	7/28/2016 10:02	8/17/2016	47551	LEAD	<1 PPB	15 PPB
11-15A Classroom 6 Sink Faucet	7/28/2016 10:05	8/17/2016	47552	LEAD	3 PPB	15 PPB
11-16A Classroom 6 Drinking Fountain	7/28/2016 10:05	8/17/2016	47553	LEAD	4 PPB	15 PPB
11-17A Classroom 5 Sink Faucet	7/28/2016 10:09	8/17/2016	47554	LEAD	23 PPB	15 PPB
11-18A Classroom 5 Drinking Fountain	7/28/2016 10:09	8/17/2016	47555	LEAD	16 PPB	15 PPB
11-19A Classroom 3 Sink Faucet	7/28/2016 10:13	8/17/2016	47556	LEAD	2 PPB	15 PPB
11-20A Classroom 3 Drinking Fountain	7/28/2016 10:13	8/17/2016	47557	LEAD	6 PPB	15 PPB
11-21A Classroom 4 Sink Faucet	7/28/2016 10:17	8/17/2016	47558	LEAD	4 PPB	15 PPB
11-22A Classroom 4 Drinking Fountain	7/28/2016 10:17	8/17/2016	47559	LEAD	3 PPB	15 PPB
11-23A Corridor 32C Drinking Fountain at Room 9	7/28/2016 10:23	8/17/2016	47560	LEAD	2 PPB	15 PPB
11-24A Staff Room Sink Faucet	7/28/2016 12:26	8/17/2016	47561	LEAD	1 PPB	15 PPB
11-25A Staff Room Drinking Fountain	7/28/2016 10:26	8/17/2016	47562	LEAD	9 PPB	15 PPB
11-26A Main Office Sink Faucet	7/28/2016 10:32	8/17/2016	47563	LEAD	<1 PPB	15 PPB
11-27A Main Office Drinking Fountain	7/28/2016 10:32	8/17/2016	47564	LEAD	2 PPB	15 PPB
11-28A Classroom 18 Sink Faucet	7/28/2016 10:39	8/17/2016	47565	LEAD	3 PPB	15 PPB
11-29A Corridor 49 Drinking Fountain	7/28/2016 10:43	8/17/2016	47566	LEAD	3 PPB	15 PPB
11-30A Classroom 10 Sink Faucet	7/28/2016 10:46	8/17/2016	47567	LEAD	2 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Cummings Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
11-31A Classroom 10 Drinking Fountain	7/28/2016 10:46	8/17/2016	47568	LEAD	2 PPB	15 PPB
11-32A Classroom 11 Sink Faucet	7/28/2016 10:49	8/17/2016	47569	LEAD	2 PPB	15 PPB
11-33A Classroom 11 Drinking Fountain	7/28/2016 10:49	8/17/2016	47570	LEAD	1 PPB	15 PPB
11-34A Classroom 12 Sink Faucet	7/28/2016 10:53	8/17/2016	47571	LEAD	3 PPB	15 PPB
11-35A Classroom 12 Drinking Fountain	7/28/2016 10:53	8/17/2016	47572	LEAD	1 PPB	15 PPB
11-36A Classroom 17 Sink Faucet	7/28/2016 10:57	8/17/2016	47573	LEAD	1 PPB	15 PPB
11-37A Classroom 17 Drinking Fountain	7/28/2016 10:57	8/17/2016	47574	LEAD	<1 PPB	15 PPB
11-38A Classroom 16 Sink Faucet	7/28/2016 11:01	8/17/2016	47575	LEAD	2 PPB	15 PPB
11-39A Classroom 16 Drinking Fountain	7/28/2016 11:01	8/17/2016	47576	LEAD	5 PPB	15 PPB
11-40A Classroom 13 Sink Faucet	7/28/2016 11:05	8/17/2016	47577	LEAD	2 PPB	15 PPB
11-41A Classroom 13 Drinking Fountain	7/28/2016 11:05	8/17/2016	47578	LEAD	<1 PPB	15 PPB
11-42A Classroom 14 Sink Faucet	7/28/2016 11:09	8/17/2016	47579	LEAD	7 PPB	15 PPB
11-43A Classroom 14 Drinking Fountain	7/28/2016 11:09	8/17/2016	47580	LEAD	2 PPB	15 PPB
11-44A Classroom 15 Sink Faucet	7/28/2016 11:12	8/17/2016	47581	LEAD	3 PPB	15 PPB
11-45A Classroom 15 Drinking Fountain	7/28/2016 11:12	8/17/2016	47582	LEAD	3 PPB	15 PPB
11-46A Hall Outside M.P Room Drinking Fountain	7/28/2016 11:15	8/17/2016	47583	LEAD	<1 PPB	15 PPB
11-47A M.P Room by Door 1-C Drinking Fountain	7/28/2016 11:22	8/17/2016	47584	LEAD	11 PPB	15 PPB
11-48A M.P Room Boys Restroom Utility Sink	7/28/2016 11:24	8/17/2016	47585	LEAD	11 PPB	15 PPB
11-49A Kitchen Utility Sink	7/28/2016 11:27	8/17/2016	47586	LEAD	<1 PPB	15 PPB
11-50A Kitchen Small Sink with Eye Wash Station	7/28/2016 11:27	8/17/2016	47587	LEAD	<1 PPB	15 PPB
11-51A Drinking Fountain LRC	7/28/2016 9:33	8/17/2016	47588	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
Cummings Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
11-17B Classroom 5 Sink Faucet	7/28/2016 10:10	9/1/2016	52920	LEAD	6 PPB	15 PPB
11-18B Classroom 5 Drinking Fountain	7/28/2016 10:11	9/1/2016	52921	LEAD	9 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (C) Sample Data
Cummings Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
11-17C Classroom 5 Sink Faucet	10/21/2016 6:03	10/25/2016	64843	LEAD	12 PPB	15 PPB
11-18C Classroom 5 Drinking Fountain	10/21/2016 6:05	10/25/2016	64844	LEAD	6 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level