

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Eyre Elementary School

| Sample Identification # and Location         | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|--|-------------------|---------------|--------------|------------|---------|--------------|
| 14-01A Gymnasium Drinking Fountain           | 7/26/2016 11:25   | 8/5/2016      | 44396        | COPPER     | 0.4 PPM | 1.3 PPM      |
| 14-02A Gymnasium Vestibule Drinking Fountain | 7/26/2016 11:27   | 8/5/2016      | 44397        | COPPER     | 0.3 PPM | 1.3 PPM      |
| 14-03A Room 136 staff lounge Sink Faucet     | 7/26/2016 11:29   | 8/5/2016      | 44398        | COPPER     | 0.4 PPM | 1.3 PPM      |
| 14-04A Cafeteria/room 135 Sink Faucet        | 7/26/2016 11:30   | 8/5/2016      | 44399        | COPPER     | 0.8 PPM | 1.3 PPM      |
| 14-05A Cafeteria/room 135 Drinking Fountain  | 7/26/2016 11:33   | 8/5/2016      | 44400        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-06A Kitchen Sink Faucet                   | 7/26/2016 11:35   | 8/5/2016      | 44401        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-07A Room 134 Sink Faucet                  | 7/26/2016 11:37   | 8/5/2016      | 44402        | COPPER     | 0.4 PPM | 1.3 PPM      |
| 14-09A LRC Room 132 Sink Faucet (left)       | 7/26/2016 11:43   | 8/5/2016      | 44403        | COPPER     | 0.9 PPM | 1.3 PPM      |
| 14-10A LRC Room 132 Sink Faucet (right)      | 7/26/2016 11:45   | 8/5/2016      | 44404        | COPPER     | 0.6 PPM | 1.3 PPM      |
| 14-11A LRC Room 132 Drinking Fountain        | 7/26/2016 11:47   | 8/5/2016      | 44405        | COPPER     | 0.4 PPM | 1.3 PPM      |
| 14-12A C-6 Sink Faucet                       | 7/26/2016 11:50   | 8/5/2016      | 44406        | COPPER     | 0.8 PPM | 1.3 PPM      |
| 14-13A C-6 Drinking Fountain                 | 7/26/2016 11:52   | 8/5/2016      | 44407        | COPPER     | 0.4 PPM | 1.3 PPM      |
| 14-14A C-5 Sink Faucet                       | 7/26/2016 11:54   | 8/5/2016      | 44408        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-15A C-5 Drinking Fountain                 | 7/26/2016 11:56   | 8/5/2016      | 44409        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-16A C-4 Sink Faucet                       | 7/26/2016 11:58   | 8/5/2016      | 44410        | COPPER     | 0.7 PPM | 1.3 PPM      |
| 14-17A C-4 Drinking Fountain                 | 7/26/2016 12:00   | 8/5/2016      | 44411        | COPPER     | 0.6 PPM | 1.3 PPM      |
| 14-18A C-3 Sink Faucet                       | 7/26/2016 12:02   | 8/5/2016      | 44412        | COPPER     | 0.7 PPM | 1.3 PPM      |
| 14-19A C-3 Drinking Fountain                 | 7/26/2016 12:04   | 8/5/2016      | 44413        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-20A C-2 Sink Faucet                       | 7/26/2016 12:06   | 8/11/2016     | 44414        | COPPER     | 1.5 PPM | 1.3 PPM      |
| 14-21A C-2 Drinking Fountain                 | 7/26/2016 12:08   | 8/5/2016      | 44415        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-22A C-1 Sink Faucet                       | 7/26/2016 12:10   | 8/5/2016      | 44416        | COPPER     | 0.4 PPM | 1.3 PPM      |
| 14-23A C-1 Drinking Fountain                 | 7/26/2016 12:12   | 8/5/2016      | 44417        | COPPER     | 0.6 PPM | 1.3 PPM      |
| 14-24A B-6 Sink Faucet                       | 7/26/2016 12:14   | 8/5/2016      | 44418        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-25A B-6 Drinking Fountain                 | 7/26/2016 12:16   | 8/5/2016      | 44419        | COPPER     | 0.7 PPM | 1.3 PPM      |
| 14-26A B-5 Sink Faucet                       | 7/26/2016 12:18   | 8/5/2016      | 44420        | COPPER     | 0.4 PPM | 1.3 PPM      |
| 14-27A B-5 Drinking Fountain                 | 7/26/2016 12:20   | 8/5/2016      | 44421        | COPPER     | 0.6 PPM | 1.3 PPM      |
| 14-28A B-4 Sink Faucet                       | 7/26/2016 12:22   | 8/5/2016      | 44422        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-29A B-4 Drinking Fountain                 | 7/26/2016 12:24   | 8/5/2016      | 44423        | COPPER     | 0.6 PPM | 1.3 PPM      |
| 14-30A B-3 Sink Faucet                       | 7/26/2016 12:26   | 8/5/2016      | 44424        | COPPER     | 0.8 PPM | 1.3 PPM      |
| 14-31A B-3 Drinking Fountain                 | 7/26/2016 12:28   | 8/5/2016      | 44425        | COPPER     | 0.5 PPM | 1.3 PPM      |

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Eyre Elementary School

| Sample Identification # and Location           | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|--|-------------------|---------------|--------------|------------|---------|--------------|
| 14-32A B-2 Sink Faucet                         | 7/26/2016 12:30   | 8/5/2016      | 44426        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-33A B-2 Drinking Fountain                   | 7/26/2016 12:32   | 8/5/2016      | 44427        | COPPER     | 0.4 PPM | 1.3 PPM      |
| 14-34A B-1 Sink Faucet                         | 7/26/2016 12:34   | 8/5/2016      | 44428        | COPPER     | 0.4 PPM | 1.3 PPM      |
| 14-35A B-1 Drinking Fountain                   | 7/26/2016 12:36   | 8/5/2016      | 44429        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-36A Computer Lab Sink Faucet                | 7/26/2016 12:38   | 8/5/2016      | 44430        | COPPER     | 0.4 PPM | 1.3 PPM      |
| 14-37A Computer Lab Drinking Fountain          | 7/26/2016 12:40   | 8/5/2016      | 44431        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-38A Library Storage Sink Faucet             | 7/26/2016 12:42   | 8/5/2016      | 44432        | COPPER     | 0.1 PPM | 1.3 PPM      |
| 14-39A Health Room Sink Faucet                 | 7/26/2016 12:44   | 8/5/2016      | 44433        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-40A A- Pod Girls Restroom Drinking Fountain | 7/26/2016 12:46   | 8/5/2016      | 44434        | COPPER     | 0.1 PPM | 1.3 PPM      |
| 14-41A A-6 Sink Faucet                         | 7/26/2016 12:48   | 8/5/2016      | 44435        | COPPER     | 0.4 PPM | 1.3 PPM      |
| 14-42A A-6 Drinking Fountain                   | 7/26/2016 12:50   | 8/5/2016      | 44436        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-43A A-6 Sink Faucet                         | 7/26/2016 12:52   | 8/5/2016      | 44437        | COPPER     | 0.6 PPM | 1.3 PPM      |
| 14-44A A-5 Sink Faucet                         | 7/26/2016 12:54   | 8/5/2016      | 44438        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-45A A-5 Sink Faucet                         | 7/26/2016 12:56   | 8/5/2016      | 44439        | COPPER     | 0.4 PPM | 1.3 PPM      |
| 14-46A A-5 Drinking Fountain                   | 7/26/2016 12:58   | 8/5/2016      | 44440        | COPPER     | 0.6 PPM | 1.3 PPM      |
| 14-47A A-4 Sink Faucet                         | 7/26/2016 13:00   | 8/5/2016      | 44441        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-48A A-4 Drinking Fountain                   | 7/26/2016 13:02   | 8/5/2016      | 44442        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-49A A-3 Sink Faucet                         | 7/26/2016 13:04   | 8/5/2016      | 44443        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-50A A-3 Drinking Fountain                   | 7/26/2016 13:06   | 8/5/2016      | 44444        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-51A A-2 Sink Faucet                         | 7/26/2016 13:08   | 8/5/2016      | 44445        | COPPER     | 0.2 PPM | 1.3 PPM      |
| 14-52A A-2 Drinking Fountain                   | 7/26/2016 13:10   | 8/5/2016      | 44446        | COPPER     | 0.2 PPM | 1.3 PPM      |
| 14-53A A-1 Sink Faucet                         | 7/26/2016 13:12   | 8/5/2016      | 44447        | COPPER     | 0.2 PPM | 1.3 PPM      |
| 14-54A A-1 Drinking Fountain                   | 7/26/2016 12:14   | 8/5/2016      | 44448        | COPPER     | 0.5 PPM | 1.3 PPM      |
| 14-55A A-Pod Boys Restroom Drinking Fountain   | 7/26/2016 13:16   | 8/5/2016      | 44449        | COPPER     | 0.1 PPM | 1.3 PPM      |
| 14-56A Room 157 Sink Faucet                    | 7/26/2016 13:18   | 8/5/2016      | 44450        | COPPER     | 0.3 PPM | 1.3 PPM      |
| 14-57A D-7 Sink Faucet                         | 7/26/2016 13:25   | 8/5/2016      | 44451        | COPPER     | 0.4 PPM | 1.3 PPM      |
| 14-58A D-7 Drinking Fountain                   | 7/26/2016 13:27   | 8/5/2016      | 44452        | COPPER     | 0.1 PPM | 1.3 PPM      |
| 14-59A D-8 Sink Faucet                         | 7/26/2016 13:29   | 8/5/2016      | 44453        | COPPER     | 0.2 PPM | 1.3 PPM      |
| 14-60A D-8 Drinking Fountain                   | 7/26/2016 13:31   | 8/5/2016      | 44454        | COPPER     | 0.0 PPM | 1.3 PPM      |
| 14-61A D-1 Sink Faucet                         | 7/26/2016 13:33   | 8/5/2016      | 44455        | COPPER     | 0.3 PPM | 1.3 PPM      |

Salem-Keizer Public Schools  
 Copper Water Sampling Results  
 First Draw (A) Sample Data  
 Eyre Elementary School

| Sample Identification # and Location  | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|---------------------------------------|-------------------|---------------|--------------|------------|---------|--------------|
| 14-62A D-1 Drinking Fountain          | 7/26/2016 13:35   | 8/5/2016      | 44456        | COPPER     | 0.1 PPM | 1.3 PPM      |
| 14-63A D-2 Sink Faucet                | 7/26/2016 13:37   | 8/5/2016      | 44457        | COPPER     | 0.2 PPM | 1.3 PPM      |
| 14-64A D-2 Drinking Fountain          | 7/26/2016 13:39   | 8/5/2016      | 44458        | COPPER     | 0.1 PPM | 1.3 PPM      |
| 14-65A D-3 Sink Faucet                | 7/26/2016 13:41   | 8/5/2016      | 44459        | COPPER     | 0.3 PPM | 1.3 PPM      |
| 14-66A D-3 Drinking Fountain          | 7/26/2016 13:43   | 8/5/2016      | 44460        | COPPER     | 0.1 PPM | 1.3 PPM      |
| 14-67A D-4 Sink Faucet                | 7/26/2016 13:45   | 8/5/2016      | 44461        | COPPER     | 0.3 PPM | 1.3 PPM      |
| 14-68A D-4 Drinking Fountain          | 7/26/2016 13:47   | 8/5/2016      | 44462        | COPPER     | 0.1 PPM | 1.3 PPM      |
| 14-69A Hall B/C Pod Drinking Fountain | 7/26/2016 13:20   | 8/5/2016      | 44463        | COPPER     | 0.3 PPM | 1.3 PPM      |

EPA Action Level for Copper in Schools is 1.3 PPM

**SKPS Action Level for Copper is 1.3 PPM**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Eyre Elementary School

| Sample Identification # and Location  | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|---------------------------------------|-------------------|---------------|--------------|------------|---------|--------------|
| 14-08A Media Center Drinking Fountain | 9/30/2016 6:41    | 10/3/2016     | 59712        | COPPER     | 0.3 PPM | 1.3 PPM      |

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Copper Water Sampling Results  
Flushed (B) Sample Data  
Eyre Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|--------------------------------------|-------------------|---------------|--------------|------------|---------|--------------|
| 14-20B C-2 Sink Faucet               | 7/26/2016 12:07   | 9/1/2016      | 52934        | COPPER     | 0.6 PPM | 1.3 PPM      |

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
 Copper Water Sampling Results  
 First Draw (C) Sample Data  
 Eyre Elementary School

| Sample Identification # and Location     | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|--|-------------------|---------------|--------------|------------|---------|--------------|
| 014-07C Room 134 Sink Faucet             | 11/4/2016 4:09    | 11/7/2016     | 67535        | COPPER     | 0.1 PPM | 1.3 PPM      |
| 014-08C Media Center Drinking Fountain   | 11/4/2016 4:12    | 11/7/2016     | 67536        | COPPER     | 0.2 PPM | 1.3 PPM      |
| 014-09C LRC Room 132 Sink Faucet (Left)  | 11/4/2016 4:15    | 11/7/2016     | 67537        | COPPER     | 0.3 PPM | 1.3 PPM      |
| 014-10C LRC Room 132 Sink Faucet (right) | 11/4/2016 4:17    | 11/7/2016     | 67538        | COPPER     | 0.2 PPM | 1.3 PPM      |
| 014-12C C-6 Sink Faucet                  | 11/4/2016 4:20    | 11/7/2016     | 67539        | COPPER     | 0.2 PPM | 1.3 PPM      |
| 014-16C C-4 Sink Faucet                  | 11/4/2016 4:23    | 11/7/2016     | 67540        | COPPER     | 0.3 PPM | 1.3 PPM      |
| 014-20C C-2 Sink Faucet                  | 11/4/2016 4:25    | 11/7/2016     | 67541        | COPPER     | 0.2 PPM | 1.3 PPM      |
| 014-34C B-1 Sink Faucet                  | 11/4/2016 4:28    | 11/7/2016     | 67542        | COPPER     | 0.2 PPM | 1.3 PPM      |

EPA Action Level for Copper in Schools is 1.3 PPM

**SKPS Action Level for Copper is 1.3 PPM**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**