

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Four Corners Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result	Action Level
016-01A Classroom 19 Sink Faucet	8/11/2016 7:28	8/23/2016	50341	COPPER	0.1 PPM	1.3 PPM
016-02A Classroom 19 Drinking Fountain	8/11/2016 7:28	8/23/2016	50342	COPPER	0.2 PPM	1.3 PPM
016-03A Classroom 18 Sink Faucet	8/11/2016 7:30	8/23/2016	50343	COPPER	0.1 PPM	1.3 PPM
016-04A Classroom 18 Drinking Fountain	8/11/2016 7:30	8/23/2016	50344	COPPER	0.4 PPM	1.3 PPM
016-05A Classroom 17 Sink Faucet	8/11/2016 7:33	8/23/2016	50345	COPPER	0.2 PPM	1.3 PPM
016-06A Classroom 17 Drinking Fountain	8/11/2016 7:33	8/23/2016	50346	COPPER	0.2 PPM	1.3 PPM
016-07A Classroom 16 Sink Faucet	8/11/2016 7:35	8/23/2016	50347	COPPER	0.5 PPM	1.3 PPM
016-08A Classroom 16 Drinking Fountain	8/11/2016 7:35	8/23/2016	50348	COPPER	0.3 PPM	1.3 PPM
016-09A Classroom 15 Sink Faucet	8/11/2016 7:38	8/23/2016	50349	COPPER	0.2 PPM	1.3 PPM
016-10A Classroom 15 Drinking Fountain	8/11/2016 7:38	8/23/2016	50350	COPPER	0.2 PPM	1.3 PPM
016-11A Classroom 14 Sink Faucet	8/11/2016 7:40	8/23/2016	50351	COPPER	0.7 PPM	1.3 PPM
016-12A Classroom 14 Drinking Fountain	8/11/2016 7:40	8/23/2016	50352	COPPER	0.2 PPM	1.3 PPM
016-13A Hallway Drinking Fountain	8/11/2016 7:43	8/23/2016	50353	COPPER	0.2 PPM	1.3 PPM
016-14A Kitchen Sink Faucet 1	8/11/2016 7:47	8/23/2016	50354	COPPER	0.2 PPM	1.3 PPM
016-15A Kitchen Sink Faucet 2	8/11/2016 7:48	8/23/2016	50355	COPPER	0.2 PPM	1.3 PPM
016-16A Kitchen Sink Faucet 3	8/11/2016 7:48	8/23/2016	50356	COPPER	0.3 PPM	1.3 PPM
016-17A Multi-Purpose Room Drinking fountain	8/11/2016 7:50	8/23/2016	50357	COPPER	0.3 PPM	1.3 PPM
016-18A Staff Room Sink Faucet	8/11/2016 7:53	8/23/2016	50358	COPPER	0.1 PPM	1.3 PPM
016-19A Office by Receptionist Sink Faucet	8/11/2016 7:56	8/23/2016	50359	COPPER	0.1 PPM	1.3 PPM
016-20A Health Room Sink Faucet	8/11/2016 7:57	8/23/2016	50360	COPPER	0.2 PPM	1.3 PPM
016-21A Hallway Double Drinking Fountain	8/11/2016 8:00	8/23/2016	50361	COPPER	0.3 PPM	1.3 PPM
016-22A Hallway Double Drinking Fountain	8/11/2016 8:01	8/23/2016	50362	COPPER	0.1 PPM	1.3 PPM
016-23A Library Storage Sink Faucet	8/11/2016 8:03	8/23/2016	50363	COPPER	0.1 PPM	1.3 PPM
016-24A Library Storage Drinking Fountain	8/11/2016 8:03	8/23/2016	50364	COPPER	0.2 PPM	1.3 PPM
016-25A Student Services Sink Faucet	8/11/2016 8:13	8/23/2016	50365	COPPER	0.1 PPM	1.3 PPM
016-26A Classroom 13 Sink Faucet	8/11/2016 8:20	8/23/2016	50366	COPPER	0.1 PPM	1.3 PPM
016-27A Classroom 13 Drinking Fountain	8/11/2016 8:20	8/23/2016	50367	COPPER	0.1 PPM	1.3 PPM
016-28A Classroom 0 Drinking Fountian	8/11/2016 8:24	8/23/2016	50368	COPPER	0.3 PPM	1.3 PPM
016-29A Classroom 0 Sink Faucet	8/11/2016 8:24	8/23/2016	50369	COPPER	0.4 PPM	1.3 PPM
016-30A Hallway Double Drinking Fountain	8/11/2016 8:27	8/23/2016	50370	COPPER	0.3 PPM	1.3 PPM

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Four Corners Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result	Action Level
016-31A Classroom 01 Drinking Fountain	8/11/2016 8:29	8/23/2016	50371	COPPER	0.4 PPM	1.3 PPM
016-32A Classroom 01 Sink Faucet	8/11/2016 8:29	8/23/2016	50372	COPPER	0.3 PPM	1.3 PPM
016-33A Classroom 02 Drinking Fountain	8/11/2016 8:34	8/23/2016	50373	COPPER	0.3 PPM	1.3 PPM
016-34A Classroom 02 Sink Faucet	8/11/2016 8:34	8/23/2016	50374	COPPER	0.3 PPM	1.3 PPM
016-35A Classroom 12 Drinking Fountain	8/11/2016 8:32	8/23/2016	50375	COPPER	0.4 PPM	1.3 PPM
016-36A Classroom 12 Sink Faucet	8/11/2016 8:32	8/23/2016	50376	COPPER	0.2 PPM	1.3 PPM
016-37A Classroom 11 Drinking Fountain	8/11/2016 8:37	8/23/2016	50377	COPPER	0.3 PPM	1.3 PPM
016-38A Classroom 11 Sink Faucet	8/11/2016 8:37	8/23/2016	50378	COPPER	0.3 PPM	1.3 PPM
016-39A Classroom 03 Drinking Fountain	8/11/2016 9:05	8/23/2016	50379	COPPER	0.3 PPM	1.3 PPM
016-40A Classroom 03 Sink Faucet	8/11/2016 9:05	8/23/2016	50380	COPPER	0.2 PPM	1.3 PPM
016-41A Classroom 10 Drinking Fountain	8/11/2016 9:08	8/23/2016	50381	COPPER	0.3 PPM	1.3 PPM
016-42A Classroom 10 Sink Faucet	8/11/2016 9:08	8/23/2016	50382	COPPER	0.1 PPM	1.3 PPM
016-43A Classroom 04 Sink Faucet	8/11/2016 9:11	8/23/2016	50383	COPPER	0.4 PPM	1.3 PPM
016-44A Classroom 04 Drinking Fountain	8/11/2016 9:11	8/23/2016	50384	COPPER	0.3 PPM	1.3 PPM
016-45A Classroom 05 Sink Faucet	8/11/2016 9:16	8/23/2016	50385	COPPER	0.3 PPM	1.3 PPM
016-46A Classroom 05 Drinking Fountain	8/11/2016 9:16	8/23/2016	50386	COPPER	0.4 PPM	1.3 PPM
016-47A Classroom 09 Sink Faucet	8/11/2016 9:19	8/24/2016	50387	COPPER	0.3 PPM	1.3 PPM
016-48A Classroom 09 Drinking Fountain	8/11/2016 9:12	8/24/2016	50388	COPPER	0.4 PPM	1.3 PPM
016-49A Classroom 06 Sink Faucet	8/11/2016 9:24	8/24/2016	50389	COPPER	0.3 PPM	1.3 PPM
016-50A Classroom 06 Drinking Fountain	8/11/2016 9:24	8/24/2016	50390	COPPER	0.4 PPM	1.3 PPM
016-51A Classroom 08 Sink Faucet	8/11/2016 9:28	8/24/2016	50391	COPPER	0.3 PPM	1.3 PPM
016-52A Classroom 08 Drinking Fountain	8/11/2016 9:28	8/24/2016	50392	COPPER	0.4 PPM	1.3 PPM
016-53A Classroom 07 Sink Faucet	8/11/2016 9:32	8/24/2016	50393	COPPER	0.4 PPM	1.3 PPM
016-54A Classroom 07 Drinking Fountain	8/11/2016 9:32	8/24/2016	50394	COPPER	0.5 PPM	1.3 PPM
016-55A Gymnasium Restrooms Drinking Fountain	8/11/2016 8:58	8/24/2016	50395	COPPER	0.1 PPM	1.3 PPM
016-56A Music Room Sink Faucet	8/11/2016 9:00	8/24/2016	50396	COPPER	0.1 PPM	1.3 PPM
016-57A Portable Room 20 Sink Faucet	8/11/2016 8:54	8/24/2016	50397	COPPER	0.1 PPM	1.3 PPM
016-58A Portable Room 20 Drinking Fountain	8/11/2016 8:54	8/24/2016	50398	COPPER	0.0 PPM	1.3 PPM
016-59A Portable Room 21 Sink Faucet	8/11/2016 8:50	8/24/2016	50399	COPPER	0.1 PPM	1.3 PPM
016-60A Portable Room 21 Drinking Fountain	8/11/2016 8:50	8/24/2016	50400	COPPER	0.1 PPM	1.3 PPM

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Four Corners Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result	Action Level
016-61A Portable Room 22 Sink Faucet	8/11/2016 8:45	8/24/2016	50401	COPPER	0.1 PPM	1.3 PPM
016-62A Portable Room 22 Drinking Fountain	8/11/2016 8:45	8/24/2016	50402	COPPER	0.1 PPM	1.3 PPM
016-63A Portable Room 23 Sink Faucet	8/11/2016 8:43	8/24/2016	50403	COPPER	0.1 PPM	1.3 PPM
016-64A Portable Room 23 Drinking Fountain	8/11/2016 8:43	8/24/2016	50404	COPPER	0.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level