

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Four Corners Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
016-01A Classroom 19 Sink Faucet	8/11/2016 7:28	8/23/2016	50341	LEAD	<1 PPB	15 PPB
016-02A Classroom 19 Drinking Fountain	8/11/2016 7:28	8/23/2016	50342	LEAD	<1 PPB	15 PPB
016-03A Classroom 18 Sink Faucet	8/11/2016 7:30	8/23/2016	50343	LEAD	<1 PPB	15 PPB
016-04A Classroom 18 Drinking Fountain	8/11/2016 7:30	8/23/2016	50344	LEAD	<1 PPB	15 PPB
016-05A Classroom 17 Sink Faucet	8/11/2016 7:33	8/23/2016	50345	LEAD	<1 PPB	15 PPB
016-06A Classroom 17 Drinking Fountain	8/11/2016 7:33	8/23/2016	50346	LEAD	2 PPB	15 PPB
016-07A Classroom 16 Sink Faucet	8/11/2016 7:35	8/23/2016	50347	LEAD	<1 PPB	15 PPB
016-08A Classroom 16 Drinking Fountain	8/11/2016 7:35	8/23/2016	50348	LEAD	<1 PPB	15 PPB
016-09A Classroom 15 Sink Faucet	8/11/2016 7:38	8/23/2016	50349	LEAD	<1 PPB	15 PPB
016-10A Classroom 15 Drinking Fountain	8/11/2016 7:38	8/23/2016	50350	LEAD	<1 PPB	15 PPB
016-11A Classroom 14 Sink Faucet	8/11/2016 7:40	8/23/2016	50351	LEAD	1 PPB	15 PPB
016-12A Classroom 14 Drinking Fountain	8/11/2016 7:40	8/23/2016	50352	LEAD	<1 PPB	15 PPB
016-13A Hallway Drinking Fountain 1	8/11/2016 7:43	8/23/2016	50353	LEAD	7 PPB	15 PPB
016-14A Kitchen Sink Faucet 1	8/11/2016 7:47	8/23/2016	50354	LEAD	2 PPB	15 PPB
016-15A Kitchen Sink Faucet 2	8/11/2016 7:48	8/23/2016	50355	LEAD	3 PPB	15 PPB
016-16A Kitchen Sink Faucet 3	8/11/2016 7:48	8/23/2016	50356	LEAD	7 PPB	15 PPB
016-17A Multi-Purpose Room Drinking fountain	8/11/2016 7:50	8/23/2016	50357	LEAD	1 PPB	15 PPB
016-18A Staff Room Sink Faucet	8/11/2016 7:53	8/23/2016	50358	LEAD	1 PPB	15 PPB
016-19A Office by Receptionist Sink Faucet	8/11/2016 7:56	8/23/2016	50359	LEAD	1 PPB	15 PPB
016-20A Health Room Sink Faucet	8/11/2016 7:57	8/23/2016	50360	LEAD	3 PPB	15 PPB
016-21A Hallway Double Drinking Fountain 2	8/11/2016 8:00	8/23/2016	50361	LEAD	<1 PPB	15 PPB
016-22A Hallway Double Drinking Fountain 3	8/11/2016 8:01	8/23/2016	50362	LEAD	<1 PPB	15 PPB
016-23A Library Storage Sink Faucet	8/11/2016 8:03	8/23/2016	50363	LEAD	1 PPB	15 PPB
016-24A Library Storage Drinking Fountain	8/11/2016 8:03	8/23/2016	50364	LEAD	6 PPB	15 PPB
016-25A Student Services Sink Faucet	8/11/2016 8:13	8/23/2016	50365	LEAD	3 PPB	15 PPB
016-26A Classroom 13 Sink Faucet	8/11/2016 8:20	8/23/2016	50366	LEAD	<1 PPB	15 PPB
016-27A Classroom 13 Drinking Fountain	8/11/2016 8:20	8/23/2016	50367	LEAD	1 PPB	15 PPB
016-28A Classroom 0 Drinking Fountian	8/11/2016 8:24	8/23/2016	50368	LEAD	1 PPB	15 PPB
016-29A Classroom 0 Sink Faucet	8/11/2016 8:24	8/23/2016	50369	LEAD	<1 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Four Corners Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
016-30A Hallway Double Drinking Fountain 4	8/11/2016 8:27	8/23/2016	50370	LEAD	2 PPB	15 PPB
016-31A Classroom 01 Drinking Fountain	8/11/2016 8:29	8/23/2016	50371	LEAD	3 PPB	15 PPB
016-32A Classroom 01 Sink Faucet	8/11/2016 8:29	8/23/2016	50372	LEAD	1 PPB	15 PPB
016-33A Classroom 02 Drinking Fountain	8/11/2016 8:34	8/23/2016	50373	LEAD	6 PPB	15 PPB
016-34A Classroom 02 Sink Faucet	8/11/2016 8:34	8/23/2016	50374	LEAD	1 PPB	15 PPB
016-35A Classroom 12 Drinking Fountain	8/11/2016 8:32	8/23/2016	50375	LEAD	4 PPB	15 PPB
016-36A Classroom 12 Sink Faucet	8/11/2016 8:32	8/23/2016	50376	LEAD	3 PPB	15 PPB
016-37A Classroom 11 Drinking Fountain	8/11/2016 8:37	8/23/2016	50377	LEAD	4 PPB	15 PPB
016-38A Classroom 11 Sink Faucet	8/11/2016 8:37	8/23/2016	50378	LEAD	2 PPB	15 PPB
016-39A Classroom 03 Drinking Fountain	8/11/2016 9:05	8/23/2016	50379	LEAD	3 PPB	15 PPB
016-40A Classroom 03 Sink Faucet	8/11/2016 9:05	8/23/2016	50380	LEAD	<1 PPB	15 PPB
016-41A Classroom 10 Drinking Fountain	8/11/2016 9:08	8/23/2016	50381	LEAD	5 PPB	15 PPB
016-42A Classroom 10 Sink Faucet	8/11/2016 9:08	8/23/2016	50382	LEAD	2 PPB	15 PPB
016-43A Classroom 04 Sink Faucet	8/11/2016 9:11	8/23/2016	50383	LEAD	4 PPB	15 PPB
016-44A Classroom 04 Drinking Fountain	8/11/2016 9:11	8/23/2016	50384	LEAD	1 PPB	15 PPB
016-45A Classroom 05 Sink Faucet	8/11/2016 9:16	8/23/2016	50385	LEAD	1 PPB	15 PPB
016-46A Classroom 05 Drinking Fountain	8/11/2016 9:16	8/23/2016	50386	LEAD	2 PPB	15 PPB
016-47A Classroom 09 Sink Faucet	8/11/2016 9:19	8/24/2016	50387	LEAD	1 PPB	15 PPB
016-48A Classroom 09 Drinking Fountain	8/11/2016 9:12	8/24/2016	50388	LEAD	2 PPB	15 PPB
016-49A Classroom 06 Sink Faucet	8/11/2016 9:24	8/24/2016	50389	LEAD	1 PPB	15 PPB
016-50A Classroom 06 Drinking Fountain	8/11/2016 9:24	8/24/2016	50390	LEAD	4 PPB	15 PPB
016-51A Classroom 08 Sink Faucet	8/11/2016 9:28	8/24/2016	50391	LEAD	1 PPB	15 PPB
016-52A Classroom 08 Drinking Fountain	8/11/2016 9:28	8/24/2016	50392	LEAD	3 PPB	15 PPB
016-53A Classroom 07 Sink Faucet	8/11/2016 9:32	8/24/2016	50393	LEAD	1 PPB	15 PPB
016-54A Classroom 07 Drinking Fountain	8/11/2016 9:32	8/24/2016	50394	LEAD	5 PPB	15 PPB
016-55A Gymnasium Restrooms Drinking Fountain	8/11/2016 8:58	8/24/2016	50395	LEAD	<1 PPB	15 PPB
016-56A Music Room Sink Faucet	8/11/2016 9:00	8/24/2016	50396	LEAD	<1 PPB	15 PPB
016-57A Portable Room 20 Sink Faucet	8/11/2016 8:54	8/24/2016	50397	LEAD	3 PPB	15 PPB
016-58A Portable Room 20 Drinking Fountain	8/11/2016 8:54	8/24/2016	50398	LEAD	<1 PPB	15 PPB

Salem-Keizer Public Schools
 Lead Water Sampling Results
 First Draw (A) Sample Data
 Four Corners Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
016-59A Portable Room 21 Sink Faucet	8/11/2016 8:50	8/24/2016	50399	LEAD	3 PPB	15 PPB
016-60A Portable Room 21 Drinking Fountain	8/11/2016 8:50	8/24/2016	50400	LEAD	<1 PPB	15 PPB
016-61A Portable Room 22 Sink Faucet	8/11/2016 8:45	8/24/2016	50401	LEAD	3 PPB	15 PPB
016-62A Portable Room 22 Drinking Fountain	8/11/2016 8:45	8/24/2016	50402	LEAD	<1 PPB	15 PPB
016-63A Portable Room 23 Sink Faucet	8/11/2016 8:43	8/24/2016	50403	LEAD	3 PPB	15 PPB
016-64A Portable Room 23 Drinking Fountain	8/11/2016 8:43	8/24/2016	50404	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level