

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Grant Elementary School

Sample Identification # and Location		Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
17-01A	Staff Lounge Sink Faucet	7/27/16 2:15 PM	8/1/2016	1607C78-01A	COPPER	0.2 PPM	1.3 PPM
17-02A	Main Hall Drinking Fountain	7/27/16 2:17 PM	8/1/2016	1607C78-02A	COPPER	0.2 PPM	1.3 PPM
17-04A	Kitchen Sink Faucet	7/27/16 2:21 PM	8/1/2016	1607C78-03A	COPPER	0.3 PPM	1.3 PPM
17-05A	Room 3 Sink Faucet	7/27/16 2:23 PM	8/1/2016	1607C78-04A	COPPER	0.3 PPM	1.3 PPM
17-06A	Room 3 Drinking Fountain	7/27/16 2:23 PM	8/1/2016	1607C78-05A	COPPER	0.1 PPM	1.3 PPM
17-07A	Room 4 Sink Faucet	7/27/16 2:25 PM	8/1/2016	1607C78-06A	COPPER	0.4 PPM	1.3 PPM
17-08A	Room 4 Drinking Fountain	7/27/16 2:25 PM	8/1/2016	1607C78-07A	COPPER	0.1 PPM	1.3 PPM
17-09A	Room 1 Sink Faucet	7/27/16 2:27 PM	8/1/2016	1607C78-08A	COPPER	0.4 PPM	1.3 PPM
17-10A	Room 1 Drinking Fountain	7/27/16 2:27 PM	8/1/2016	1607C78-09A	COPPER	0.1 PPM	1.3 PPM
17-11A	Room 2 Sink Faucet	7/27/16 2:29 PM	8/1/2016	1607C78-10A	COPPER	0.4 PPM	1.3 PPM
17-12A	Room 2 Drinking Fountain	7/27/16 2:29 PM	8/1/2016	1607C78-11A	COPPER	0.1 PPM	1.3 PPM
17-13A	Main Office Sink Faucet	7/27/16 2:31 PM	8/1/2016	1607C78-12A	COPPER	0.4 PPM	1.3 PPM
17-14A	Room 6 Sink Faucet	7/27/16 2:33 PM	8/1/2016	1607C78-13A	COPPER	0.2 PPM	1.3 PPM
17-15A	Room 6 Drinking Fountain	7/27/16 2:33 PM	8/1/2016	1607C78-14A	COPPER	0.2 PPM	1.3 PPM
17-16A	Room 5 Sink Faucet	7/27/16 2:35 PM	8/1/2016	1607C78-15A	COPPER	0.4 PPM	1.3 PPM
17-17A	Room 5 Drinking Fountain	7/27/16 2:35 PM	8/1/2016	1607C78-16A	COPPER	0.3 PPM	1.3 PPM
17-18A	Room 8 Sink Faucet	7/27/16 2:37 PM	8/1/2016	1607C78-17A	COPPER	0.4 PPM	1.3 PPM
17-19A	Room 8 Drinking Fountain	7/27/16 2:37 PM	8/1/2016	1607C78-18A	COPPER	0.1 PPM	1.3 PPM
17-20A	Room 7 Sink Faucet	7/27/16 2:39 PM	8/1/2016	1607C78-19A	COPPER	0.4 PPM	1.3 PPM
17-21A	Room 7 Drinking Fountain	7/27/16 2:39 PM	8/1/2016	1607C78-20A	COPPER	0.4 PPM	1.3 PPM
17-22A	Room 10 Sink Faucet	7/27/16 2:41 PM	8/1/2016	1607C78-21A	COPPER	0.4 PPM	1.3 PPM
17-23A	Room 10 Drinking Fountain	7/27/16 2:41 PM	8/1/2016	1607C78-22A	COPPER	0.1 PPM	1.3 PPM
17-24A	Room 9 Sink Faucet	7/27/16 2:43 PM	8/1/2016	1607C78-23A	COPPER	0.4 PPM	1.3 PPM
17-25A	Room 9 Drinking Fountain	7/27/16 2:43 PM	8/1/2016	1607C78-24A	COPPER	0.2 PPM	1.3 PPM
17-26A	Room 11 Sink Faucet	7/27/16 2:45 PM	8/1/2016	1607C78-25A	COPPER	0.2 PPM	1.3 PPM
17-27A	Room 11 Drinking Fountain	7/27/16 2:45 PM	8/1/2016	1607C78-26A	COPPER	0.1 PPM	1.3 PPM
17-28A	Room 12 Sink Faucet	7/27/16 2:47 PM	8/1/2016	1607C78-27A	COPPER	0.2 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Grant Elementary School

17-29A	Room 12 Drinking Fountain	7/27/16 2:47 PM	8/1/2016	1607C78-28A	COPPER	0.1 PPM	1.3 PPM
17-30A	Main Hall Near Room 5 Drinking Fountain	7/27/16 2:49 PM	8/1/2016	1607C78-29A	COPPER	0.2 PPM	1.3 PPM
17-31A	Music Room Sink Faucet	7/27/16 2:51 PM	8/1/2016	1607C78-30A	COPPER	0.4 PPM	1.3 PPM
17-32A	Music Room Drinking Fountain	7/27/16 2:51 PM	8/1/2016	1607C78-31A	COPPER	0.4 PPM	1.3 PPM
17-33A	Gymnasium Drinking Fountain	7/27/16 2:53 PM	8/1/2016	1607C78-32A	COPPER	0.3 PPM	1.3 PPM
17-34A	Room 120 Sink Faucet	7/27/16 2:55 PM	8/1/2016	1607C78-33A	COPPER	0.6 PPM	1.3 PPM
17-35A	Room 140 Sink Faucet	7/27/16 2:57 PM	8/1/2016	1607C78-34A	COPPER	0.6 PPM	1.3 PPM
17-36A	Annex Main Hall Drinking Fountain (Left)	7/27/16 2:59 PM	8/1/2016	1607C78-35A	COPPER	0.5 PPM	1.3 PPM
17-37A	Annex Main Hall Drinking Fountain (Right)	7/27/16 3:01 PM	8/1/2016	1607C78-36A	COPPER	0.4 PPM	1.3 PPM
17-38A	Room 160 Sink Faucet	7/27/16 3:03 PM	8/1/2016	1607C78-37A	COPPER	0.7 PPM	1.3 PPM
17-39A	Room 180 Sink Faucet	7/27/16 3:05 PM	8/1/2016	1607C78-38A	COPPER	0.7 PPM	1.3 PPM
17-40A	Room 280 Sink Faucet	7/27/16 3:07 PM	8/1/2016	1607C78-39A	COPPER	0.7 PPM	1.3 PPM
17-41A	Room 260 Sink Faucet	7/27/16 3:09 PM	8/1/2016	1607C78-40A	COPPER	0.6 PPM	1.3 PPM
17-42A	Annex 2nd Floor Hall Drinking Fountain (Left)	7/27/16 3:11 PM	8/2/2016	1607C78-41A	COPPER	1.0 PPM	1.3 PPM
17-43A	Annex 2nd Floor Hall Drinking Fountain (Right)	7/27/16 3:13 PM	8/1/2016	1607C78-42A	COPPER	0.9 PPM	1.3 PPM
17-44A	Room 220 Sink Faucet	7/27/16 3:15 PM	8/1/2016	1607C78-43A	COPPER	0.6 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Grant Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
17-03A Cafeteria Drinking Fountain	10/14/2016 4:31	10/18/2016	63261	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level