

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Grant Elementary School

Sample Identification # and Location		Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
17-01A	Staff Lounge Sink Faucet	7/27/16 2:15 PM	8/1/2016	1607C78-01A	LEAD	<1.0 PPB	15 PPB
17-02A	Main Hall Drinking Fountain	7/27/16 2:17 PM	8/1/2016	1607C78-02A	LEAD	2 PPB	15 PPB
17-04A	Kitchen Sink Faucet	7/27/16 2:21 PM	8/1/2016	1607C78-03A	LEAD	<1.0 PPB	15 PPB
17-05A	Room 3 Sink Faucet	7/27/16 2:23 PM	8/1/2016	1607C78-04A	LEAD	3 PPB	15 PPB
17-06A	Room 3 Drinking Fountain	7/27/16 2:23 PM	8/1/2016	1607C78-05A	LEAD	<1.0 PPB	15 PPB
17-07A	Room 4 Sink Faucet	7/27/16 2:25 PM	8/1/2016	1607C78-06A	LEAD	3 PPB	15 PPB
17-08A	Room 4 Drinking Fountain	7/27/16 2:25 PM	8/1/2016	1607C78-07A	LEAD	2 PPB	15 PPB
17-09A	Room 1 Sink Faucet	7/27/16 2:27 PM	8/1/2016	1607C78-08A	LEAD	3 PPB	15 PPB
17-10A	Room 1 Drinking Fountain	7/27/16 2:27 PM	8/1/2016	1607C78-09A	LEAD	3 PPB	15 PPB
17-11A	Room 2 Sink Faucet	7/27/16 2:29 PM	8/1/2016	1607C78-10A	LEAD	2 PPB	15 PPB
17-12A	Room 2 Drinking Fountain	7/27/16 2:29 PM	8/1/2016	1607C78-11A	LEAD	3 PPB	15 PPB
17-13A	Main Office Sink Faucet	7/27/16 2:31 PM	8/1/2016	1607C78-12A	LEAD	2 PPB	15 PPB
17-14A	Room 6 Sink Faucet	7/27/16 2:33 PM	8/1/2016	1607C78-13A	LEAD	3 PPB	15 PPB
17-15A	Room 6 Drinking Fountain	7/27/16 2:33 PM	8/1/2016	1607C78-14A	LEAD	<1.0 PPB	15 PPB
17-16A	Room 5 Sink Faucet	7/27/16 2:35 PM	8/1/2016	1607C78-15A	LEAD	2 PPB	15 PPB
17-17A	Room 5 Drinking Fountain	7/27/16 2:35 PM	8/1/2016	1607C78-16A	LEAD	1 PPB	15 PPB
17-18A	Room 8 Sink Faucet	7/27/16 2:37 PM	8/1/2016	1607C78-17A	LEAD	3 PPB	15 PPB
17-19A	Room 8 Drinking Fountain	7/27/16 2:37 PM	8/1/2016	1607C78-18A	LEAD	1 PPB	15 PPB
17-20A	Room 7 Sink Faucet	7/27/16 2:39 PM	8/1/2016	1607C78-19A	LEAD	2 PPB	15 PPB
17-21A	Room 7 Drinking Fountain	7/27/16 2:39 PM	8/1/2016	1607C78-20A	LEAD	6 PPB	15 PPB
17-22A	Room 10 Sink Faucet	7/27/16 2:41 PM	8/1/2016	1607C78-21A	LEAD	3 PPB	15 PPB
17-23A	Room 10 Drinking Fountain	7/27/16 2:41 PM	8/1/2016	1607C78-22A	LEAD	1 PPB	15 PPB
17-24A	Room 9 Sink Faucet	7/27/16 2:43 PM	8/1/2016	1607C78-23A	LEAD	3 PPB	15 PPB
17-25A	Room 9 Drinking Fountain	7/27/16 2:43 PM	8/1/2016	1607C78-24A	LEAD	1 PPB	15 PPB
17-26A	Room 11 Sink Faucet	7/27/16 2:45 PM	8/1/2016	1607C78-25A	LEAD	5 PPB	15 PPB
17-27A	Room 11 Drinking Fountain	7/27/16 2:45 PM	8/1/2016	1607C78-26A	LEAD	3 PPB	15 PPB
17-28A	Room 12 Sink Faucet	7/27/16 2:47 PM	8/1/2016	1607C78-27A	LEAD	4 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Grant Elementary School

17-29A	Room 12 Drinking Fountain	7/27/16 2:47 PM	8/1/2016	1607C78-28A	LEAD	3	PPB	15 PPB
17-30A	Main Hall Near Room 5 Drinking Fountain	7/27/16 2:49 PM	8/1/2016	1607C78-29A	LEAD	4	PPB	15 PPB
17-31A	Music Room Sink Faucet	7/27/16 2:51 PM	8/1/2016	1607C78-30A	LEAD	4	PPB	15 PPB
17-32A	Music Room Drinking Fountain	7/27/16 2:51 PM	8/1/2016	1607C78-31A	LEAD	7	PPB	15 PPB
17-33A	Gymnasium Drinking Fountain	7/27/16 2:53 PM	8/1/2016	1607C78-32A	LEAD	3	PPB	15 PPB
17-34A	Room 120 Sink Faucet	7/27/16 2:55 PM	8/1/2016	1607C78-33A	LEAD	1	PPB	15 PPB
17-35A	Room 140 Sink Faucet	7/27/16 2:57 PM	8/1/2016	1607C78-34A	LEAD	3	PPB	15 PPB
17-36A	Annex Main Hall Drinking Fountain (Left)	7/27/16 2:59 PM	8/1/2016	1607C78-35A	LEAD	<1.0	PPB	15 PPB
17-37A	Annex Main Hall Drinking Fountain (Right)	7/27/16 3:01 PM	8/1/2016	1607C78-36A	LEAD	<1.0	PPB	15 PPB
17-38A	Room 160 Sink Faucet	7/27/16 3:03 PM	8/1/2016	1607C78-37A	LEAD	1	PPB	15 PPB
17-39A	Room 180 Sink Faucet	7/27/16 3:05 PM	8/1/2016	1607C78-38A	LEAD	2	PPB	15 PPB
17-40A	Room 280 Sink Faucet	7/27/16 3:07 PM	8/1/2016	1607C78-39A	LEAD	1	PPB	15 PPB
17-41A	Room 260 Sink Faucet	7/27/16 3:09 PM	8/1/2016	1607C78-40A	LEAD	1	PPB	15 PPB
17-42A	Annex 2nd Floor Hall Drinking Fountain (Left)	7/27/16 3:11 PM	8/2/2016	1607C78-41A	LEAD	<1.0	PPB	15 PPB
17-43A	Annex 2nd Floor Hall Drinking Fountain (Right)	7/27/16 3:13 PM	8/1/2016	1607C78-42A	LEAD	<1.0	PPB	15 PPB
17-44A	Room 220 Sink Faucet	7/27/16 3:15 PM	8/1/2016	1607C78-43A	LEAD	1	PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Grant Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
17-03A Cafeteria Drinking Fountain	10/14/2016 4:31	10/18/2016	63261	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level