

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Gubser Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
021-01A Gymnasium Drinking Fountain	7/21/16 6:47	7/29/16 10:16	607250001	LEAD	1 PPB	15 PPB
021-02A Hallway Drinking Fountain 1	7/21/16 6:51	7/29/16 10:17	607250002	LEAD	2 PPB	15 PPB
021-03A Cafeteria Sink Faucet	7/21/16 6:54	7/29/16 10:17	607250003	LEAD	< 1 PPB	15 PPB
021-04A Cafeteria Drinking Fountain	7/21/16 6:56	7/29/16 10:17	607250004	LEAD	2 PPB	15 PPB
021-05A Community Room Sink Faucet	7/21/16 6:59	7/29/16 10:17	607250005	LEAD	2 PPB	15 PPB
021-06A Hallway Drinking Fountain 2	7/21/16 7:02	7/29/16 10:17	607250006	LEAD	8 PPB	15 PPB
021-07A Kitchen Food Prep Sink Faucet	7/21/16 7:05	7/29/16 10:17	607250007	LEAD	< 1 PPB	15 PPB
021-08A Music Room Sink Faucet	7/21/16 7:09	7/29/16 10:17	607250008	LEAD	5 PPB	15 PPB
021-09A Music Room Drinking Fountain	7/21/16 7:11	7/29/16 10:17	607250009	LEAD	< 1 PPB	15 PPB
021-10A LRC 120 Sink Faucet	7/21/16 7:19	7/29/16 11:49	607250010	LEAD	5 PPB	15 PPB
021-11A Boys Bathroom Drinking Fountain	7/21/16 7:22	7/29/16 10:29	607250011	LEAD	3 PPB	15 PPB
021-12A Classroom A1 Sink Faucet	7/21/16 7:25	7/29/16 10:29	607250012	LEAD	3 PPB	15 PPB
021-13A Classroom A1 Drinking Fountain	7/21/16 7:27	7/29/16 10:29	607250013	LEAD	1 PPB	15 PPB
021-14A Classroom A2 Sink Faucet	7/21/16 7:30	7/29/16 10:29	607250014	LEAD	5 PPB	15 PPB
021-15A Classroom A2 Drinking Fountain	7/21/16 7:32	7/29/16 10:29	607250015	LEAD	1 PPB	15 PPB
021-16A Classroom A3 Sink Faucet	7/21/16 7:35	7/29/16 10:29	607250016	LEAD	4 PPB	15 PPB
021-17A Classroom A3 Drinking Fountain	7/21/16 7:38	7/29/16 10:29	607250017	LEAD	3 PPB	15 PPB
021-18A Classroom A4 Sink Faucet	7/21/16 7:41	7/29/16 10:29	607250018	LEAD	4 PPB	15 PPB
021-19A Classroom A4 Drinking Fountain	7/21/16 7:43	7/29/16 10:29	607250019	LEAD	2 PPB	15 PPB
021-20A Classroom A5 Sink Faucet	7/21/16 7:46	7/29/16 11:52	607250020	LEAD	6 PPB	15 PPB
021-21A Classroom A5 Drinking Fountain	7/21/16 7:48	7/29/16 10:31	607250021	LEAD	< 1 PPB	15 PPB
021-22A Classroom A5 Sink Faucet	7/21/16 7:20	7/29/16 10:31	607250022	LEAD	< 1 PPB	15 PPB
021-23A Classroom A6 Sink Faucet	7/21/16 7:57	7/29/16 10:31	607250023	LEAD	4 PPB	15 PPB
021-24A Classroom A6 Sink Faucet	7/21/16 8:01	7/29/16 10:31	607250024	LEAD	< 1 PPB	15 PPB
021-25A Classroom A6 Drinking Fountain	7/21/16 8:03	7/29/16 10:31	607250025	LEAD	2 PPB	15 PPB
021-26A Girls Bathroom Drinking Fountain	7/21/16 8:06	7/29/16 10:32	607250026	LEAD	1 PPB	15 PPB
021-27A Health 111 Sink Faucet	7/21/16 8:07	7/29/16 10:32	607250027	LEAD	6 PPB	15 PPB
021-28A Hallway Drinking Fountain 3	7/21/16 8:13	7/29/16 10:32	607250028	LEAD	5 PPB	15 PPB
021-29A Classroom B1 Sink Faucet	7/21/16 8:16	7/29/16 10:32	607250029	LEAD	5 PPB	15 PPB
021-30A Classroom B1 Drinking Fountain	7/21/16 8:18	7/29/16 11:54	607250030	LEAD	2 PPB	15 PPB
021-31A Classroom B2 Sink Faucet	7/21/16 8:21	8/1/16 9:28	607250031	LEAD	8 PPB	15 PPB
021-32A Classroom B2 Drinking Fountain	7/21/16 8:23	7/29/16 12:29	607250032	LEAD	2 PPB	15 PPB
021-33A Classroom B3 Sink Faucet	7/21/16 8:26	7/29/16 12:29	607250033	LEAD	3 PPB	15 PPB
021-34A Classroom B3 Drinking Fountain	7/21/16 8:28	7/29/16 12:29	607250034	LEAD	2 PPB	15 PPB
021-35A Classroom B4 Sink Faucet	7/21/16 8:31	7/29/16 12:29	607250035	LEAD	3 PPB	15 PPB
021-36A Classroom B4 Drinking Fountain	7/21/16 8:33	7/29/16 12:29	607250036	LEAD	2 PPB	15 PPB
021-37A Classroom B5 Sink Faucet	7/21/16 8:36	7/29/16 12:29	607250037	LEAD	4 PPB	15 PPB
021-38A Classroom B5 Drinking Fountain	7/21/16 8:38	7/29/16 12:29	607250038	LEAD	< 1 PPB	15 PPB
021-39A Classroom B6 Sink Faucet	7/21/16 8:41	7/29/16 12:30	607250039	LEAD	3 PPB	15 PPB
021-40A Classroom B6 Drinking Fountain	7/21/16 8:43	7/29/16 12:34	607250040	LEAD	1 PPB	15 PPB
021-41A Hallway Drinking Fountain 4	7/21/16 8:46	7/29/16 12:34	607250041	LEAD	2 PPB	15 PPB
021-42A Classroom C1 Sink Faucet	7/21/16 8:50	7/29/16 12:35	607250042	LEAD	3 PPB	15 PPB
021-43A Classroom C1 Drinking Fountain	7/21/16 8:52	7/29/16 12:35	607250043	LEAD	1 PPB	15 PPB
021-44A Classroom C2 Sink Faucet	7/21/16 8:54	7/29/16 12:35	607250044	LEAD	5 PPB	15 PPB
021-45A Classroom C2 Drinking Fountain	7/21/16 8:56	7/29/16 12:35	607250045	LEAD	< 1 PPB	15 PPB
021-46A Classroom C3 Sink Faucet	7/21/16 8:59	7/29/16 12:35	607250046	LEAD	3 PPB	15 PPB
021-47A Classroom C3 Drinking Fountain	7/21/16 9:01	7/29/16 12:35	607250047	LEAD	< 1 PPB	15 PPB
021-48A Classroom C4 Sink Faucet	7/21/16 9:04	7/29/16 12:35	607250048	LEAD	6 PPB	15 PPB
021-49A Classroom C4 Drinking Fountain	7/21/16 9:06	7/29/16 12:35	607250049	LEAD	2 PPB	15 PPB

Salem-Keizer Public Schools  
 Lead Water Sampling Results  
 First Draw (A) Sample Data  
 Gubser Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
021-50A Classroom C5 Sink Faucet	7/21/16 9:09	7/29/16 12:36	607250050	LEAD	4 PPB	15 PPB
021-51A Classroom C5 Drinking Fountain	7/21/16 9:11	7/29/16 12:36	607250051	LEAD	2 PPB	15 PPB
021-52A Classroom C6 Sink Faucet	7/21/16 9:14	7/29/16 12:36	607250052	LEAD	6 PPB	15 PPB
021-53A Classroom C6 Drinking Fountain	7/21/16 9:16	7/29/16 12:36	607250053	LEAD	1 PPB	15 PPB
021-54A Music Room Second Sink	7/21/16 7:13	7/29/16 12:36	607250054	LEAD	24 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
 Lead Water Sampling Results  
 Flushed (B) Sample Data  
 Gubser Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Tested For	Result	Action Level
021-54B Music Room Second Sink	7/21/16 7:14 AM	9/7/2016	608311001	LEAD	<1 PPB	15 PPB
EPA Action Level for Lead in Schools is 20 PPB						
SKPS Action Level for Lead is 15 PPB						
<b>Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level</b>						

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (C) Sample Data  
Gubser Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
021-54C Music Room Second Sink	10/21/2016 5:27	10/25/2016	64834	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**