

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Hallman Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
19-01A Music Room Sink Faucet	7/27/2016 11:20	8/11/2016	44555	COPPER	0.1 PPM	1.3 PPM
19-02A Music Room Drinking Fountain	7/27/2016 11:20	8/11/2016	44556	COPPER	0.1 PPM	1.3 PPM
19-03A Kitchen Sink Faucet	7/27/2016 11:22	8/11/2016	44557	COPPER	0.1 PPM	1.3 PPM
19-04A Main Hall Restroom Drinking Fountain (Left)	7/27/2016 11:24	8/11/2016	44558	COPPER	0.0 PPM	1.3 PPM
19-05A Main Hall Restroom Drinking Fountain (Right)	7/27/2016 11:25	8/11/2016	44559	COPPER	0.0 PPM	1.3 PPM
19-06A Nurses Room Sink Faucet	7/27/2016 11:26	8/11/2016	44560	COPPER	0.1 PPM	1.3 PPM
19-07A Nurses Room Drinking Fountain	7/27/2016 11:26	8/11/2016	44561	COPPER	0.0 PPM	1.3 PPM
19-08A Main Office Workroom Sink Faucet	7/27/2016 11:28	8/11/2016	44562	COPPER	0.0 PPM	1.3 PPM
19-09A Main Office Workroom Drinking Fountain	7/27/2016 11:28	8/11/2016	44563	COPPER	0.0 PPM	1.3 PPM
19-10A Counseling Office Sink Faucet	7/27/2016 11:42	8/11/2016	44564	COPPER	0.1 PPM	1.3 PPM
19-11A Counseling Office Drinking Fountain	7/27/2016 11:42	8/11/2016	44565	COPPER	0.1 PPM	1.3 PPM
19-12A Room 110 Sink Faucet	7/27/2016 11:44	8/11/2016	44566	COPPER	0.0 PPM	1.3 PPM
19-13A Room 110 Drinking Fountain	7/27/2016 11:44	8/11/2016	44567	COPPER	0.0 PPM	1.3 PPM
19-14A Room 109 Sink Faucet	7/27/2016 11:47	8/11/2016	44568	COPPER	0.1 PPM	1.3 PPM
19-15A Room 109 Drinking Fountain	7/27/2016 11:47	8/11/2016	44569	COPPER	0.0 PPM	1.3 PPM
19-16A Room 101 Sink Faucet	7/27/2016 11:49	8/11/2016	44570	COPPER	0.0 PPM	1.3 PPM
19-17A Room 101 Drinking Fountain	7/27/2016 11:49	8/11/2016	44571	COPPER	0.1 PPM	1.3 PPM
19-18A Room 102 Sink Faucet	7/27/2016 11:51	8/11/2016	44572	COPPER	0.1 PPM	1.3 PPM
19-19A Room 102 Drinking Fountain	7/27/2016 11:51	8/11/2016	44573	COPPER	0.1 PPM	1.3 PPM
19-20A Main hall Drinking Fountain (Left)	7/27/2016 11:53	8/11/2016	44574	COPPER	0.1 PPM	1.3 PPM
19-21A Main hall Drinking Fountain (Right)	7/27/2016 11:54	8/11/2016	44575	COPPER	0.6 PPM	1.3 PPM
19-22A Room 103 Sink Faucet	7/27/2016 11:56	8/11/2016	44576	COPPER	0.2 PPM	1.3 PPM
19-23A Room 103 Drinking Fountain	7/27/2016 11:56	8/11/2016	44577	COPPER	0.2 PPM	1.3 PPM
19-24A Room 104 Sink Faucet	7/27/2016 11:58	8/11/2016	44578	COPPER	0.1 PPM	1.3 PPM
19-25A Room 104 Drinking Fountain	7/27/2016 11:58	8/11/2016	44579	COPPER	0.2 PPM	1.3 PPM
19-26A Room 108 Sink Faucet	7/27/2016 12:00	8/11/2016	44580	COPPER	0.1 PPM	1.3 PPM
19-27A Room 108 Drinking Fountain	7/27/2016 12:00	8/11/2016	44581	COPPER	0.2 PPM	1.3 PPM
19-28A Room 107 Sink Faucet	7/27/2016 12:02	8/11/2016	44582	COPPER	0.2 PPM	1.3 PPM
19-29A Room 107 Drinking Fountain	7/27/2016 12:02	8/11/2016	44583	COPPER	0.3 PPM	1.3 PPM
19-30A Room 105 Sink Faucet	7/27/2016 12:04	8/11/2016	44584	COPPER	0.3 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Hallman Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
19-31A Room 105 Drinking Fountain	7/27/2016 12:04	8/11/2016	44585	COPPER	0.2 PPM	1.3 PPM
19-32A Room 106 Sink Faucet	7/27/2016 12:06	8/11/2016	44586	COPPER	0.2 PPM	1.3 PPM
19-33A Room 106 Drinking Fountain	7/27/2016 12:06	8/11/2016	44587	COPPER	0.2 PPM	1.3 PPM
19-34A Room 205 Sink Faucet	7/27/2016 12:15	8/11/2016	44588	COPPER	0.2 PPM	1.3 PPM
19-35A Room 205 Drinking Fountain	7/27/2016 12:15	8/11/2016	44589	COPPER	0.2 PPM	1.3 PPM
19-36A Room 204 Sink Faucet	7/27/2016 12:17	8/11/2016	44590	COPPER	0.2 PPM	1.3 PPM
19-37A Room 204 Drinking Fountain	7/27/2016 12:17	8/11/2016	44591	COPPER	0.2 PPM	1.3 PPM
19-38A Room 206 Sink Faucet	7/27/2016 12:19	8/11/2016	44592	COPPER	0.2 PPM	1.3 PPM
19-39A Room 206 Drinking Fountain	7/27/2016 12:19	8/11/2016	44593	COPPER	0.2 PPM	1.3 PPM
19-40A Room 203 Sink Faucet	7/27/2016 12:21	8/11/2016	44594	COPPER	0.2 PPM	1.3 PPM
19-41A Room 203 Drinking Fountain	7/27/2016 12:21	8/11/2016	44595	COPPER	0.2 PPM	1.3 PPM
19-42A Room 202 Sink Faucet	7/27/2016 12:23	8/11/2016	44596	COPPER	0.2 PPM	1.3 PPM
19-43A Room 202 Drinking Fountain	7/27/2016 12:23	8/11/2016	44597	COPPER	0.1 PPM	1.3 PPM
19-44A Room 207 Sink Faucet	7/27/2016 12:25	8/11/2016	44598	COPPER	0.2 PPM	1.3 PPM
19-45A Room 207 Drinking Fountain	7/27/2016 12:25	8/11/2016	44599	COPPER	0.1 PPM	1.3 PPM
19-46A 2nd Floor Hall Drinking Fountain 1	7/27/2016 12:27	8/11/2016	44600	COPPER	0.1 PPM	1.3 PPM
19-47A 2nd Floor Hall Drinking Fountain 2	7/27/2016 12:28	8/11/2016	44601	COPPER	0.1 PPM	1.3 PPM
19-48A Room 201 Sink Faucet	7/27/2016 12:30	8/11/2016	44602	COPPER	0.1 PPM	1.3 PPM
19-49A Room 201 Drinking Fountain	7/27/2016 12:30	8/11/2016	44603	COPPER	0.1 PPM	1.3 PPM
19-50A Room 208 Sink Faucet	7/27/2016 13:32	8/11/2016	44604	COPPER	0.1 PPM	1.3 PPM
19-51A Room 208 Drinking Fountain	7/27/2016 12:32	8/11/2016	44605	COPPER	0.1 PPM	1.3 PPM
19-52A Room 209 Sink Faucet	7/27/2016 12:34	8/11/2016	44606	COPPER	0.0 PPM	1.3 PPM
19-53A Room 209 Drinking Fountain	7/27/2016 12:34	8/11/2016	44607	COPPER	0.1 PPM	1.3 PPM
19-54A Library Sink Faucet	7/27/2016 12:36	8/11/2016	44608	COPPER	0.2 PPM	1.3 PPM
19-55A Library Drinking Fountain	7/27/2016 12:36	8/11/2016	44609	COPPER	0.1 PPM	1.3 PPM
19-56A Staff Room Sink Faucet	7/27/2016 12:38	8/11/2016	44610	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level