

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Hallman Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
19-01A Music Room Sink Faucet	7/27/2016 11:20	8/11/2016	44555	LEAD	4 PPB	15 PPB
19-02A Music Room Drinking Fountain	7/27/2016 11:20	8/11/2016	44556	LEAD	<1 PPB	15 PPB
19-03A Kitchen Sink Faucet	7/27/2016 11:22	8/11/2016	44557	LEAD	<1 PPB	15 PPB
19-04A Main Hall Restroom Drinking Fountain (Left)	7/27/2016 11:24	8/11/2016	44558	LEAD	<1 PPB	15 PPB
19-05A Main Hall Restroom Drinking Fountain (Right)	7/27/2016 11:25	8/11/2016	44559	LEAD	<1 PPB	15 PPB
19-06A Nurses Room Sink Faucet	7/27/2016 11:26	8/11/2016	44560	LEAD	1 PPB	15 PPB
19-07A Nurses Room Drinking Fountain	7/27/2016 11:26	8/11/2016	44561	LEAD	<1 PPB	15 PPB
19-08A Main Office Workroom Sink Faucet	7/27/2016 11:28	8/11/2016	44562	LEAD	2 PPB	15 PPB
19-09A Main Office Workroom Drinking Fountain	7/27/2016 11:28	8/11/2016	44563	LEAD	3 PPB	15 PPB
19-10A Counseling Office Sink Faucet	7/27/2016 11:42	8/11/2016	44564	LEAD	2 PPB	15 PPB
19-11A Counseling Office Drinking Fountain	7/27/2016 11:42	8/11/2016	44565	LEAD	<1 PPB	15 PPB
19-12A Room 110 Sink Faucet	7/27/2016 11:44	8/11/2016	44566	LEAD	1 PPB	15 PPB
19-13A Room 110 Drinking Fountain	7/27/2016 11:44	8/11/2016	44567	LEAD	2 PPB	15 PPB
19-14A Room 109 Sink Faucet	7/27/2016 11:47	8/11/2016	44568	LEAD	1 PPB	15 PPB
19-15A Room 109 Drinking Fountain	7/27/2016 11:47	8/11/2016	44569	LEAD	<1 PPB	15 PPB
19-16A Room 101 Sink Faucet	7/27/2016 11:49	8/11/2016	44570	LEAD	<1 PPB	15 PPB
19-17A Room 101 Drinking Fountain	7/27/2016 11:49	8/11/2016	44571	LEAD	<1 PPB	15 PPB
19-18A Room 102 Sink Faucet	7/27/2016 11:51	8/11/2016	44572	LEAD	1 PPB	15 PPB
19-19A Room 102 Drinking Fountain	7/27/2016 11:51	8/11/2016	44573	LEAD	<1 PPB	15 PPB
19-20A Main hall Drinking Fountain (Left)	7/27/2016 11:53	8/11/2016	44574	LEAD	<1 PPB	15 PPB
19-21A Main hall Drinking Fountain (Right)	7/27/2016 11:54	8/11/2016	44575	LEAD	<1 PPB	15 PPB
19-22A Room 103 Sink Faucet	7/27/2016 11:56	8/11/2016	44576	LEAD	<1 PPB	15 PPB
19-23A Room 103 Drinking Fountain	7/27/2016 11:56	8/11/2016	44577	LEAD	<1 PPB	15 PPB
19-24A Room 104 Sink Faucet	7/27/2016 11:58	8/11/2016	44578	LEAD	3 PPB	15 PPB
19-25A Room 104 Drinking Fountain	7/27/2016 11:58	8/11/2016	44579	LEAD	<1 PPB	15 PPB
19-26A Room 108 Sink Faucet	7/27/2016 12:00	8/11/2016	44580	LEAD	<1 PPB	15 PPB
19-27A Room 108 Drinking Fountain	7/27/2016 12:00	8/11/2016	44581	LEAD	<1 PPB	15 PPB
19-28A Room 107 Sink Faucet	7/27/2016 12:02	8/11/2016	44582	LEAD	1 PPB	15 PPB
19-29A Room 107 Drinking Fountain	7/27/2016 12:02	8/11/2016	44583	LEAD	<1 PPB	15 PPB
19-30A Room 105 Sink Faucet	7/27/2016 12:04	8/11/2016	44584	LEAD	1 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Hallman Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
19-31A Room 105 Drinking Fountain	7/27/2016 12:04	8/11/2016	44585	LEAD	<1 PPB	15 PPB
19-32A Room 106 Sink Faucet	7/27/2016 12:06	8/11/2016	44586	LEAD	3 PPB	15 PPB
19-33A Room 106 Drinking Fountain	7/27/2016 12:06	8/11/2016	44587	LEAD	<1 PPB	15 PPB
19-34A Room 205 Sink Faucet	7/27/2016 12:15	8/11/2016	44588	LEAD	3 PPB	15 PPB
19-35A Room 205 Drinking Fountain	7/27/2016 12:15	8/11/2016	44589	LEAD	<1 PPB	15 PPB
19-36A Room 204 Sink Faucet	7/27/2016 12:17	8/11/2016	44590	LEAD	3 PPB	15 PPB
19-37A Room 204 Drinking Fountain	7/27/2016 12:17	8/11/2016	44591	LEAD	<1 PPB	15 PPB
19-38A Room 206 Sink Faucet	7/27/2016 12:19	8/11/2016	44592	LEAD	4 PPB	15 PPB
19-39A Room 206 Drinking Fountain	7/27/2016 12:19	8/11/2016	44593	LEAD	<1 PPB	15 PPB
19-40A Room 203 Sink Faucet	7/27/2016 12:21	8/11/2016	44594	LEAD	4 PPB	15 PPB
19-41A Room 203 Drinking Fountain	7/27/2016 12:21	8/11/2016	44595	LEAD	<1 PPB	15 PPB
19-42A Room 202 Sink Faucet	7/27/2016 12:23	8/11/2016	44596	LEAD	1 PPB	15 PPB
19-43A Room 202 Drinking Fountain	7/27/2016 12:23	8/11/2016	44597	LEAD	<1 PPB	15 PPB
19-44A Room 207 Sink Faucet	7/27/2016 12:25	8/11/2016	44598	LEAD	1 PPB	15 PPB
19-45A Room 207 Drinking Fountain	7/27/2016 12:25	8/11/2016	44599	LEAD	<1 PPB	15 PPB
19-46A 2nd Floor Hall Drinking Fountain 1	7/27/2016 12:27	8/11/2016	44600	LEAD	<1 PPB	15 PPB
19-47A 2nd Floor Hall Drinking Fountain 2	7/27/2016 12:28	8/11/2016	44601	LEAD	<1 PPB	15 PPB
19-48A Room 201 Sink Faucet	7/27/2016 12:30	8/11/2016	44602	LEAD	2 PPB	15 PPB
19-49A Room 201 Drinking Fountain	7/27/2016 12:30	8/11/2016	44603	LEAD	<1 PPB	15 PPB
19-50A Room 208 Sink Faucet	7/27/2016 13:32	8/11/2016	44604	LEAD	2 PPB	15 PPB
19-51A Room 208 Drinking Fountain	7/27/2016 12:32	8/11/2016	44605	LEAD	<1 PPB	15 PPB
19-52A Room 209 Sink Faucet	7/27/2016 12:34	8/11/2016	44606	LEAD	<1 PPB	15 PPB
19-53A Room 209 Drinking Fountain	7/27/2016 12:34	8/11/2016	44607	LEAD	<1 PPB	15 PPB
19-54A Library Sink Faucet	7/27/2016 12:36	8/11/2016	44608	LEAD	3 PPB	15 PPB
19-55A Library Drinking Fountain	7/27/2016 12:36	8/11/2016	44609	LEAD	<1 PPB	15 PPB
19-56A Staff Room Sink Faucet	7/27/2016 12:38	8/11/2016	44610	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level