

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Harritt Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result	Action Level
018-01A Kitchen Food Prep Sink Faucet	7/15/16 4:50 AM	7/22/2016	41820	LEAD	<1 PPB	15 PPB
018-02A Multi-Purpose Room Sink Faucet	7/15/16 4:53 AM	7/22/2016	41821	LEAD	2 PPB	15 PPB
018-03A Bathroom Drinking Fountain 1	7/15/16 4:58 AM	7/22/2016	41822	LEAD	<1 PPB	15 PPB
018-04A Bathroom Drinking Fountain 2	7/15/16 5:00 AM	7/22/2016	41823	LEAD	<1 PPB	15 PPB
018-05A Music Room Drinking Fountain	7/15/16 5:05 AM	7/22/2016	41824	LEAD	2 PPB	15 PPB
018-06A Music Room Sink Faucet	7/15/16 5:07 AM	7/22/2016	41825	LEAD	3 PPB	15 PPB
018-07A Nurse/Health Office Drinking Fountain	7/15/16 5:11 AM	7/22/2016	41826	LEAD	3 PPB	15 PPB
018-08A Nurse/Health Office Sink Faucet	7/15/16 5:13 AM	7/22/2016	41827	LEAD	2 PPB	15 PPB
018-09A Office Workroom Drinking Fountain	7/15/16 5:17 AM	7/22/2016	41828	LEAD	5 PPB	15 PPB
018-10A Office Workroom Sink Faucet	7/15/16 5:19 AM	7/22/2016	41829	LEAD	1 PPB	15 PPB
018-11A Faculty Lounge Sink Faucet	7/15/16 5:22 AM	7/22/2016	41830	LEAD	<1 PPB	15 PPB
018-12A Classroom B1 Drinking Fountain	7/15/16 5:27 AM	7/22/2016	41831	LEAD	3 PPB	15 PPB
018-13A Classroom B1 Sink Faucet	7/15/16 5:29 AM	7/22/2016	41832	LEAD	7 PPB	15 PPB
018-14A Classroom B2 Drinking Fountain	7/15/16 5:33 AM	7/22/2016	41833	LEAD	2 PPB	15 PPB
018-15A Classroom B2 Sink Faucet	7/15/16 5:35 AM	7/22/2016	41834	LEAD	3 PPB	15 PPB
018-16A Classroom B3 Drinking Fountain	7/15/16 5:39 AM	7/22/2016	41835	LEAD	3 PPB	15 PPB
018-17A Classroom B3 Sink Faucet	7/15/16 5:41 AM	7/22/2016	41836	LEAD	2 PPB	15 PPB
018-18A Classroom B4 Drinking Fountain	7/15/16 5:45 AM	7/22/2016	41837	LEAD	3 PPB	15 PPB
018-19A Classroom B4 Sink Faucet	7/15/16 5:47 AM	7/21/2016	41838	LEAD	9 PPB	15 PPB
018-20A Classroom B5 Drinking Fountain	7/15/16 5:50 AM	7/22/2016	41839	LEAD	3 PPB	15 PPB
018-21A Classroom B5 Sink Faucet	7/15/16 5:52 AM	7/22/2016	41840	LEAD	2 PPB	15 PPB
018-22A Classroom B6 Drinking Fountain	7/15/16 5:57 AM	7/22/2016	41841	LEAD	2 PPB	15 PPB
018-23A Classroom B6 Sink Faucet	7/15/16 5:59 AM	7/22/2016	41842	LEAD	11 PPB	15 PPB
018-24A Classroom C1 Drinking Fountain	7/15/16 6:05 AM	7/22/2016	41843	LEAD	4 PPB	15 PPB
018-25A Classroom C1 Sink Faucet	7/15/16 6:07 AM	7/22/2016	41844	LEAD	2 PPB	15 PPB
018-26A Classroom C2 Drinking Fountain	7/15/16 6:11 AM	7/22/2016	41845	LEAD	3 PPB	15 PPB
018-27A Classroom C2 Sink Faucet	7/15/16 6:13 AM	7/22/2016	41846	LEAD	2 PPB	15 PPB
018-28A Classroom C3 Drinking Fountain	7/15/16 6:17 AM	7/22/2016	41847	LEAD	2 PPB	15 PPB
018-29A Classroom C3 Sink Faucet	7/15/16 6:19 AM	7/22/2016	41848	LEAD	2 PPB	15 PPB
018-30A Classroom C4 Drinking Fountain	7/15/16 6:23 AM	7/22/2016	41849	LEAD	2 PPB	15 PPB
018-31A Classroom C4 Sink Faucet	7/15/16 6:25 AM	7/22/2016	41850	LEAD	2 PPB	15 PPB
018-32A Classroom C5 Drinking Fountain	7/15/16 6:30 AM	7/22/2016	41851	LEAD	2 PPB	15 PPB
018-33A Classroom C5 Sink Faucet	7/15/16 6:32 AM	7/22/2016	41852	LEAD	3 PPB	15 PPB
018-34A Classroom C6 Drinking Fountain	7/15/16 6:35 AM	7/22/2016	41853	LEAD	2 PPB	15 PPB
018-35A Classroom C6 Sink Faucet	7/15/16 6:37 AM	7/22/2016	41854	LEAD	2 PPB	15 PPB
018-36A LRC Drinking Fountain	7/15/16 6:42 AM	7/22/2016	41855	LEAD	4 PPB	15 PPB
018-37A LRC Sink Faucet	7/15/16 6:44 AM	7/22/2016	41856	LEAD	1 PPB	15 PPB
018-38A Classroom A6 Drinking Fountain	7/15/16 6:48 AM	7/22/2016	41857	LEAD	1 PPB	15 PPB
018-39A Classroom A6 Sink Faucet	7/15/16 6:50 AM	7/22/2016	41858	LEAD	<1 PPB	15 PPB
018-40A Classroom A5 Drinking Fountain	7/15/16 6:54 AM	7/22/2016	41859	LEAD	3 PPB	15 PPB
018-41A Classroom A5 Sink Faucet	7/15/16 6:56 AM	7/22/2016	41860	LEAD	2 PPB	15 PPB
018-42A Classroom A4 Drinking Fountain	7/15/16 7:01 AM	7/22/2016	41861	LEAD	2 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Harritt Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result	Action Level
018-43A Classroom A4 Sink Faucet	7/15/16 7:03 AM	7/22/2016	41862	LEAD	2 PPB	15 PPB
018-44A Classroom A3 Drinking Fountain	7/15/16 7:06 AM	7/22/2016	41863	LEAD	3 PPB	15 PPB
018-45A Classroom A3 Sink Faucet	7/15/16 7:08 AM	7/22/2016	41864	LEAD	2 PPB	15 PPB
018-46A Classroom A2 Drinking Fountain	7/15/16 7:13 AM	7/22/2016	41865	LEAD	3 PPB	15 PPB
018-47A Classroom A2 Sink Faucet	7/15/16 7:15 AM	7/22/2016	41866	LEAD	<1 PPB	15 PPB
018-48A Classroom A1 Drinking Fountain	7/15/16 7:18 AM	7/22/2016	41867	LEAD	4 PPB	15 PPB
018-49A Classroom A2 Sink Faucet	7/15/16 7:20 AM	7/22/2016	41868	LEAD	1 PPB	15 PPB
018-50A Classroom M1 Drinking Fountain	7/15/16 7:27 AM	7/22/2016	41869	LEAD	2 PPB	15 PPB
018-51A Classroom M1 Sink Faucet	7/15/16 7:29 AM	7/22/2016	41870	LEAD	3 PPB	15 PPB
018-52A Classroom M2 Drinking Fountain	7/15/16 7:32 AM	7/22/2016	41871	LEAD	2 PPB	15 PPB
018-53A Classroom M2 Sink Faucet	7/15/16 7:34 AM	7/22/2016	41872	LEAD	1 PPB	15 PPB
018-54A Classroom M3 Sink Faucet	7/15/16 7:37 AM	7/22/2016	41873	LEAD	3 PPB	15 PPB
018-55A Classroom M3 Drinking Fountain	7/15/16 7:39 AM	7/22/2016	41874	LEAD	<1 PPB	15 PPB
018-56A Classroom M4 Sink Faucet	7/15/16 7:43 AM	7/22/2016	41875	LEAD	3 PPB	15 PPB
018-57A Classroom M4 Drinking Fountain	7/15/16 7:45 AM	7/22/2016	41876	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB						
SKPS Action Level for Lead is 15 PPB						
Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level						