

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Hayesville Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
29-01A Staff Room (12) Sink Faucet	7/28/2016 12:59	8/16/2016	45529	LEAD	2 PPB	15 PPB
29-02A Drinking Fountain in Hall Between Boys & Girls Restrooms	7/28/2016 13:02	8/16/2016	45530	LEAD	<1 PPB	15 PPB
29-03A Room 20 (Library) Office Sink Faucet	7/28/2016 13:05	8/16/2016	45531	LEAD	<1 PPB	15 PPB
29-04A Room 20 (Library) Office Drinking Fountain	7/28/2016 13:05	8/16/2016	45532	LEAD	21 PPB	15 PPB
29-05A Room 13 Sink Faucet	7/28/2016 13:09	8/16/2016	45533	LEAD	14 PPB	15 PPB
29-06A Room 13 Drinking Fountain	7/28/2016 13:09	8/16/2016	45534	LEAD	<1 PPB	15 PPB
29-07A Classroom 14 Sink Faucet	7/28/2016 13:14	8/16/2016	45535	LEAD	2 PPB	15 PPB
29-08A Classroom 14 Drinking Fountain	7/28/2016 13:15	8/16/2016	45536	LEAD	<1 PPB	15 PPB
29-09A Classroom 19 Sink Faucet	7/28/2016 13:19	8/16/2016	45537	LEAD	2 PPB	15 PPB
29-10A Classroom 19 Drinking Fountain	7/28/2016 13:20	8/16/2016	45538	LEAD	1 PPB	15 PPB
29-11A Classroom 18 Sink Faucet	7/28/2016 13:24	8/16/2016	45539	LEAD	1 PPB	15 PPB
29-12A Classroom 18 Drinking Fountain	7/28/2016 13:25	8/16/2016	45540	LEAD	2 PPB	15 PPB
29-13A Classroom 15 Sink Faucet	7/28/2016 13:29	8/16/2016	45541	LEAD	2 PPB	15 PPB
29-14A Classroom 15 Drinking Fountain	7/28/2016 13:30	8/16/2016	45542	LEAD	<1 PPB	15 PPB
29-15A Classroom 15 Sink Faucet	7/28/2016 13:35	8/16/2016	45543	LEAD	<1 PPB	15 PPB
29-16A Classroom 16 Drinking Fountain	7/28/2016 13:35	8/16/2016	45544	LEAD	<1 PPB	15 PPB
29-17A Classroom 17 Sink Faucet	7/28/2016 13:38	8/16/2016	45545	LEAD	<1 PPB	15 PPB
29-18A Classroom 17 Drinking Fountain	7/28/2016 13:38	8/16/2016	45546	LEAD	<1 PPB	15 PPB
29-19A Kitchen Storage Room Sink	7/28/2016 13:52	8/16/2016	45547	LEAD	<1 PPB	15 PPB
29-20A Kitchen Left Faucet on Triple Sink	7/28/2016 14:01	8/16/2016	45548	LEAD	14 PPB	15 PPB
29-21A Kitchen Center Faucet Triple Sink	7/28/2016 14:01	8/16/2016	45549	LEAD	48 PPB	15 PPB
29-22A Kitchen Right Sink Faucet	7/28/2016 14:03	8/16/2016	45550	LEAD	42 PPB	15 PPB
29-23A Kitchen Sink Faucet Right of Dishwasher	7/28/2016 14:04	8/16/2016	45551	LEAD	2 PPB	15 PPB
29-24A Hall Between Kitchen & MPR Drinking Fountain	7/28/2016 14:07	8/16/2016	45552	LEAD	<1 PPB	15 PPB
29-25A Faculty Workroom Sink Faucet	7/28/2016 14:11	8/16/2016	45553	LEAD	<1 PPB	15 PPB
29-26A Classroom 1 Sink Faucet	7/28/2016 14:14	8/16/2016	45554	LEAD	3 PPB	15 PPB
29-27A Classroom 1 Drinking Fountain	7/28/2016 14:15	8/16/2016	45555	LEAD	<1 PPB	15 PPB
29-28A Classroom 11 Sink Faucet	7/28/2016 14:18	8/16/2016	45556	LEAD	5 PPB	15 PPB
29-29A Classroom 11 Drinking Fountain	7/28/2016 14:19	8/16/2016	45557	LEAD	2 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Hayesville Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
29-30A Classroom 2 Sink Faucet	7/28/2016 14:22	8/16/2016	45558	LEAD	6 PPB	15 PPB
29-31A Classroom 2 Drinking Fountain	7/28/2016 14:23	8/16/2016	45559	LEAD	<1 PPB	15 PPB
29-32A Classroom 10 Sink Faucet	7/28/2016 14:27	8/16/2016	45560	LEAD	2 PPB	15 PPB
29-33A Classroom 10 Drinking Fountain	7/28/2016 14:28	8/16/2016	45561	LEAD	2 PPB	15 PPB
29-34A Classroom 3 Sink Faucet	7/28/2016 14:30	8/16/2016	45562	LEAD	3 PPB	15 PPB
29-35A Calsroom 3 Drinking Fountain	7/28/2016 14:31	8/16/2016	45563	LEAD	<1 PPB	15 PPB
29-36A Hallway Drinking Fountain Across from Room 4	7/28/2016 14:34	8/16/2016	45564	LEAD	<1 PPB	15 PPB
29-37A Classroom 4 Sink Faucet	7/28/2016 14:37	8/16/2016	45565	LEAD	3 PPB	15 PPB
29-38A Calsroom 4 Drinking Fountain	7/28/2016 14:38	8/16/2016	45566	LEAD	2 PPB	15 PPB
29-39A Classroom 9 Sink Faucet	7/28/2016 14:42	8/16/2016	45567	LEAD	7 PPB	15 PPB
29-40A Classroom 9 Drinking Fountain	7/28/2016 14:43	8/16/2016	45568	LEAD	<1 PPB	15 PPB
29-41A Classroom 5 Sink Faucet	7/28/2016 14:48	8/16/2016	45569	LEAD	2 PPB	15 PPB
29-42A Classroom 5 Drinking Fountain	7/28/2016 14:49	8/16/2016	45570	LEAD	<1 PPB	15 PPB
29-43A Classroom 8 Sink Faucet	7/28/2016 14:53	8/16/2016	45571	LEAD	2 PPB	15 PPB
29-44A Classroom 8 Drinking Fountain	7/28/2016 14:54	8/16/2016	45572	LEAD	<1 PPB	15 PPB
<b>29-45A Classroom 6 Sink Faucet</b>	<b>7/28/2016 14:56</b>	<b>8/16/2016</b>	<b>45573</b>	<b>LEAD</b>	<b>17 PPB</b>	<b>15 PPB</b>
29-46A Classroom 6 Drinking Fountain	7/28/2016 14:57	8/16/2016	45574	LEAD	<1 PPB	15 PPB
29-47A Classroom 7 Sink Faucet	7/28/2016 15:01	8/16/2016	45575	LEAD	4 PPB	15 PPB
29-48A Classroom 7 Drinking Fountain	7/28/2016 15:02	8/16/2016	45576	LEAD	1 PPB	15 PPB
29-49A Gymnasium Drinking Fountain	7/28/2016 15:06	8/16/2016	45577	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
30 Second Draw (B) Sample Data  
Hayesville Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
29-04B Room 20 (Library) Office Water Fountain	7/28/2016 13:06	9/1/2016	52938	LEAD	2 PPB	15 PPB
29-21B Kitchen Center Faucet on Triple Sink	7/28/2016 14:03	9/1/2016	52939	LEAD	<1 PPB	15 PPB
29-22B Kitchen Right Sink Faucet	7/28/2016 14:04	9/1/2016	52940	LEAD	<1 PPB	15 PPB
29-45B Classroom 6 Sink Faucet	7/28/2016 15:07	9/1/2016	52941	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (C) Sample Data  
Hayesville Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
29-04C Room 20 (Library) Office Drinking Fountain	10/28/2016 6:13	11/1/2016	65991	LEAD	4 PPB	15 PPB
29-21C Kitchen Center Faucet Triple Sink	10/28/2016 6:09	11/1/2016	65992	LEAD	1 PPB	15 PPB
29-22C Kitchen Right Sink Faucet	10/28/2016 6:09	11/1/2016	65993	LEAD	6 PPB	15 PPB
29-45C Classroom 6 Sink Faucet	10/28/2016 6:17	11/1/2016	65994	LEAD	13 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level