

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Highland Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
23-01A	Room 1 Drinking Fountain	8/6/16 12:16	8/10/2016	1608453-01A	COPPER 0.1 PPM	1.3 PPM
23-02A	Room 1 Sink Faucet	8/6/16 12:16	8/10/2016	1608453-02A	COPPER 0.1 PPM	1.3 PPM
23-03A	Room 2 Sink Faucet	8/6/16 12:18	8/10/2016	1608453-03A	COPPER 0.2 PPM	1.3 PPM
23-04A	Room 2 Drinking Fountain	8/6/16 12:18	8/10/2016	1608453-04A	COPPER 0.2 PPM	1.3 PPM
23-05A	Room 3 Drinking Fountain	8/6/16 12:20	8/10/2016	1608453-05A	COPPER 0.2 PPM	1.3 PPM
23-06A	Room 3 Sink Faucet	8/6/16 12:20	8/10/2016	1608453-06A	COPPER 0.2 PPM	1.3 PPM
23-07A	Room 4 Drinking Fountain	8/6/16 12:22	8/10/2016	1608453-07A	COPPER 0.4 PPM	1.3 PPM
23-08A	Room 4 Sink Faucet	8/6/16 12:23	8/10/2016	1608453-08A	COPPER 0.4 PPM	1.3 PPM
23-09A	Hall by Custodian Drinking Fountain 1	8/6/16 12:24	8/10/2016	1608453-09A	COPPER 0.5 PPM	1.3 PPM
23-10A	Room 5 Drinking Fountain	8/6/16 12:26	8/10/2016	1608453-10A	COPPER 0.5 PPM	1.3 PPM
23-11A	Room 5 Sink Faucet	8/6/16 12:26	8/10/2016	1608453-11A	COPPER 0.3 PPM	1.3 PPM
23-12A	Room 6 Drinking Fountain	8/6/16 12:29	8/10/2016	1608453-12A	COPPER 0.4 PPM	1.3 PPM
23-13A	Room 6 Sink Faucet	8/6/16 12:29	8/10/2016	1608453-13A	COPPER 0.3 PPM	1.3 PPM
23-14A	Room 7 Drinking Fountain	8/6/16 12:46	8/10/2016	1608453-14A	COPPER 0.7 PPM	1.3 PPM
23-15A	Room 7 Sink Faucet	8/6/16 12:46	8/10/2016	1608453-15A	COPPER 0.2 PPM	1.3 PPM
23-16A	Room 8 Drinking Fountain	8/6/16 12:49	8/10/2016	1608453-16A	COPPER 0.3 PPM	1.3 PPM
23-17A	Room 8 Sink Faucet	8/6/16 12:49	8/10/2016	1608453-17A	COPPER 0.3 PPM	1.3 PPM
23-18A	Hall Drinking Fountain 2	8/6/16 12:52	8/10/2016	1608453-18A	COPPER 0.5 PPM	1.3 PPM
23-19A	Health Room Nurse's Station Sink Faucet	8/6/16 12:54	8/10/2016	1608453-19A	COPPER 0.3 PPM	1.3 PPM
23-20A	Health Room Nurse's Station Drinking Fountain	8/6/16 12:54	8/10/2016	1608453-20A	COPPER 0.4 PPM	1.3 PPM
23-21A	Room 9 Drinking Fountain	8/6/16 12:56	8/11/2016	1608453-21A	COPPER 0.3 PPM	1.3 PPM
23-22A	Room 9 Sink Faucet	8/6/16 12:56	8/11/2016	1608453-22A	COPPER 0.2 PPM	1.3 PPM
23-23A	Staff Room Alcove Sink Faucet	8/6/16 12:58	8/11/2016	1608453-23A	COPPER 0.4 PPM	1.3 PPM
23-24A	Room 11 Drinking Fountain	8/6/16 13:00	8/11/2016	1608453-24A	COPPER 0.1 PPM	1.3 PPM
23-25A	Room 11 Sink Faucet	8/6/16 13:00	8/11/2016	1608453-25A	COPPER 0.1 PPM	1.3 PPM
23-26A	Library Sink Faucet	8/6/16 13:05	8/11/2016	1608453-26A	COPPER 0.2 PPM	1.3 PPM
23-27A	Library Drinking Fountain	8/6/16 13:05	8/11/2016	1608453-27A	COPPER 0.2 PPM	1.3 PPM
23-29A	Computer Room 16 Sink Faucet	8/6/16 13:19	8/11/2016	1608453-28A	COPPER 0.1 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Highland Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
23-30A Room 18 Sink Faucet	8/6/16 13:22	8/11/2016	1608453-29A	COPPER	0.3 PPM	1.3 PPM
23-31A Room 18 Drinking Fountain	8/6/16 13:22	8/11/2016	1608453-30A	COPPER	0.1 PPM	1.3 PPM
23-32A Room 19 Sink Faucet	8/6/16 13:26	8/11/2016	1608453-31A	COPPER	0.1 PPM	1.3 PPM
23-33A Room 19 Drinking Fountain	8/6/16 13:26	8/11/2016	1608453-32A	COPPER	0.0 PPM	1.3 PPM
23-34A Room 12 Drinking Fountain	8/6/16 13:29	8/11/2016	1608453-33A	COPPER	0.2 PPM	1.3 PPM
23-35A Room 12 Sink Faucet	8/6/16 13:29	8/11/2016	1608453-34A	COPPER	0.1 PPM	1.3 PPM
23-36A Room 15 Drinking Fountain	8/6/16 13:31	8/11/2016	1608453-35A	COPPER	0.3 PPM	1.3 PPM
23-37A Room 15 Sink Faucet	8/6/16 13:31	8/11/2016	1608453-36A	COPPER	0.2 PPM	1.3 PPM
23-38A 3rd Floor Hall Drinking Fountain by Custodial Room 3	8/6/16 13:32	8/11/2016	1608453-37A	COPPER	0.8 PPM	1.3 PPM
23-39A Room 13 Drinking Fountain	8/6/16 13:35	8/11/2016	1608453-38A	COPPER	0.6 PPM	1.3 PPM
23-40A Room 13 Sink Faucet	8/6/16 13:35	8/11/2016	1608453-39A	COPPER	0.3 PPM	1.3 PPM
23-41A Room 12 Drinking Fountain	8/6/16 13:37	8/11/2016	1608453-40A	COPPER	0.5 PPM	1.3 PPM
23-42A Room 12 Sink Faucet	8/6/16 13:37	8/11/2016	1608453-41A	COPPER	0.3 PPM	1.3 PPM
23-43A Gymnasium Restroom Drinking Fountain	8/6/16 13:49	8/11/2016	1608453-42A	COPPER	0.2 PPM	1.3 PPM
23-44A Music Room Sink Faucet	8/6/16 13:52	8/11/2016	1608453-43A	COPPER	0.2 PPM	1.3 PPM
23-45A Room 28 Portable Sink Faucet	8/6/16 13:59	8/11/2016	1608453-44A	COPPER	0.2 PPM	1.3 PPM
23-46A Room 28 Drinking Fountain	8/6/16 13:59	8/11/2016	1608453-45A	COPPER	0.3 PPM	1.3 PPM
23-47A Room 28 Sink Faucet	8/6/16 14:01	8/11/2016	1608453-46A	COPPER	0.2 PPM	1.3 PPM
23-48A Room 28 Drinking Fountain	8/6/16 14:01	8/11/2016	1608453-47A	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Highland Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
23-28A Computer Room 16 Drinking Fountain	9/23/2016 4:41	9/26/2016	58300	COPPER	0.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (C) Sample Data
Highland Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
23-28C Computer Room 16 Drinking Fountain	10/27/2016 5:29	10/28/2016	65859	COPPER	0.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level