

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Judson Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
028-01A Hallway Drinking Fountain 1	7/29/16 11:45	8/11/16 11:22	608013201	COPPER	0.6 PPM	1.3 PPM
028-02A Boys Lockers Drinking Fountain	7/29/16 11:48	8/11/16 11:23	608013202	COPPER	0.8 PPM	1.3 PPM
028-03A Gymnasium Drinking Fountain	7/29/16 11:50	8/11/16 11:21	608013203	COPPER	0.6 PPM	1.3 PPM
028-04A Gymnasium Drinking Fountain	7/29/16 11:52	8/11/16 11:21	608013204	COPPER	0.3 PPM	1.3 PPM
028-05A Girls Lockers Drinking Fountain	7/29/16 11:54	8/11/16 11:21	608013205	COPPER	0.7 PPM	1.3 PPM
028-06A Auxillary Gymnasium Drinking Fountain	7/29/16 11:59	8/11/16 11:21	608013206	COPPER	0.6 PPM	1.3 PPM
028-07A Auxillary Gymnasium Drinking Fountain	7/29/16 12:00	8/11/16 11:22	608013207	COPPER	0.5 PPM	1.3 PPM
028-08A Hallway Drinking Fountain 2	7/29/16 12:05	8/11/16 11:22	608013208	COPPER	0.8 PPM	1.3 PPM
028-12A Staff Lounge Sink Faucet	7/29/16 12:12	8/11/16 11:22	608013209	COPPER	0.7 PPM	1.3 PPM
028-13A Classroom 105 Sink Faucet	7/29/16 12:15	8/11/16 11:22	608013210	COPPER	0.8 PPM	1.3 PPM
028-14A Classroom 105 Drinking Fountain	7/29/16 12:15	8/11/16 11:23	608013211	COPPER	0.9 PPM	1.3 PPM
028-15A Classroom 102 Sink Faucet	7/29/16 12:19	8/11/16 11:23	608013212	COPPER	0.8 PPM	1.3 PPM
028-16A Classroom 102 Drinking Fountain	7/29/16 12:19	8/11/16 11:25	608013213	COPPER	1.3 PPM	1.3 PPM
028-17A Office Conference Sink Faucet	7/29/16 12:23	8/11/16 11:23	608013214	COPPER	0.9 PPM	1.3 PPM
028-18A Library Break Area Sink Faucet	7/29/16 12:27	8/11/16 11:23	608013215	COPPER	0.9 PPM	1.3 PPM
028-19A Hallway Drinking Fountain 5	7/29/16 12:31	8/11/16 11:23	608013216	COPPER	0.9 PPM	1.3 PPM
028-20A Classroom 410 Sink Faucet	7/29/16 12:34	8/11/16 11:23	608013217	COPPER	0.8 PPM	1.3 PPM
028-21A Classroom 410 Drinking Fountain	7/29/16 12:34	8/11/16 11:23	608013218	COPPER	0.9 PPM	1.3 PPM
028-22A Home Economics Sink Faucet (1)	7/29/16 12:40	8/11/16 11:24	608013219	COPPER	0.4 PPM	1.3 PPM
028-23A Home Economics Sink Faucet (2)	7/29/16 12:41	8/11/16 11:24	608013220	COPPER	0.7 PPM	1.3 PPM
028-24A Home Economics Sink Faucet (3)	7/29/16 12:42	8/11/16 11:24	608013221	COPPER	0.8 PPM	1.3 PPM
028-25A Home Economics Sink Faucet (4)	7/29/16 12:43	8/11/16 11:24	608013222	COPPER	0.8 PPM	1.3 PPM
028-26A Home Economics Sink Faucet (5)	7/29/16 12:44	8/11/16 11:24	608013223	COPPER	0.7 PPM	1.3 PPM
028-27A Home Economics Sink Faucet (6)	7/29/16 12:45	8/11/16 11:24	608013224	COPPER	0.7 PPM	1.3 PPM
028-28A Home Economics Sink Faucet (7)	7/29/16 12:46	8/11/16 11:24	608013225	COPPER	0.8 PPM	1.3 PPM
028-29A Hallway Drinking Fountain 6	7/29/16 12:51	8/11/16 11:26	608013226	COPPER	1.2 PPM	1.3 PPM
028-30A Classroom 310 Sink Faucet	7/29/16 12:56	8/11/16 11:24	608013227	COPPER	0.6 PPM	1.3 PPM
028-31A Classroom 310 Drinking Fountain	7/29/16 12:56	8/11/16 11:24	608013228	COPPER	0.9 PPM	1.3 PPM
028-32A Classroom 308 Sink Faucet	7/29/16 13:00	8/11/16 11:29	608013229	COPPER	0.4 PPM	1.3 PPM
028-33A Classroom 308 Drinking Fountain	7/29/16 13:00	8/11/16 11:29	608013230	COPPER	0.8 PPM	1.3 PPM
028-34A Hallway Drinking Fountain 7	7/29/16 13:04	8/12/16 12:35	608013231	COPPER	1.3 PPM	1.3 PPM
028-35A Hallway Drinking Fountain 8	7/29/16 13:07	8/11/16 11:29	608013232	COPPER	1.0 PPM	1.3 PPM
028-36A Hallway Drinking Fountain 9	7/29/16 13:10	8/11/16 11:29	608013233	COPPER	0.7 PPM	1.3 PPM
028-37A Office/Health Sink Faucet	7/29/16 13:15	8/11/16 11:29	608013234	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
Flushed (B) Sample Data
Judson Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
028-16B Classroom 102 Drinking Fountain	7/29/16 12:20	8/25/16 11:18	608231501	COPPER	0.5 PPM	1.3 PPM
028-34B Hallway Drinking Fountain 7	7/29/16 13:05	8/26/16 11:49	608231502	COPPER	1.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Judson Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
028-09A Cafeteria Drinking Fountain	9/22/2016 5:30	9/27/2016	57947	COPPER	1.8 PPM	1.3 PPM
028-10A Hallway Drinking Fountain #3	9/22/2016 5:32	9/27/2016	57948	COPPER	2.0 PPM	1.3 PPM
028-11A Hallway Drinking Fountain #4	9/22/2016 5:34	9/27/2016	57949	COPPER	1.6 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
 Copper Water Sampling Results
 Flushed (B) Sample Data
 Judson Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
028-09B Cafeteria Drinking Fountain	9/22/2016 5:31	10/18/2016	62710	COPPER	1.7 PPM	1.3 PPM
028-10B Hallway Drinking Fountain 3	9/22/2016 5:33	10/18/2016	62711	COPPER	1.9 PPM	1.3 PPM
028-11B Hallway Drinking Fountain 4	9/22/2016 5:35	10/18/2016	62712	COPPER	1.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (C) Sample Data
Judson Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
028-16C Classroom 102 Drinking Fountain	9/29/2016 5:58	10/3/2016	59454	COPPER	1.0 PPM	1.3 PPM
028-34C Hallway Drinking Fountain 7	9/29/2016 6:07	10/4/2016	59455	COPPER	1.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (C) Sample Data
Judson Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
028-09C Cafeteria Drinking Fountain	1/6/2017 6:25	1/9/2017	790	COPPER	0.7 PPM	1.3 PPM
028-10C Hallway Drinking Fountain #3	1/6/2017 6:27	1/9/2017	791	COPPER	0.5 PPM	1.3 PPM
028-11C Hallway Drinking Fountain #4	1/6/2017 6:28	1/9/2017	792	COPPER	0.7 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level