

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Kalapuya Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result	Action Level
022-01A Music Room Drinking Fountain 1	7/15/16 11:00 AM	7/21/2016	41930	COPPER	0.7 PPM	1.3 PPM
022-02A Music Room Drinking Fountain 2	7/15/16 11:02 AM	7/21/2016	41931	COPPER	0.6 PPM	1.3 PPM
022-03A Music Room Sink Faucet	7/15/16 11:04 AM	7/21/2016	41932	COPPER	0.4 PPM	1.3 PPM
022-04A Kitchen Food Prep Sink Faucet	7/15/16 11:08 AM	7/21/2016	41933	COPPER	0.3 PPM	1.3 PPM
022-05A Gymnasium Drinking Fountain 1	7/15/16 11:12 AM	7/21/2016	41934	COPPER	1.0 PPM	1.3 PPM
022-06A Gymnasium Drinking Fountain 2	7/15/16 11:14 AM	7/21/2016	41935	COPPER	1.0 PPM	1.3 PPM
022-07A Health Room Sink Faucet	7/15/16 10:51 AM	7/21/2016	41936	COPPER	0.4 PPM	1.3 PPM
022-08A Faculty Lounge Sink Faucet	7/15/16 10:55 AM	7/21/2016	41937	COPPER	0.3 PPM	1.3 PPM
022-09A Classroom 103 Sink Faucet	7/15/16 11:19 AM	7/21/2016	41938	COPPER	0.4 PPM	1.3 PPM
022-10A Classroom 103 Drinking Fountain	7/15/16 11:21 AM	7/21/2016	41939	COPPER	0.4 PPM	1.3 PPM
022-11A Classroom 130 Sink Faucet	7/15/16 11:25 AM	7/21/2016	41940	COPPER	0.4 PPM	1.3 PPM
022-12A Classroom 130 Drinking Fountain	7/15/16 11:28 AM	7/21/2016	41941	COPPER	0.5 PPM	1.3 PPM
022-13A Classroom 104 Sink Faucet	7/15/16 11:32 AM	7/21/2016	41942	COPPER	0.4 PPM	1.3 PPM
022-14A Classroom 104 Drinking Fountain	7/15/16 11:34 AM	7/21/2016	41943	COPPER	0.3 PPM	1.3 PPM
022-15A Classroom 105 Sink Faucet	7/15/16 11:38 AM	7/21/2016	41944	COPPER	0.4 PPM	1.3 PPM
022-16A Classroom 105 Drinking Fountain	7/15/16 11:40 AM	7/21/2016	41945	COPPER	0.5 PPM	1.3 PPM
022-17A Classroom 129 Sink Faucet	7/15/16 11:42 AM	7/21/2016	41946	COPPER	0.4 PPM	1.3 PPM
022-18A Classroom 129 Drinking Fountain	7/15/16 11:44 AM	7/21/2016	41947	COPPER	0.5 PPM	1.3 PPM
022-19A PLC Room Sink Faucet	7/15/16 11:48 AM	7/21/2016	41948	COPPER	0.3 PPM	1.3 PPM
022-20A Classroom 127 Sink Faucet	7/15/16 11:53 AM	7/21/2016	41949	COPPER	0.4 PPM	1.3 PPM
022-21A Classroom 127 Drinking Fountain	7/15/16 11:55 AM	7/21/2016	41950	COPPER	0.5 PPM	1.3 PPM
022-22A Classroom 112 Sink Faucet	7/15/16 11:59 AM	7/21/2016	41951	COPPER	0.4 PPM	1.3 PPM
022-23A Classroom 112 Drinking Fountain	7/15/16 12:01 PM	7/21/2016	41952	COPPER	0.4 PPM	1.3 PPM
022-24A Classroom 126 Sink Faucet	7/15/16 12:12 PM	7/21/2016	41953	COPPER	0.4 PPM	1.3 PPM
022-25A Classroom 126 Drinking Fountain	7/15/16 12:14 PM	7/21/2016	41954	COPPER	0.5 PPM	1.3 PPM
022-26A Hallway Drinking Fountain 1	7/15/16 12:18 PM	7/21/2016	41955	COPPER	0.7 PPM	1.3 PPM
022-27A Hallway Drinking Fountain 2	7/15/16 12:20 PM	7/21/2016	41956	COPPER	0.7 PPM	1.3 PPM
022-28A Classroom 124 Sink Faucet	7/15/16 12:25 PM	7/21/2016	41957	COPPER	0.5 PPM	1.3 PPM
022-29A Classroom 124 Drinking Fountain	7/15/16 12:27 PM	7/21/2016	41958	COPPER	0.6 PPM	1.3 PPM
022-30A Classroom 121 Sink Faucet	7/15/16 12:32 PM	7/21/2016	41959	COPPER	0.5 PPM	1.3 PPM
022-31A Classroom 121 Drinking Fountain	7/15/16 12:34 PM	7/21/2016	41960	COPPER	0.7 PPM	1.3 PPM
022-32A Classroom 222 Sink Faucet	7/15/16 12:39 PM	7/21/2016	41961	COPPER	0.5 PPM	1.3 PPM
022-33A Classroom 222 Drinking Fountain	7/15/16 12:41 PM	7/21/2016	41962	COPPER	0.5 PPM	1.3 PPM
022-34A Classroom 219 Sink Faucet	7/15/16 12:45 PM	7/21/2016	41963	COPPER	0.4 PPM	1.3 PPM
022-35A Calsroom 219 Drinking Fountain	7/15/16 12:47 PM	7/21/2016	41964	COPPER	0.5 PPM	1.3 PPM
022-36A Hallway Drinking Fountain 3	7/15/16 12:50 PM	7/21/2016	41965	COPPER	0.7 PPM	1.3 PPM
022-37A Classroom 224 Sink Faucet	7/15/16 12:54 PM	7/21/2016	41966	COPPER	0.4 PPM	1.3 PPM
022-38A Calsroom 224 Drinking Fountain	7/15/16 12:56 PM	7/21/2016	41967	COPPER	0.3 PPM	1.3 PPM
022-39A Classroom 214 Sink Faucet	7/15/16 12:59 PM	7/21/2016	41968	COPPER	0.4 PPM	1.3 PPM
022-40A Classroom 214 Drinking Fountain	7/15/16 1:01 PM	7/21/2016	41969	COPPER	0.4 PPM	1.3 PPM
022-41A Classroom 225 Sink Faucet	7/15/16 1:05 PM	7/21/2016	41970	COPPER	0.4 PPM	1.3 PPM
022-42A Classroom 225 Drinking Fountain	7/15/16 1:07 PM	7/21/2016	41971	COPPER	0.5 PPM	1.3 PPM
022-43A Classroom 212 Sink Faucet	7/15/16 1:11 PM	7/21/2016	41972	COPPER	0.4 PPM	1.3 PPM
022-44A Classroom 212 Drinking Fountain	7/15/16 1:13 PM	7/21/2016	41973	COPPER	0.3 PPM	1.3 PPM
022-45A DLC Room Sink Faucet	7/15/16 1:16 PM	7/21/2016	41974	COPPER	0.3 PPM	1.3 PPM

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Kalapuya Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result	Action Level
022-46A PLC Room Sink Faucet	7/15/16 1:18 PM	7/21/2016	41975	COPPER	0.4 PPM	1.3 PPM
022-47A Classroom 227 Sink Faucet	7/15/16 1:22 PM	7/21/2016	41976	COPPER	0.4 PPM	1.3 PPM
022-48A Classroom 227 Drinking Fountain	7/15/16 1:24 PM	7/21/2016	41977	COPPER	0.4 PPM	1.3 PPM
022-49A Classroom 207 Sink Faucet	7/15/16 1:27 PM	7/21/2016	41978	COPPER	0.4 PPM	1.3 PPM
022-50A Classroom 207 Drinking Fountain	7/15/16 1:29 PM	7/21/2016	41979	COPPER	0.6 PPM	1.3 PPM
022-51A Classroom 228 Sink Faucet	7/15/16 1:32 PM	7/21/2016	41980	COPPER	0.4 PPM	1.3 PPM
022-52A Classroom 228 Drinking Fountain	7/15/16 1:34 PM	7/21/2016	41981	COPPER	0.4 PPM	1.3 PPM
022-53A Classroom 206 Sink Faucet	7/15/16 1:37 PM	7/21/2016	41982	COPPER	0.4 PPM	1.3 PPM
022-54A Classroom 206 Drinking Fountain	7/15/16 1:39 PM	7/21/2016	41983	COPPER	0.4 PPM	1.3 PPM
022-55A Wet Lab Sink Faucet	7/15/16 1:42 PM	7/21/2016	41984	COPPER	0.5 PPM	1.3 PPM
022-56A Wet Lab Sink Faucet	7/15/16 1:44 PM	7/21/2016	41985	COPPER	0.4 PPM	1.3 PPM
022-57A Wet Lab Sink Faucet	7/15/16 1:46 PM	7/21/2016	41986	COPPER	0.4 PPM	1.3 PPM
022-58A Wet Lab Sink Faucet	7/15/16 1:48 PM	7/21/2016	41987	COPPER	0.6 PPM	1.3 PPM
022-59A Wet Lab Sink Faucet	7/15/16 1:50 PM	7/21/2016	41988	COPPER	0.4 PPM	1.3 PPM
022-60A Wet Lab Sink Faucet	7/15/16 1:52 PM	7/21/2016	41989	COPPER	0.5 PPM	1.3 PPM
022-61A Wet Lab Sink Faucet	7/15/16 1:54 PM	7/21/2016	41990	COPPER	0.4 PPM	1.3 PPM
022-62A LRC Sink Faucet	7/15/16 1:59 PM	7/21/2016	41991	COPPER	0.5 PPM	1.3 PPM
022-63A LRC Drinking Fountain	7/15/16 2:02 PM	7/21/2016	41992	COPPER	0.4 PPM	1.3 PPM
022-64A Classroom 237 Sink Faucet	7/15/16 2:06 PM	7/21/2016	41993	COPPER	0.4 PPM	1.3 PPM
022-65A Classroom 237 Drinking Fountain	7/15/16 2:08 PM	7/21/2016	41994	COPPER	0.5 PPM	1.3 PPM
022-66A Classroom 237 Drinking Fountain	7/15/16 2:13 PM	7/21/2016	41995	COPPER	0.4 PPM	1.3 PPM
022-67A Classroom 238 Drinking Fountain	7/15/16 2:15 PM	7/21/2016	41996	COPPER	0.4 PPM	1.3 PPM
022-68A Room 111 Sink Faucet	7/15/16 12:05 PM	7/21/2016	41997	COPPER	0.5 PPM	1.3 PPM
022-69A Room 111 Drinking Fountain	7/15/16 12:07 PM	7/21/2016	41998	COPPER	0.5 PPM	1.3 PPM
022-70 Nurse Office Ice Maker	7/15/16 10:52 AM	7/22/2016	41999	COPPER	1.0 PPM	1.3 PPM
022-71 Staff Lounge Ice Maker	7/15/16 10:56 AM	7/22/2016	42000	COPPER	1.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**