

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Kalapuya Elementary Schol

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result	Action Level
022-01A Music Room Drinking Fountain 1	7/15/16 11:00 AM	7/21/2016	41930	LEAD	<1 PPB	15 PPB
022-02A Music Room Drinking Fountain 2	7/15/16 11:02 AM	7/21/2016	41931	LEAD	<1 PPB	15 PPB
022-03A Music Room Sink Faucet	7/15/16 11:04 AM	7/21/2016	41932	LEAD	2 PPB	15 PPB
022-04A Kitchen Food Prep Sink Faucet	7/15/16 11:08 AM	7/21/2016	41933	LEAD	<1 PPB	15 PPB
022-05A Gymnasium Drinking Fountain 1	7/15/16 11:12 AM	7/21/2016	41934	LEAD	<1 PPB	15 PPB
022-06A Gymnasium Drinking Fountain 2	7/15/16 11:14 AM	7/21/2016	41935	LEAD	<1 PPB	15 PPB
022-07A Health Room Sink Faucet	7/15/16 10:51 AM	7/21/2016	41936	LEAD	2 PPB	15 PPB
022-08A Faculty Lounge Sink Faucet	7/15/16 10:55 AM	7/21/2016	41937	LEAD	1 PPB	15 PPB
022-09A Classroom 103 Sink Faucet	7/15/16 11:19 AM	7/21/2016	41938	LEAD	3 PPB	15 PPB
022-10A Classroom 103 Drinking Fountain	7/15/16 11:21 AM	7/21/2016	41939	LEAD	<1 PPB	15 PPB
022-11A Classroom 130 Sink Faucet	7/15/16 11:25 AM	7/21/2016	41940	LEAD	2 PPB	15 PPB
022-12A Classroom 130 Drinking Fountain	7/15/16 11:28 AM	7/21/2016	41941	LEAD	<1 PPB	15 PPB
022-13A Classroom 104 Sink Faucet	7/15/16 11:32 AM	7/21/2016	41942	LEAD	2 PPB	15 PPB
022-14A Classroom 104 Drinking Fountain	7/15/16 11:34 AM	7/21/2016	41943	LEAD	2 PPB	15 PPB
022-15A Classroom 105 Sink Faucet	7/15/16 11:38 AM	7/21/2016	41944	LEAD	2 PPB	15 PPB
022-16A Classroom 105 Drinking Fountain	7/15/16 11:40 AM	7/21/2016	41945	LEAD	<1 PPB	15 PPB
022-17A Classroom 129 Sink Faucet	7/15/16 11:42 AM	7/21/2016	41946	LEAD	3 PPB	15 PPB
022-18A Classroom 129 Drinking Fountain	7/15/16 11:44 AM	7/21/2016	41947	LEAD	<1 PPB	15 PPB
022-19A PLC Room Sink Faucet	7/15/16 11:48 AM	7/21/2016	41948	LEAD	1 PPB	15 PPB
022-20A Classroom 127 Sink Faucet	7/15/16 11:53 AM	7/21/2016	41949	LEAD	2 PPB	15 PPB
022-21A Classroom 127 Drinking Fountain	7/15/16 11:55 AM	7/21/2016	41950	LEAD	<1 PPB	15 PPB
022-22A Classroom 112 Sink Faucet	7/15/16 11:59 AM	7/21/2016	41951	LEAD	2 PPB	15 PPB
022-23A Classroom 112 Drinking Fountain	7/15/16 12:01 PM	7/21/2016	41952	LEAD	<1 PPB	15 PPB
022-24A Classroom 126 Sink Faucet	7/15/16 12:12 PM	7/21/2016	41953	LEAD	2 PPB	15 PPB
022-25A Classroom 126 Drinking Fountain	7/15/16 12:14 PM	7/21/2016	41954	LEAD	<1 PPB	15 PPB
022-26A Hallway Drinking Fountain 1	7/15/16 12:18 PM	7/21/2016	41955	LEAD	<1 PPB	15 PPB
022-27A Hallway Drinking Fountain 2	7/15/16 12:20 PM	7/21/2016	41956	LEAD	<1 PPB	15 PPB
022-28A Classroom 124 Sink Faucet	7/15/16 12:25 PM	7/21/2016	41957	LEAD	1 PPB	15 PPB
022-29A Classroom 124 Drinking Fountain	7/15/16 12:27 PM	7/21/2016	41958	LEAD	<1 PPB	15 PPB
022-30A Classroom 121 Sink Faucet	7/15/16 12:32 PM	7/21/2016	41959	LEAD	1 PPB	15 PPB
022-31A Classroom 121 Drinking Fountain	7/15/16 12:34 PM	7/21/2016	41960	LEAD	<1 PPB	15 PPB
022-32A Classroom 222 Sink Faucet	7/15/16 12:39 PM	7/21/2016	41961	LEAD	2 PPB	15 PPB
022-33A Classroom 222 Drinking Fountain	7/15/16 12:41 PM	7/21/2016	41962	LEAD	<1 PPB	15 PPB
022-34A Classroom 219 Sink Faucet	7/15/16 12:45 PM	7/21/2016	41963	LEAD	1 PPB	15 PPB
022-35A Calsroom 219 Drinking Fountain	7/15/16 12:47 PM	7/21/2016	41964	LEAD	<1 PPB	15 PPB
022-36A Hallway Drinking Fountain 3	7/15/16 12:50 PM	7/21/2016	41965	LEAD	<1 PPB	15 PPB
022-37A Classroom 224 Sink Faucet	7/15/16 12:54 PM	7/21/2016	41966	LEAD	1 PPB	15 PPB
022-38A Calsroom 224 Drinking Fountain	7/15/16 12:56 PM	7/21/2016	41967	LEAD	<1 PPB	15 PPB
022-39A Classroom 214 Sink Faucet	7/15/16 12:59 PM	7/21/2016	41968	LEAD	4 PPB	15 PPB
022-40A Classroom 214 Drinking Fountain	7/15/16 1:01 PM	7/21/2016	41969	LEAD	<1 PPB	15 PPB
022-41A Classroom 225 Sink Faucet	7/15/16 1:05 PM	7/21/2016	41970	LEAD	3 PPB	15 PPB
022-42A Classroom 225 Drinking Fountain	7/15/16 1:07 PM	7/21/2016	41971	LEAD	<1 PPB	15 PPB
022-43A Classroom 212 Sink Faucet	7/15/16 1:11 PM	7/21/2016	41972	LEAD	<1 PPB	15 PPB
022-44A Classroom 212 Drinking Fountain	7/15/16 1:13 PM	7/21/2016	41973	LEAD	2 PPB	15 PPB
022-45A DLC Room Sink Faucet	7/15/16 1:16 PM	7/21/2016	41974	LEAD	2 PPB	15 PPB
022-46A PLC Room Sink Faucet	7/15/16 1:18 PM	7/21/2016	41975	LEAD	<1 PPB	15 PPB
022-47A Classroom 227 Sink Faucet	7/15/16 1:22 PM	7/21/2016	41976	LEAD	1 PPB	15 PPB
022-48A Classroom 227 Drinking Fountain	7/15/16 1:24 PM	7/21/2016	41977	LEAD	<1 PPB	15 PPB
022-49A Classroom 207 Sink Faucet	7/15/16 1:27 PM	7/21/2016	41978	LEAD	2 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Kalapuya Elementary Schol

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result	Action Level
022-50A Classroom 207 Drinking Fountain	7/15/16 1:29 PM	7/21/2016	41979	LEAD	<1 PPB	15 PPB
022-51A Classroom 228 Sink Faucet	7/15/16 1:32 PM	7/21/2016	41980	LEAD	3 PPB	15 PPB
022-52A Classroom 228 Drinking Fountain	7/15/16 1:34 PM	7/21/2016	41981	LEAD	<1 PPB	15 PPB
022-53A Classroom 206 Sink Faucet	7/15/16 1:37 PM	7/21/2016	41982	LEAD	2 PPB	15 PPB
022-54A Classroom 206 Drinking Fountain	7/15/16 1:39 PM	7/21/2016	41983	LEAD	<1 PPB	15 PPB
022-55A Wet Lab Sink Faucet	7/15/16 1:42 PM	7/21/2016	41984	LEAD	2 PPB	15 PPB
022-56A Wet Lab Sink Faucet	7/15/16 1:44 PM	7/21/2016	41985	LEAD	3 PPB	15 PPB
022-57A Wet Lab Sink Faucet	7/15/16 1:46 PM	7/21/2016	41986	LEAD	<1 PPB	15 PPB
022-58A Wet Lab Sink Faucet	7/15/16 1:48 PM	7/21/2016	41987	LEAD	<1 PPB	15 PPB
022-59A Wet Lab Sink Faucet	7/15/16 1:50 PM	7/21/2016	41988	LEAD	3 PPB	15 PPB
022-60A Wet Lab Sink Faucet	7/15/16 1:52 PM	7/21/2016	41989	LEAD	<1 PPB	15 PPB
022-61A Wet Lab Sink Faucet	7/15/16 1:54 PM	7/21/2016	41990	LEAD	<1 PPB	15 PPB
022-62A LRC Sink Fountain	7/15/16 1:59 PM	7/21/2016	41991	LEAD	4 PPB	15 PPB
022-63A LRC Drinking Fountain	7/15/16 2:02 PM	7/21/2016	41992	LEAD	<1 PPB	15 PPB
022-64A Classroom 237 Sink Faucet	7/15/16 2:06 PM	7/21/2016	41993	LEAD	2 PPB	15 PPB
022-65A Classroom 237 Drinking Fountain	7/15/16 2:08 PM	7/21/2016	41994	LEAD	1 PPB	15 PPB
022-66A Classroom 237 Drinking Fountain	7/15/16 2:13 PM	7/21/2016	41995	LEAD	<1 PPB	15 PPB
022-67A Classroom 238 Drinking Fountain	7/15/16 2:15 PM	7/21/2016	41996	LEAD	1 PPB	15 PPB
022-68A Room 111 Sink Faucet	7/15/16 12:05 PM	7/21/2016	41997	LEAD	2 PPB	15 PPB
022-69A Room 111 Drinking Fountain	7/15/16 12:07 PM	7/21/2016	41998	LEAD	<1 PPB	15 PPB
022-70 Nurse Office Ice Maker	7/15/16 10:52 AM	7/21/2016	41999	LEAD	10 PPB	15 PPB
022-71 Staff Lounge Ice Maker	7/15/16 10:56 AM	7/21/2016	42000	LEAD	11 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level