

Salem Keizer School District
Copper Water Sampling Results
A (First Draw) Sample Data
Keizer Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
040-01A Hallway Drinking Fountain 1	7/21/16 9:47	7/28/16 12:14	607224201	COPPER	0.0 PPM	1.3 PPM
040-02A Classroom 1 Sink Faucet	7/21/16 9:50	7/28/16 12:15	607224202	COPPER	0.0 PPM	1.3 PPM
040-04A Classroom 2 Sink Faucet	7/21/16 9:55	7/28/16 12:15	607224204	COPPER	0.0 PPM	1.3 PPM
040-05A Classroom 2 Drinking Fountain	7/21/16 9:57	7/28/16 12:15	607224205	COPPER	0.1 PPM	1.3 PPM
040-06A Classroom 4 Sink Faucet	7/21/16 10:00	7/28/16 12:15	607224206	COPPER	0.1 PPM	1.3 PPM
040-07A Classroom 4 Sink Faucet	7/21/16 10:02	7/28/16 12:15	607224207	COPPER	0.1 PPM	1.3 PPM
040-08A Classroom 4 Drinking Fountain	7/21/16 10:04	7/28/16 12:16	607224208	COPPER	0.1 PPM	1.3 PPM
040-09A Classroom 3 Sink Faucet	7/21/16 10:07	7/28/16 12:16	607224209	COPPER	0.1 PPM	1.3 PPM
040-10A Classroom 3 Drinking Fountain	7/21/16 10:09	7/28/16 12:16	607224210	COPPER	0.1 PPM	1.3 PPM
040-11A Hallway Drinking Fountain 2	7/21/16 10:11	7/28/16 12:16	607224211	COPPER	0.0 PPM	1.3 PPM
040-12A Nurse/Health Sink Faucet	7/21/16 10:15	7/28/16 12:17	607224212	COPPER	0.0 PPM	1.3 PPM
040-13A Nurse/Health Drinking Fountain	7/21/16 10:17	7/28/16 12:17	607224213	COPPER	0.0 PPM	1.3 PPM
040-14A Staff Lounge Sink Faucet	7/21/16 10:20	8/1/16 15:34	607224214	COPPER	< 0.005 PPM	1.3 PPM
040-15A Staff Lounge Refrigerator Faucet	7/21/16 10:22	7/28/16 12:17	607224215	COPPER	0.0 PPM	1.3 PPM
040-16A Classroom 23 Sink Faucet	7/21/16 10:27	7/28/16 12:17	607224216	COPPER	0.1 PPM	1.3 PPM
040-17A Classroom 23 Drinking Fountain	7/21/16 10:29	7/28/16 12:17	607224217	COPPER	0.1 PPM	1.3 PPM
040-18A Classroom 24 Sink Faucet	7/21/16 10:32	7/28/16 12:53	607224218	COPPER	0.1 PPM	1.3 PPM
040-19A Classroom 24 Drinking Fountain	7/21/16 10:34	7/28/16 12:53	607224219	COPPER	0.0 PPM	1.3 PPM
040-20A Classroom 25 Sink Faucet	7/21/16 10:37	7/28/16 12:53	607224220	COPPER	0.1 PPM	1.3 PPM
040-21A Classroom 25 Drinking Fountain	7/21/16 10:39	7/28/16 12:53	607224221	COPPER	0.0 PPM	1.3 PPM
040-22A Classroom 26 Sink Faucet	7/21/16 10:42	7/28/16 12:53	607224222	COPPER	0.0 PPM	1.3 PPM
040-23A Classroom 26 Drinking Fountain	7/21/16 10:44	7/28/16 12:53	607224223	COPPER	0.1 PPM	1.3 PPM
040-24A Classroom 27 Sink Faucet	7/21/16 10:47	7/28/16 12:53	607224224	COPPER	0.0 PPM	1.3 PPM
040-25A Classroom 27 Drinking Fountain	7/21/16 10:49	7/28/16 12:53	607224225	COPPER	0.0 PPM	1.3 PPM
040-26A Classroom 28 Sink Faucet	7/21/16 10:52	7/28/16 12:53	607224226	COPPER	0.0 PPM	1.3 PPM
040-27A Classroom 28 Drinking Fountain	7/21/16 10:54	7/28/16 12:53	607224227	COPPER	0.0 PPM	1.3 PPM
040-28A Classroom 29 Sink Faucet	7/21/16 10:57	7/28/16 12:55	607224228	COPPER	0.0 PPM	1.3 PPM
040-29A Classroom 29 Drinking Fountain	7/21/16 10:59	7/28/16 12:55	607224229	COPPER	0.0 PPM	1.3 PPM
040-30A Classroom 30 Sink Faucet	7/21/16 11:02	7/28/16 12:55	607224230	COPPER	0.0 PPM	1.3 PPM
040-31A Classroom 30 Drinking Fountain	7/21/16 11:04	7/28/16 12:55	607224231	COPPER	0.0 PPM	1.3 PPM
040-32A Kitchen Food Prep Sink Faucet	7/21/16 11:07	7/28/16 12:55	607224232	COPPER	0.0 PPM	1.3 PPM
040-33A Computer Lab Sink Faucet 1	7/21/16 11:09	7/28/16 12:55	607224233	COPPER	0.1 PPM	1.3 PPM
040-34A Computer Lab Drinking Fountain 1	7/21/16 11:11	7/28/16 12:55	607224234	COPPER	0.1 PPM	1.3 PPM
040-35A Computer Lab Sink Faucet 2	7/21/16 11:12	7/28/16 12:55	607224235	COPPER	0.3 PPM	1.3 PPM
040-36A Computer Lab Drinking Fountain 2	7/21/16 11:14	7/28/16 12:55	607224236	COPPER	0.5 PPM	1.3 PPM
040-37A Classroom 14 Sink Faucet	7/21/16 11:18	7/28/16 12:55	607224237	COPPER	0.1 PPM	1.3 PPM
040-38A Classroom 14 Drinking Fountain	7/21/16 11:20	7/28/16 12:58	607224238	COPPER	0.1 PPM	1.3 PPM
040-39A Classroom 15 Sink Faucet	7/21/16 11:24	7/28/16 12:58	607224239	COPPER	0.1 PPM	1.3 PPM
040-40A Classroom 15 Drinking Fountain	7/21/16 11:26	7/28/16 12:58	607224240	COPPER	0.1 PPM	1.3 PPM
040-41A Classroom 16 Sink Faucet	7/21/16 11:29	7/28/16 12:58	607224241	COPPER	0.1 PPM	1.3 PPM
040-42A Classroom 16 Drinking Fountain	7/21/16 11:31	7/28/16 12:58	607224242	COPPER	0.1 PPM	1.3 PPM
040-43A Classroom 17 Sink Faucet	7/21/16 11:35	7/28/16 12:58	607224243	COPPER	0.1 PPM	1.3 PPM
040-44A Classroom 17 Drinking Fountain	7/21/16 11:37	7/28/16 12:58	607224244	COPPER	0.1 PPM	1.3 PPM
040-45A Classroom 18 Sink Faucet	7/21/16 11:39	7/28/16 12:58	607224245	COPPER	0.1 PPM	1.3 PPM
040-46A Classroom 18 Drinking Fountain	7/21/16 11:41	7/28/16 12:58	607224246	COPPER	0.0 PPM	1.3 PPM
040-47A Classroom 19 Sink Faucet	7/21/16 11:45	7/28/16 12:58	607224247	COPPER	0.0 PPM	1.3 PPM
040-48A Classroom 19 Drinking Fountain	7/21/16 11:47	7/28/16 13:06	607224248	COPPER	0.1 PPM	1.3 PPM
040-49A Classroom 20 Sink Faucet	7/21/16 11:51	7/28/16 13:06	607224249	COPPER	0.0 PPM	1.3 PPM
040-50A Classroom 20 Drinking Fountain	7/21/16 11:53	7/28/16 13:06	607224250	COPPER	0.0 PPM	1.3 PPM
040-51A Classroom 21 Sink Faucet	7/21/16 11:57	7/28/16 13:06	607224251	COPPER	0.0 PPM	1.3 PPM
040-52A Classroom 21 Drinking Fountain	7/21/16 11:59	7/28/16 13:06	607224252	COPPER	0.0 PPM	1.3 PPM
040-53A Classroom 5 Sink Faucet	7/21/16 12:02	7/28/16 13:06	607224253	COPPER	0.0 PPM	1.3 PPM

Salem Keizer School District
Copper Water Sampling Results
A (First Draw) Sample Data
Keizer Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
040-54A Classroom 5 Drinking Fountain	7/21/16 12:04	7/28/16 13:06	607224254	COPPER	0.1 PPM	1.3 PPM
040-55A Classroom 6 Sink Faucet	7/21/16 12:07	7/28/16 13:06	607224255	COPPER	0.1 PPM	1.3 PPM
040-56A Classroom 6 Drinking Fountain	7/21/16 12:09	7/28/16 13:06	607224256	COPPER	0.1 PPM	1.3 PPM
040-57A Classroom 7 Sink Faucet	7/21/16 12:13	7/28/16 13:06	607224257	COPPER	0.1 PPM	1.3 PPM
040-58A Classroom 7 Drinking Fountain	7/21/16 12:15	7/28/16 13:07	607224258	COPPER	0.1 PPM	1.3 PPM
040-59A Classroom 8 Sink Faucet	7/21/16 12:18	7/28/16 13:07	607224259	COPPER	0.0 PPM	1.3 PPM
040-60A Classroom 8 Drinking Fountain	7/21/16 12:20	7/28/16 13:08	607224260	COPPER	0.1 PPM	1.3 PPM
040-61A Classroom 9 Sink Faucet	7/21/16 12:23	7/28/16 13:08	607224261	COPPER	0.0 PPM	1.3 PPM
040-62A Classroom 9 Drinking Fountain	7/21/16 12:25	7/28/16 13:08	607224262	COPPER	0.1 PPM	1.3 PPM
040-63A Classroom 10 Sink Faucet	7/21/16 12:29	7/28/16 13:08	607224263	COPPER	0.0 PPM	1.3 PPM
040-64A Classroom 10 Drinking Fountain	7/21/16 12:31	7/28/16 13:08	607224264	COPPER	0.0 PPM	1.3 PPM
040-65A Classroom 11 Sink Faucet	7/21/16 12:35	7/28/16 13:08	607224265	COPPER	0.1 PPM	1.3 PPM
040-66A Classroom 11 Drinking Fountain	7/21/16 12:37	7/28/16 13:08	607224266	COPPER	0.0 PPM	1.3 PPM
040-67A Classroom 12 Sink Faucet	7/21/16 12:40	7/28/16 13:08	607224267	COPPER	0.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
Flushed (B) Sample Data
Keizer Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Tested For	Results	Action Limit
040-06B Classroom 4 Sink Faucet	7/21/16 10:01	8/18/16 10:51	608101801	COPPER	0.1 PPM	1.3 PPM
040-35B Computer Lab Sink Faucet 2	7/21/16 11:13	8/18/16 10:54	608101802	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS)

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Keizer Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
040-68A Classroom 12 Drinking Fountain	8/4/2017 8:18	8/7/2017	43364	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (C) Sample Data
Keizer Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
040-06C Classroom 4 Sink Faucet	9/30/2016 5:30	10/3/2016	59704	COPPER	0.1 PPM	1.3 PPM
040-35C Computer Lab Sink Faucet	9/30/2016 5:23	10/3/2016	59705	COPPER	0.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level