

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Lamb Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|--|-------------------|---------------|--------------|------------|---------|--------------|
| 65-01A Gymnasium Drinking Fountain | 7/26/2016 9:00 | 8/5/2016 | 44339 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-02A Gymnasium Bottle Refill Station | 7/26/2016 9:02 | 8/5/2016 | 44340 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-03A Kitchen Sink Faucet | 7/26/2016 9:05 | 8/5/2016 | 44341 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-04A Cafeteria Closet Sink Faucet | 7/26/2016 9:07 | 8/5/2016 | 44342 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-05A Gymnasium Hall Restroom Drinking Fountain (Left) | 7/26/2016 9:09 | 8/5/2016 | 44343 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-06A Gymnasium Hall Restroom Drinking Fountain (Right) | 7/26/2016 9:11 | 8/5/2016 | 44344 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-07A Music Room Sink Faucet | 7/26/2016 9:19 | 8/5/2016 | 44345 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-08A Music Room Drinking Fountain | 7/26/2016 9:16 | 8/5/2016 | 44346 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-09A Nurse Room Sink Faucet | 7/26/2016 9:19 | 8/5/2016 | 44347 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-10A Nurse Room Drinking Fountain | 7/26/2016 9:21 | 8/5/2016 | 44348 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-11A Office Work Room Sink Faucet | 7/26/2016 9:23 | 8/5/2016 | 44349 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-12A Office Work Room Drinking Fountain | 7/26/2016 9:25 | 8/5/2016 | 44350 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-13A Staff Lounge Sink Faucet | 7/26/2016 9:27 | 8/5/2016 | 44351 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-14A Room C-1 Sink Faucet | 7/26/2016 9:30 | 8/5/2016 | 44352 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-15A C-1 Drinking Fountain | 7/26/2016 9:32 | 8/5/2016 | 44353 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-16A C-2 Sink Faucet | 7/26/2016 9:34 | 8/5/2016 | 44354 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-17A C-2 Drinking Fountain | 7/26/2016 9:36 | 8/5/2016 | 44355 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-18A C-3 Sink Faucet | 7/26/2016 9:38 | 8/5/2016 | 44356 | COPPER | 0.2 PPM | 1.3 PPM |
| 65-19A C-3 Drinking Fountain | 7/26/2016 9:40 | 8/5/2016 | 44357 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-20A C-4 Sink Faucet | 7/26/2016 9:42 | 8/5/2016 | 44358 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-21A C-4 Drinking Fountain | 7/26/2016 9:44 | 8/5/2016 | 44359 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-22A C-5 Sink Faucet | 7/26/2016 9:46 | 8/5/2016 | 44360 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-23A C-5 Drinking Fountain | 7/26/2016 9:48 | 8/5/2016 | 44361 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-24A C-6 Sink Faucet | 7/26/2016 9:50 | 8/5/2016 | 44362 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-25A C-6 Drinking Fountain | 7/26/2016 9:52 | 8/5/2016 | 44363 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-26A Library Sink Faucet | 7/26/2016 9:54 | 8/5/2016 | 44364 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-27A D-1 Sink Faucet | 7/26/2016 9:57 | 8/5/2016 | 44365 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-28A D-1 Drinking Fountain | 7/26/2016 9:59 | 8/5/2016 | 44366 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-29A D-2 Sink Faucet | 7/26/2016 10:01 | 8/5/2016 | 44367 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-30A D-2 Drinking Fountain | 7/26/2016 10:03 | 8/5/2016 | 44368 | COPPER | 0.1 PPM | 1.3 PPM |

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Lamb Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|--------------------------------------|-------------------|---------------|--------------|------------|---------|--------------|
| 65-31A D-3 Sink Faucet | 7/26/2016 10:05 | 8/5/2016 | 44369 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-32A D-3 Drinking Fountain | 7/26/2016 10:07 | 8/5/2016 | 44370 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-33A D-4 Sink Faucet | 7/26/2016 10:10 | 8/5/2016 | 44371 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-34A D-4 Drinking Fountain | 7/26/2016 10:11 | 8/5/2016 | 44372 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-35A D-5 Sink Faucet | 7/26/2016 10:13 | 8/5/2016 | 44373 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-36A D-5 Drinking Fountain | 7/26/2016 10:15 | 8/5/2016 | 44374 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-37A D-6 Sink Faucet | 7/26/2016 10:17 | 8/5/2016 | 44375 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-38A D-6 Drinking Fountain | 7/26/2016 10:19 | 8/5/2016 | 44376 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-39A Room E-7 Sink Faucet | 7/26/2016 10:21 | 8/5/2016 | 44377 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-40A Room E-7 Drinking Fountain | 7/26/2016 10:23 | 8/5/2016 | 44378 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-41A E-6 Sink Faucet | 7/26/2016 10:29 | 8/5/2016 | 44379 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-42A E-6 Drinking Fountain | 7/26/2016 10:31 | 8/5/2016 | 44380 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-43A E-5 Sink Faucet | 7/26/2016 10:33 | 8/5/2016 | 44381 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-44A E-5 Drinking Fountain | 7/26/2016 10:35 | 8/5/2016 | 44382 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-45A E-4 Sink Faucet | 7/26/2016 10:37 | 8/5/2016 | 44383 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-46A E-4 Drinking Fountain | 7/26/2016 10:39 | 8/5/2016 | 44384 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-47A E-3 Sink Faucet | 7/26/2016 10:41 | 8/5/2016 | 44385 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-48A E-3 Drinking Fountain | 7/26/2016 10:43 | 8/5/2016 | 44386 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-49A E-2 Sink Faucet | 7/26/2016 10:45 | 8/5/2016 | 44387 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-50A E-2 Drinking Fountain | 7/26/2016 10:47 | 8/5/2016 | 44388 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-51A E-1 Sink Faucet | 7/26/2016 10:49 | 8/5/2016 | 44389 | COPPER | 0.1 PPM | 1.3 PPM |
| 65-52A E-1 Drinking Fountain | 7/26/2016 10:51 | 8/5/2016 | 44390 | COPPER | 0.1 PPM | 1.3 PPM |

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level