

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Lamb Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
65-01A Gymnasium Drinking Fountain	7/26/2016 9:00	8/5/2016	44339	LEAD	<1 PPB	15 PPB
65-02A Gymnasium Bottle Refill Station	7/26/2016 9:02	8/5/2016	44340	LEAD	<1 PPB	15 PPB
65-03A Kitchen Sink Faucet	7/26/2016 9:05	8/5/2016	44341	LEAD	2 PPB	15 PPB
65-04A Cafeteria Closet Sink Faucet	7/26/2016 9:07	8/5/2016	44342	LEAD	2 PPB	15 PPB
65-05A Gymnasium Hall Restroom Drinking Fountain (Left)	7/26/2016 9:09	8/5/2016	44343	LEAD	<1 PPB	15 PPB
65-06A Gymnasium Hall Restroom Drinking Fountain (Right)	7/26/2016 9:11	8/5/2016	44344	LEAD	<1 PPB	15 PPB
65-07A Music Room Sink Faucet	7/26/2016 9:19	8/5/2016	44345	LEAD	2 PPB	15 PPB
65-08A Music Room Drinking Fountain	7/26/2016 9:16	8/5/2016	44346	LEAD	2 PPB	15 PPB
65-09A Nurse Room Sink Faucet	7/26/2016 9:19	8/5/2016	44347	LEAD	<1 PPB	15 PPB
65-10A Nurse Room Drinking Fountain	7/26/2016 9:21	8/5/2016	44348	LEAD	2 PPB	15 PPB
65-11A Office Work Room Sink Faucet	7/26/2016 9:23	8/5/2016	44349	LEAD	3 PPB	15 PPB
65-12A Office Work Room Drinking Fountain	7/26/2016 9:25	8/5/2016	44350	LEAD	7 PPB	15 PPB
65-13A Staff Lounge Sink Faucet	7/26/2016 9:27	8/5/2016	44351	LEAD	<1 PPB	15 PPB
65-14A Room C-1 Sink Faucet	7/26/2016 9:30	8/5/2016	44352	LEAD	1 PPB	15 PPB
65-15A C-1 Drinking Fountain	7/26/2016 9:32	8/5/2016	44353	LEAD	2 PPB	15 PPB
65-16A C-2 Sink Faucet	7/26/2016 9:34	8/5/2016	44354	LEAD	1 PPB	15 PPB
65-17A C-2 Drinking Fountain	7/26/2016 9:36	8/5/2016	44355	LEAD	2 PPB	15 PPB
65-18A C-3 Sink Faucet	7/26/2016 9:38	8/5/2016	44356	LEAD	2 PPB	15 PPB
65-19A C-3 Drinking Fountain	7/26/2016 9:40	8/5/2016	44357	LEAD	2 PPB	15 PPB
65-20A C-4 Sink Faucet	7/26/2016 9:42	8/5/2016	44358	LEAD	<1 PPB	15 PPB
65-21A C-4 Drinking Fountain	7/26/2016 9:44	8/5/2016	44359	LEAD	1 PPB	15 PPB
65-22A C-5 Sink Faucet	7/26/2016 9:46	8/5/2016	44360	LEAD	1 PPB	15 PPB
65-23A C-5 Drinking Fountain	7/26/2016 9:48	8/5/2016	44361	LEAD	<1 PPB	15 PPB
65-24A C-6 Sink Faucet	7/26/2016 9:50	8/5/2016	44362	LEAD	1 PPB	15 PPB
65-25A C-6 Drinking Fountain	7/26/2016 9:52	8/5/2016	44363	LEAD	2 PPB	15 PPB
65-26A Library Sink Faucet	7/26/2016 9:54	8/5/2016	44364	LEAD	1 PPB	15 PPB
65-27A D-1 Sink Faucet	7/26/2016 9:57	8/5/2016	44365	LEAD	<1 PPB	15 PPB
65-28A D-1 Drinking Fountain	7/26/2016 9:59	8/5/2016	44366	LEAD	1 PPB	15 PPB
65-29A D-2 Sink Faucet	7/26/2016 10:01	8/5/2016	44367	LEAD	1 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Lamb Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
65-30A D-2 Drinking Fountain	7/26/2016 10:03	8/5/2016	44368	LEAD	<1 PPB	15 PPB
65-31A D-3 Sink Faucet	7/26/2016 10:05	8/5/2016	44369	LEAD	1 PPB	15 PPB
65-32A D-3 Drinking Fountain	7/26/2016 10:07	8/5/2016	44370	LEAD	<1 PPB	15 PPB
65-33A D-4 Sink Faucet	7/26/2016 10:10	8/5/2016	44371	LEAD	1 PPB	15 PPB
65-34A D-4 Drinking Fountain	7/26/2016 10:11	8/5/2016	44372	LEAD	2 PPB	15 PPB
65-35A D-5 Sink Faucet	7/26/2016 10:13	8/5/2016	44373	LEAD	1 PPB	15 PPB
65-36A D-5 Drinking Fountain	7/26/2016 10:15	8/5/2016	44374	LEAD	1 PPB	15 PPB
65-37A D-6 Sink Faucet	7/26/2016 10:17	8/5/2016	44375	LEAD	<1 PPB	15 PPB
65-38A D-6 Drinking Fountain	7/26/2016 10:19	8/5/2016	44376	LEAD	2 PPB	15 PPB
65-39A Room E-7 Sink Faucet	7/26/2016 10:21	8/5/2016	44377	LEAD	1 PPB	15 PPB
65-40A Room E-7 Drinking Fountain	7/26/2016 10:23	8/5/2016	44378	LEAD	2 PPB	15 PPB
65-41A E-6 Sink Faucet	7/26/2016 10:29	8/5/2016	44379	LEAD	<1 PPB	15 PPB
65-42A E-6 Drinking Fountain	7/26/2016 10:31	8/5/2016	44380	LEAD	2 PPB	15 PPB
65-43A E-5 Sink Faucet	7/26/2016 10:33	8/5/2016	44381	LEAD	<1 PPB	15 PPB
65-44A E-5 Drinking Fountain	7/26/2016 10:35	8/5/2016	44382	LEAD	1 PPB	15 PPB
65-45A E-4 Sink Faucet	7/26/2016 10:37	8/5/2016	44383	LEAD	1 PPB	15 PPB
65-46A E-4 Drinking Fountain	7/26/2016 10:39	8/5/2016	44384	LEAD	2 PPB	15 PPB
65-47A E-3 Sink Faucet	7/26/2016 10:41	8/5/2016	44385	LEAD	<1 PPB	15 PPB
65-48A E-3 Drinking Fountain	7/26/2016 10:43	8/5/2016	44386	LEAD	2 PPB	15 PPB
65-49A E-2 Sink Faucet	7/26/2016 10:45	8/5/2016	44387	LEAD	<1 PPB	15 PPB
65-50A E-2 Drinking Fountain	7/26/2016 10:47	8/5/2016	44388	LEAD	2 PPB	15 PPB
65-51A E-1 Sink Faucet	7/26/2016 10:49	8/5/2016	44389	LEAD	<1 PPB	15 PPB
65-52A E-1 Drinking Fountain	7/26/2016 10:51	8/5/2016	44390	LEAD	3 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level