

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Lee Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Tested For	Results	Action Limit
026-01A Gymnasium Drinking Fountain	8/6/16 10:04	8/15/16 9:35	608085001	COPPER	0.6 PPM	15 PPM
026-02A Kitchen Food Prep Sink Faucet	8/6/16 10:07	8/15/16 9:38	608085002	COPPER	0.3 PPM	15 PPM
026-03A Cafeteria Sink Faucet (Closet)	8/6/16 10:09	8/15/16 9:38	608085003	COPPER	0.3 PPM	15 PPM
026-04A Bathroom Drinking Fountain	8/6/16 10:13	8/15/16 9:38	608085004	COPPER	0.4 PPM	15 PPM
026-05A Bathroom Drinking Fountain	8/6/16 10:13	8/15/16 9:38	608085005	COPPER	0.3 PPM	15 PPM
026-06A Music Room Sink Faucet	8/6/16 10:16	8/15/16 9:38	608085006	COPPER	0.3 PPM	15 PPM
026-07A Music Room Drinking Fountain	8/6/16 10:16	8/15/16 9:38	608085007	COPPER	0.3 PPM	15 PPM
026-08A Health/Nurse Sink Faucet	8/6/16 10:20	8/15/16 9:38	608085008	COPPER	0.4 PPM	15 PPM
026-09A Health/Nurse Drinking Fountain	8/6/16 10:20	8/15/16 9:38	608085009	COPPER	0.5 PPM	15 PPM
026-10A Workroom Sink Faucet	8/6/16 10:26	8/15/16 9:38	608085010	COPPER	0.4 PPM	15 PPM
026-11A Workroom Drinking Fountain	8/6/16 10:26	8/15/16 9:38	608085011	COPPER	0.3 PPM	15 PPM
026-12A Staff Lounge Sink Faucet	8/6/16 10:29	8/15/16 9:38	608085012	COPPER	0.4 PPM	15 PPM
026-13A Classroom A-7 Drinking Fountain	8/6/16 10:33	8/15/16 9:38	608085013	COPPER	0.5 PPM	15 PPM
026-14A Classroom A-7 Sink Faucet	8/6/16 10:33	8/15/16 9:38	608085014	COPPER	0.5 PPM	15 PPM
026-15A Classroom A-6 Drinking Fountain	8/6/16 10:42	8/15/16 9:38	608085015	COPPER	0.5 PPM	15 PPM
026-16A Classroom A-6 Sink Faucet	8/6/16 10:42	8/15/16 9:38	608085016	COPPER	0.4 PPM	15 PPM
026-17A Classroom A-5 Drinking Fountain	8/6/16 10:44	8/15/16 9:38	608085017	COPPER	0.5 PPM	15 PPM
026-18A Classroom A-5 Sink Faucet	8/6/16 10:44	8/15/16 9:38	608085018	COPPER	0.4 PPM	15 PPM
026-19A Classroom A-4 Drinking Fountain	8/6/16 10:46	8/15/16 9:38	608085019	COPPER	0.5 PPM	15 PPM
026-20A Classroom A-4 Sink Faucet	8/6/16 10:46	8/15/16 9:38	608085020	COPPER	0.4 PPM	15 PPM
026-21A Classroom A-3 Drinking Fountain	8/6/16 10:48	8/15/16 9:38	608085021	COPPER	0.5 PPM	15 PPM
026-22A Classroom A-3 Sink Faucet	8/6/16 10:48	8/15/16 9:43	608085022	COPPER	0.4 PPM	15 PPM
026-23A Classroom A-2 Drinking Fountain	8/6/16 10:51	8/15/16 9:48	608085023	COPPER	0.4 PPM	15 PPM
026-24A Classroom A-2 Sink Faucet	8/6/16 10:51	8/15/16 9:48	608085024	COPPER	0.5 PPM	15 PPM
026-25A Classroom A-1 Drinking Fountain	8/6/16 10:53	8/15/16 9:48	608085025	COPPER	0.4 PPM	15 PPM
026-26A Classroom A-1 Sink Faucet	8/6/16 10:53	8/15/16 9:48	608085026	COPPER	0.4 PPM	15 PPM
026-27A Classroom B-8 Drinking Fountain	8/6/16 11:00	8/15/16 9:48	608085027	COPPER	0.5 PPM	15 PPM
026-28A Classroom B-8 Sink Faucet	8/6/16 11:00	8/15/16 9:48	608085028	COPPER	0.4 PPM	15 PPM
026-29A Classroom B-9 Drinking Fountain	8/6/16 11:02	8/15/16 9:48	608085029	COPPER	0.4 PPM	15 PPM
026-30A Classroom B-9 Sink Faucet	8/6/16 11:02	8/15/16 9:48	608085030	COPPER	0.3 PPM	15 PPM
026-31A Classroom B-10 Drinking Fountain	8/6/16 11:04	8/15/16 9:48	608085031	COPPER	0.4 PPM	15 PPM
026-32A Classroom B-10 Sink Faucet	8/6/16 11:04	8/15/16 9:49	608085032	COPPER	0.3 PPM	15 PPM
026-33A Classroom B-11 Drinking Fountain	8/6/16 11:06	8/15/16 9:49	608085033	COPPER	0.5 PPM	15 PPM
026-34A Classroom B-11 Sink Faucet	8/6/16 11:06	8/15/16 9:49	608085034	COPPER	0.4 PPM	15 PPM
026-35A Classroom B-12 Drinking Fountain	8/6/16 11:08	8/15/16 9:49	608085035	COPPER	0.4 PPM	15 PPM
026-36A Classroom B-12 Sink Faucet	8/6/16 11:08	8/15/16 9:49	608085036	COPPER	0.4 PPM	15 PPM
026-37A Classroom B-13 Drinking Fountain	8/6/16 11:10	8/15/16 9:49	608085037	COPPER	0.4 PPM	15 PPM
026-38A Classroom B-13 Sink Faucet	8/6/16 11:10	8/15/16 9:49	608085038	COPPER	0.4 PPM	15 PPM
026-39A Classroom C-14 Drinking Fountain	8/6/16 11:16	8/15/16 9:50	608085039	COPPER	0.3 PPM	15 PPM
026-40A Classroom C-14 Sink Faucet	8/6/16 11:16	8/15/16 9:50	608085040	COPPER	0.4 PPM	15 PPM
026-41A Classroom C-15 Drinking Fountain	8/6/16 11:18	8/15/16 9:50	608085041	COPPER	0.5 PPM	15 PPM
026-42A Classroom C-15 Sink Faucet	8/6/16 11:18	8/15/16 9:50	608085042	COPPER	0.4 PPM	15 PPM
026-43A Classroom C-16 Drinking Fountain	8/6/16 11:20	8/15/16 9:50	608085043	COPPER	0.4 PPM	15 PPM
026-44A Classroom C-16 Sink Faucet	8/6/16 11:20	8/15/16 9:50	608085044	COPPER	0.4 PPM	15 PPM
026-45A Classroom C-17 Drinking Fountain	8/6/16 11:22	8/15/16 9:50	608085045	COPPER	0.4 PPM	15 PPM
026-46A Classroom C-17 Sink Faucet	8/6/16 11:22	8/15/16 9:50	608085046	COPPER	0.4 PPM	15 PPM
026-47A Classroom C-18 Drinking Fountain	8/6/16 11:24	8/15/16 9:50	608085047	COPPER	0.4 PPM	15 PPM
026-48A Classroom C-18 Sink Faucet	8/6/16 11:24	8/15/16 9:50	608085048	COPPER	0.4 PPM	15 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Lee Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Tested For	Results	Action Limit
026-49A Classroom C-19 Drinking Fountain	8/6/16 11:26	8/15/16 9:50	608085049	COPPER	0.5 PPM	15 PPM
026-50A Classroom C-19 Sink Faucet	8/6/16 11:26	8/15/16 9:50	608085050	COPPER	0.4 PPM	15 PPM
026-51A Cafeteria Closet Ice Maker	8/6/16 10:11	8/15/16 9:50	608085051	COPPER	0.5 PPM	15 PPM
026-52A Nurse/Health Ice Maker	8/6/16 10:23	8/15/16 9:50	608085052	COPPER	1.0 PPM	15 PPM
026-53A Staff Lounge Ice Maker	8/6/16 10:31	8/15/16 9:50	608085053	COPPER	0.8 PPM	15 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level