

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Leslie Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
34-01A	Auxillary Gymnasium Hall Drinking Fountain (1)	8/5/16 7:29	8/8/2016	1608388-01A	COPPER 0.4 PPM	1.3 PPM
34-02A	Auxillary Gymnasium Hall Drinking Fountain (2)	8/5/16 7:29	8/8/2016	1608388-02A	COPPER 0.4 PPM	1.3 PPM
34-03A	Gymnasium Hall by Locker Room Drinking Fountain (1)	8/5/16 7:37	8/8/2016	1608388-03A	COPPER 0.1 PPM	1.3 PPM
34-04A	Gymnasium Hall by Locker Room Drinking Fountain (2)	8/5/16 7:37	8/8/2016	1608388-04A	COPPER 0.1 PPM	1.3 PPM
34-05A	Band Room 100 Drinking Fountain (Left)	8/5/16 7:41	8/8/2016	1608388-05A	COPPER 0.2 PPM	1.3 PPM
34-06A	Band Room 100 Drinking Fountain (Right)	8/5/16 7:41	8/8/2016	1608388-06A	COPPER 0.2 PPM	1.3 PPM
34-07A	Commons Refrigerated Drinking Fountain	8/5/16 7:51	8/8/2016	1608388-07A	COPPER 0.1 PPM	1.3 PPM
34-08A	Kitchen Serving Area Sink Faucet	8/5/16 8:01	8/8/2016	1608388-08A	COPPER 0.1 PPM	1.3 PPM
34-09A	Kitchen Food Prep Sink Faucet	8/5/16 8:03	8/8/2016	1608388-09A	COPPER 0.1 PPM	1.3 PPM
34-10A	Staff Room Sink Faucet	8/5/16 8:26	8/8/2016	1608388-10A	COPPER 0.2 PPM	1.3 PPM
34-11A	Room 137 Sink Faucet	8/5/16 8:19	8/8/2016	1608388-11A	COPPER 0.1 PPM	1.3 PPM
34-12A	Room 137 Drinking Fountain	8/5/16 8:19	8/8/2016	1608388-12A	COPPER 0.1 PPM	1.3 PPM
34-13A	1st Floor Hall B Wing Drinking Fountain (Left)	8/5/16 8:29	8/8/2016	1608388-13A	COPPER 0.2 PPM	1.3 PPM
34-14A	1st Floor Hall B Wing Drinking Fountain (Right)	8/5/16 8:29	8/8/2016	1608388-14A	COPPER 0.1 PPM	1.3 PPM
34-15A	Room 114 Sink Faucet	8/5/16 8:35	8/8/2016	1608388-15A	COPPER 0.2 PPM	1.3 PPM
34-16A	Room 114 Drinking Fountain	8/5/16 8:35	8/8/2016	1608388-16A	COPPER 0.2 PPM	1.3 PPM
34-17A	Room 115 Sink Faucet	8/5/16 8:34	8/8/2016	1608388-17A	COPPER 0.2 PPM	1.3 PPM
34-18A	Room 115 Drinking Fountain	8/5/16 8:34	8/8/2016	1608388-18A	COPPER 0.1 PPM	1.3 PPM
34-19A	Room 116 Sink Faucet	8/5/16 8:37	8/8/2016	1608388-19A	COPPER 0.2 PPM	1.3 PPM
34-20A	Room 116 Drinking Fountain	8/5/16 8:37	8/8/2016	1608388-20A	COPPER 0.1 PPM	1.3 PPM
34-21A	Room 118 Sink Faucet	8/5/16 8:41	8/8/2016	1608388-21A	COPPER 0.2 PPM	1.3 PPM
34-22A	Room 118 Drinking Fountain	8/5/16 8:41	8/8/2016	1608388-22A	COPPER 0.1 PPM	1.3 PPM
34-23A	Room 117 Sink Faucet	8/5/16 8:48	8/8/2016	1608388-23A	COPPER 0.2 PPM	1.3 PPM
34-24A	Room 117 Drinking Fountain	8/5/16 8:48	8/8/2016	1608388-24A	COPPER 0.1 PPM	1.3 PPM
34-25A	Hall Outside Library Drinking Fountain	8/5/16 9:51	8/8/2016	1608388-25A	COPPER 0.3 PPM	1.3 PPM
34-26A	Library Work Room Sink Faucet	8/5/16 8:59	8/8/2016	1608388-26A	COPPER 0.2 PPM	1.3 PPM
34-27A	Room 133 Sink Faucet	8/5/16 9:03	8/8/2016	1608388-27A	COPPER 0.3 PPM	1.3 PPM
34-28A	Room 133 Drinking Fountain	8/5/16 9:03	8/8/2016	1608388-28A	COPPER 0.1 PPM	1.3 PPM

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Leslie Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
34-29A 1st Floor C Wing Drinking Fountain (Left)	8/5/16 9:25	8/8/2016	1608388-29A	COPPER	0.4 PPM	1.3 PPM
34-30A 1sr Floor C Wing Drinking Fountain (Right)	8/5/16 9:25	8/8/2016	1608388-30A	COPPER	0.3 PPM	1.3 PPM
34-31A Room 131 Sink Faucet	8/5/16 9:29	8/8/2016	1608388-31A	COPPER	0.2 PPM	1.3 PPM
34-32A Room 131 Drinking Fountain	8/5/16 9:29	8/8/2016	1608388-32A	COPPER	0.1 PPM	1.3 PPM
34-33A Room 130 Sink Faucet	8/5/16 9:31	8/8/2016	1608388-33A	COPPER	0.2 PPM	1.3 PPM
34-34A Room 129 Sink Faucet	8/5/16 9:32	8/8/2016	1608388-34A	COPPER	0.4 PPM	1.3 PPM
34-35A Room 129 Drinking Fountain	8/5/16 9:32	8/8/2016	1608388-35A	COPPER	0.2 PPM	1.3 PPM
34-36A Room 125 Sink Faucet	8/5/16 9:35	8/8/2016	1608388-36A	COPPER	0.3 PPM	1.3 PPM
34-37A Room 125 Drinking Fountain	8/5/16 9:35	8/8/2016	1608388-37A	COPPER	0.2 PPM	1.3 PPM
34-38A Room 126 Sink Faucet	8/5/16 9:39	8/8/2016	1608388-38A	COPPER	0.3 PPM	1.3 PPM
34-39A Room 126 Drinking Fountain	8/5/16 9:39	8/8/2016	1608388-39A	COPPER	0.2 PPM	1.3 PPM
34-40A Room 128 Sink Faucet	8/5/16 9:35	8/8/2016	1608388-40A	COPPER	0.3 PPM	1.3 PPM
34-41A Room 128 Drinking Fountain	8/5/16 9:35	8/8/2016	1608388-41A	COPPER	0.2 PPM	1.3 PPM
34-42A Room 127 Sink Faucet	8/5/16 9:41	8/8/2016	1608388-42A	COPPER	0.4 PPM	1.3 PPM
34-43A Room 127 Drinking Fountain	8/5/16 9:41	8/8/2016	1608388-43A	COPPER	0.2 PPM	1.3 PPM
34-44A Room 204 Sink Faucet	8/5/16 10:04	8/8/2016	1608388-44A	COPPER	0.1 PPM	1.3 PPM
34-45A Room 204 Drinking Fountain	8/5/16 10:04	8/8/2016	1608388-45A	COPPER	0.1 PPM	1.3 PPM
34-46A Room 202 Sink Faucet Center	8/5/16 10:18	8/8/2016	1608388-46A	COPPER	0.1 PPM	1.3 PPM
34-47A Room 202 Drinking Fountain Center	8/5/16 10:18	8/8/2016	1608388-47A	COPPER	0.2 PPM	1.3 PPM
34-48A Room 202 Sink Faucet 1	8/5/16 10:20	8/8/2016	1608388-48A	COPPER	0.2 PPM	1.3 PPM
34-49A Room 202 Sink Faucet 2	8/5/16 10:21	8/8/2016	1608388-49A	COPPER	0.2 PPM	1.3 PPM
34-50A Room 202 Sink Faucet 3	8/5/16 10:21	8/8/2016	1608388-50A	COPPER	0.7 PPM	1.3 PPM
34-51A Room 202 Sink Faucet 4	8/5/16 10:22	8/8/2016	1608388-51A	COPPER	0.2 PPM	1.3 PPM
34-52A Room 202 Sink Faucet 5	8/5/16 10:22	8/8/2016	1608388-52A	COPPER	0.1 PPM	1.3 PPM
34-53A Room 202 Sink Faucet 6	8/5/16 10:23	8/8/2016	1608388-53A	COPPER	0.2 PPM	1.3 PPM
34-54A Room 201 Sink Faucet	8/5/16 10:32	8/8/2016	1608388-54A	COPPER	0.2 PPM	1.3 PPM
34-55A Room 201 Drinking Fountain	8/5/16 10:32	8/8/2016	1608388-55A	COPPER	0.3 PPM	1.3 PPM
34-56A Room 200 Sink Faucet	8/5/16 10:41	8/8/2016	1608388-56A	COPPER	0.3 PPM	1.3 PPM

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Leslie Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
34-57A Room 200 Drinking Fountain	8/5/16 10:40	8/8/2016	1608388-57A	COPPER	0.2 PPM	1.3 PPM
34-58A Nurse's Room Sink Faucet	8/5/16 10:48	8/8/2016	1608388-58A	COPPER	0.1 PPM	1.3 PPM
34-59A Office Sink Faucet	8/5/16 10:53	8/8/2016	1608388-59A	COPPER	0.2 PPM	1.3 PPM
34-60A Health Room Sink Faucet	8/5/16 10:53	8/8/2016	1608388-60A	COPPER	0.2 PPM	1.3 PPM
34-61A Room 210 Sink Faucet	8/5/16 11:01	8/8/2016	1608388-61A	COPPER	0.2 PPM	1.3 PPM
34-62A Room 210 Drinking Fountain	8/5/16 11:01	8/8/2016	1608388-62A	COPPER	0.1 PPM	1.3 PPM
34-63A 2nd Floor Commons East Wing Drinking Fountain	8/5/16 11:00	8/8/2016	1608388-63A	COPPER	0.2 PPM	1.3 PPM
34-64A 2nd Floor Commons East Wing Drinking Fountain	8/5/16 11:00	8/8/2016	1608388-64A	COPPER	0.1 PPM	1.3 PPM
34-65A Room 213 Sink Faucet	8/5/16 11:04	8/8/2016	1608388-65A	COPPER	0.2 PPM	1.3 PPM
34-66A Room 213 Drinking Fountain	8/5/16 11:04	8/8/2016	1608388-66A	COPPER	0.1 PPM	1.3 PPM
34-67A Room 212 Sink Faucet	8/5/16 11:05	8/8/2016	1608388-67A	COPPER	0.2 PPM	1.3 PPM
34-68A Room 214 Sink Faucet	8/5/16 11:06	8/8/2016	1608388-68A	COPPER	0.2 PPM	1.3 PPM
34-69A Room 214 Drinking Fountain	8/5/16 11:06	8/8/2016	1608388-69A	COPPER	0.1 PPM	1.3 PPM
34-70A Room 215 Sink Faucet	8/5/16 11:07	8/8/2016	1608388-70A	COPPER	0.2 PPM	1.3 PPM
34-71A Room 215 Drinking Fountain	8/5/16 11:07	8/8/2016	1608388-71A	COPPER	0.2 PPM	1.3 PPM
34-72A Room 217 Sink Faucet	8/5/16 11:09	8/8/2016	1608388-72A	COPPER	0.2 PPM	1.3 PPM
34-73A Room 217 Drinking Fountain	8/5/16 11:09	8/8/2016	1608388-73A	COPPER	0.1 PPM	1.3 PPM
34-74A Room 216 Sink Faucet	8/5/16 11:10	8/8/2016	1608388-74A	COPPER	0.2 PPM	1.3 PPM
34-75A Room 216 Drinking Fountain	8/5/16 11:10	8/8/2016	1608388-75A	COPPER	0.1 PPM	1.3 PPM
34-76A Room 233 Sink Faucet	8/5/16 11:14	8/8/2016	1608388-76A	COPPER	0.3 PPM	1.3 PPM
34-77A Room 233 Drinking Fountain	8/5/16 11:14	8/8/2016	1608388-77A	COPPER	0.2 PPM	1.3 PPM
34-78A Room 232 Sink Faucet	8/5/16 11:16	8/8/2016	1608388-78A	COPPER	0.2 PPM	1.3 PPM
34-79A Room 232 Drinking Fountain	8/5/16 11:16	8/8/2016	1608388-79A	COPPER	0.2 PPM	1.3 PPM
34-80A Room 231 Sink Faucet	8/5/16 11:19	8/8/2016	1608388-80A	COPPER	0.1 PPM	1.3 PPM
34-81A Room 231 Drinking Fountain	8/5/16 11:19	8/8/2016	1608388-81A	COPPER	0.1 PPM	1.3 PPM
34-82A Room 230 Sink Faucet	8/5/16 11:22	8/8/2016	1608388-82A	COPPER	0.2 PPM	1.3 PPM
34-83A Room 230 Drinking Fountain	8/5/16 11:22	8/8/2016	1608388-83A	COPPER	0.1 PPM	1.3 PPM
34-84A Room 229 Sink Faucet	8/5/16 11:12	8/8/2016	1608388-84A	COPPER	0.2 PPM	1.3 PPM

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Leslie Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
34-85A Hall Outside 229 Drinking Fountain	8/5/16 11:20	8/8/2016	1608388-85A	COPPER	0.2 PPM	1.3 PPM
34-86A Hall Outside 229 Drinking Fountain	8/5/16 11:20	8/8/2016	1608388-86A	COPPER	0.2 PPM	1.3 PPM
34-87A Room 228 Sink Faucet	8/5/16 11:25	8/8/2016	1608388-87A	COPPER	0.3 PPM	1.3 PPM
34-88A Room 228 Drinking Fountain	8/5/16 11:25	8/8/2016	1608388-88A	COPPER	0.1 PPM	1.3 PPM
34-89A Room 224 Sink Faucet	8/5/16 11:29	8/8/2016	1608388-89A	COPPER	0.2 PPM	1.3 PPM
34-90A Room 224 Drinking Fountain	8/5/16 11:29	8/8/2016	1608388-90A	COPPER	0.2 PPM	1.3 PPM
34-91A Room 225 Sink Faucet	8/5/16 11:32	8/8/2016	1608388-91A	COPPER	0.2 PPM	1.3 PPM
34-92A Room 225 Drinking Fountain	8/5/16 11:32	8/8/2016	1608388-92A	COPPER	0.1 PPM	1.3 PPM
34-93A Room 227 Sink Faucet	8/5/16 11:31	8/8/2016	1608388-93A	COPPER	0.3 PPM	1.3 PPM
34-94A Room 227 Drinking Fountain	8/5/16 11:31	8/8/2016	1608388-94A	COPPER	0.2 PPM	1.3 PPM
34-95A Room 226 Sink Faucet	8/5/16 11:35	8/8/2016	1608388-95A	COPPER	0.3 PPM	1.3 PPM
34-96A Room 226 Drinking Fountain	8/5/16 11:35	8/8/2016	1608388-96A	COPPER	0.2 PPM	1.3 PPM
34-97A Room 113 Sink Faucet	8/5/16 12:11	8/8/2016	1608388-97A	COPPER	0.1 PPM	1.3 PPM
34-98A Ice Machine Kitchen	8/5/16 8:07	8/8/2016	1608388-98A	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

**SKPS Action Level for Copper is 1.3 PPM**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**