

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Leslie Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
34-01A Auxillary Gymnasium Hall Drinking Fountain (1)	8/5/16 7:29	8/8/2016	1608388-01A	LEAD	<1.0 PPB	15 PPB
34-02A Auxillary Gymnasium Hall Drinking Fountain (2)	8/5/16 7:29	8/8/2016	1608388-02A	LEAD	<1.0 PPB	15 PPB
34-03A Gymnasium Hall by Locker Room Drinking Fountain (1)	8/5/16 7:37	8/8/2016	1608388-03A	LEAD	<1.0 PPB	15 PPB
34-04A Gymnasium Hall by Locker Room Drinking Fountain (2)	8/5/16 7:37	8/8/2016	1608388-04A	LEAD	<1.0 PPB	15 PPB
34-05A Band Room 100 Drinking Fountain (Left)	8/5/16 7:41	8/8/2016	1608388-05A	LEAD	<1.0 PPB	15 PPB
34-06A Band Room 100 Drinking Fountain (Right)	8/5/16 7:41	8/8/2016	1608388-06A	LEAD	<1.0 PPB	15 PPB
34-07A Commons Refrigerated Drinking Fountain	8/5/16 7:51	8/8/2016	1608388-07A	LEAD	<1.0 PPB	15 PPB
34-08A Kitchen Serving Area Sink Faucet	8/5/16 8:01	8/8/2016	1608388-08A	LEAD	1 PPB	15 PPB
34-09A Kitchen Food Prep Sink Faucet	8/5/16 8:03	8/8/2016	1608388-09A	LEAD	2 PPB	15 PPB
34-10A Staff Room Sink Faucet	8/5/16 8:26	8/8/2016	1608388-10A	LEAD	3 PPB	15 PPB
34-11A Room 137 Sink Faucet	8/5/16 8:19	8/8/2016	1608388-11A	LEAD	6 PPB	15 PPB
34-12A Room 137 Drinking Fountain	8/5/16 8:19	8/8/2016	1608388-12A	LEAD	<1.0 PPB	15 PPB
34-13A 1st Floor Hall B Wing Drinking Fountain (Left)	8/5/16 8:29	8/8/2016	1608388-13A	LEAD	<1.0 PPB	15 PPB
34-14A 1st Floor Hall B Wing Drinking Fountain (Right)	8/5/16 8:29	8/8/2016	1608388-14A	LEAD	<1.0 PPB	15 PPB
34-15A Room 114 Sink Faucet	8/5/16 8:35	8/8/2016	1608388-15A	LEAD	6 PPB	15 PPB
34-16A Room 114 Drinking Fountain	8/5/16 8:35	8/8/2016	1608388-16A	LEAD	<1.0 PPB	15 PPB
34-17A Room 115 Sink Faucet	8/5/16 8:34	8/8/2016	1608388-17A	LEAD	7 PPB	15 PPB
34-18A Room 115 Drinking Fountain	8/5/16 8:34	8/8/2016	1608388-18A	LEAD	<1.0 PPB	15 PPB
34-19A Room 116 Sink Faucet	8/5/16 8:37	8/8/2016	1608388-19A	LEAD	10 PPB	15 PPB
34-20A Room 116 Drinking Fountain	8/5/16 8:37	8/8/2016	1608388-20A	LEAD	1 PPB	15 PPB
34-21A Room 118 Sink Faucet	8/5/16 8:41	8/8/2016	1608388-21A	LEAD	6 PPB	15 PPB
34-22A Room 118 Drinking Fountain	8/5/16 8:41	8/8/2016	1608388-22A	LEAD	<1.0 PPB	15 PPB
34-23A Room 117 Sink Faucet	8/5/16 8:48	8/8/2016	1608388-23A	LEAD	10 PPB	15 PPB
34-24A Room 117 Drinking Fountain	8/5/16 8:48	8/8/2016	1608388-24A	LEAD	<1.0 PPB	15 PPB
34-25A Hall Outside Library Drinking Fountain	8/5/16 9:51	8/8/2016	1608388-25A	LEAD	<1.0 PPB	15 PPB
34-26A Library Work Room Sink Faucet	8/5/16 8:59	8/8/2016	1608388-26A	LEAD	3 PPB	15 PPB
34-27A Room 133 Sink Faucet	8/5/16 9:03	8/8/2016	1608388-27A	LEAD	10 PPB	15 PPB
34-28A Room 133 Drinking Fountain	8/5/16 9:03	8/8/2016	1608388-28A	LEAD	<1.0 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Leslie Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
34-29A 1st Floor C Wing Drinking Fountain (Left)	8/5/16 9:25	8/8/2016	1608388-29A	LEAD	<1.0 PPB	15 PPB
34-30A 1sr Floor C Wing Drinking Fountain (Right)	8/5/16 9:25	8/8/2016	1608388-30A	LEAD	<1.0 PPB	15 PPB
34-31A Room 131 Sink Faucet	8/5/16 9:29	8/8/2016	1608388-31A	LEAD	6 PPB	15 PPB
34-32A Room 131 Drinking Fountain	8/5/16 9:29	8/8/2016	1608388-32A	LEAD	<1.0 PPB	15 PPB
34-33A Room 130 Sink Faucet	8/5/16 9:31	8/8/2016	1608388-33A	LEAD	<1.0 PPB	15 PPB
34-34A Room 129 Sink Faucet	8/5/16 9:32	8/8/2016	1608388-34A	LEAD	12 PPB	15 PPB
34-35A Room 129 Drinking Fountain	8/5/16 9:32	8/8/2016	1608388-35A	LEAD	<1.0 PPB	15 PPB
34-36A Room 125 Sink Faucet	8/5/16 9:35	8/8/2016	1608388-36A	LEAD	7 PPB	15 PPB
34-37A Room 125 Drinking Fountain	8/5/16 9:35	8/8/2016	1608388-37A	LEAD	<1.0 PPB	15 PPB
34-38A Room 126 Sink Faucet	8/5/16 9:39	8/8/2016	1608388-38A	LEAD	5 PPB	15 PPB
34-39A Room 126 Drinking Fountain	8/5/16 9:39	8/8/2016	1608388-39A	LEAD	1 PPB	15 PPB
34-40A Room 128 Sink Faucet	8/5/16 9:35	8/8/2016	1608388-40A	LEAD	7 PPB	15 PPB
34-41A Room 128 Drinking Fountain	8/5/16 9:35	8/8/2016	1608388-41A	LEAD	<1.0 PPB	15 PPB
34-42A Room 127 Sink Faucet	8/5/16 9:41	8/8/2016	1608388-42A	LEAD	5 PPB	15 PPB
34-43A Room 127 Drinking Fountain	8/5/16 9:41	8/8/2016	1608388-43A	LEAD	<1.0 PPB	15 PPB
34-44A Room 204 Sink Faucet	8/5/16 10:04	8/8/2016	1608388-44A	LEAD	<1.0 PPB	15 PPB
34-45A Room 204 Drinking Fountain	8/5/16 10:04	8/8/2016	1608388-45A	LEAD	1 PPB	15 PPB
34-46A Room 202 Sink Faucet Center	8/5/16 10:18	8/8/2016	1608388-46A	LEAD	2 PPB	15 PPB
34-47A Room 202 Drinking Fountain Center	8/5/16 10:18	8/8/2016	1608388-47A	LEAD	3 PPB	15 PPB
34-48A Room 202 Sink Faucet 1	8/5/16 10:20	8/8/2016	1608388-48A	LEAD	1 PPB	15 PPB
34-49A Room 202 Sink Faucet 2	8/5/16 10:21	8/8/2016	1608388-49A	LEAD	<1.0 PPB	15 PPB
34-50A Room 202 Sink Faucet 3	8/5/16 10:21	8/8/2016	1608388-50A	LEAD	1 PPB	15 PPB
34-51A Room 202 Sink Faucet 4	8/5/16 10:22	8/8/2016	1608388-51A	LEAD	2 PPB	15 PPB
34-52A Room 202 Sink Faucet 5	8/5/16 10:22	8/8/2016	1608388-52A	LEAD	1 PPB	15 PPB
34-53A Room 202 Sink Faucet 6	8/5/16 10:23	8/8/2016	1608388-53A	LEAD	1 PPB	15 PPB
34-54A Room 201 Sink Faucet	8/5/16 10:32	8/8/2016	1608388-54A	LEAD	3 PPB	15 PPB
34-55A Room 201 Drinking Fountain	8/5/16 10:32	8/8/2016	1608388-55A	LEAD	1 PPB	15 PPB
34-56A Room 200 Sink Faucet	8/5/16 10:41	8/8/2016	1608388-56A	LEAD	6 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Leslie Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
34-57A Room 200 Drinking Fountain	8/5/16 10:40	8/8/2016	1608388-57A	LEAD	1 PPB	15 PPB
34-58A Nurse's Room Sink Faucet	8/5/16 10:48	8/8/2016	1608388-58A	LEAD	2 PPB	15 PPB
34-59A Office Sink Faucet	8/5/16 10:53	8/8/2016	1608388-59A	LEAD	1 PPB	15 PPB
34-60A Health Room Sink Faucet	8/5/16 10:53	8/8/2016	1608388-60A	LEAD	1 PPB	15 PPB
34-61A Room 210 Sink Faucet	8/5/16 11:01	8/8/2016	1608388-61A	LEAD	6 PPB	15 PPB
34-62A Room 210 Drinking Fountain	8/5/16 11:01	8/8/2016	1608388-62A	LEAD	<1.0 PPB	15 PPB
34-63A 2nd Floor Commons East Wing Drinking Fountain	8/5/16 11:00	8/8/2016	1608388-63A	LEAD	<1.0 PPB	15 PPB
34-64A 2nd Floor Commons East Wing Drinking Fountain	8/5/16 11:00	8/8/2016	1608388-64A	LEAD	<1.0 PPB	15 PPB
34-65A Room 213 Sink Faucet	8/5/16 11:04	8/8/2016	1608388-65A	LEAD	8 PPB	15 PPB
34-66A Room 213 Drinking Fountain	8/5/16 11:04	8/8/2016	1608388-66A	LEAD	<1.0 PPB	15 PPB
34-67A Room 212 Sink Faucet	8/5/16 11:05	8/8/2016	1608388-67A	LEAD	5 PPB	15 PPB
34-68A Room 214 Sink Faucet	8/5/16 11:06	8/8/2016	1608388-68A	LEAD	12 PPB	15 PPB
34-69A Room 214 Drinking Fountain	8/5/16 11:06	8/8/2016	1608388-69A	LEAD	2 PPB	15 PPB
34-70A Room 215 Sink Faucet	8/5/16 11:07	8/8/2016	1608388-70A	LEAD	9 PPB	15 PPB
34-71A Room 215 Drinking Fountain	8/5/16 11:07	8/8/2016	1608388-71A	LEAD	2 PPB	15 PPB
34-72A Room 217 Sink Faucet	8/5/16 11:09	8/8/2016	1608388-72A	LEAD	5 PPB	15 PPB
34-73A Room 217 Drinking Fountain	8/5/16 11:09	8/8/2016	1608388-73A	LEAD	<1.0 PPB	15 PPB
34-74A Room 216 Sink Faucet	8/5/16 11:10	8/8/2016	1608388-74A	LEAD	6 PPB	15 PPB
34-75A Room 216 Drinking Fountain	8/5/16 11:10	8/8/2016	1608388-75A	LEAD	<1.0 PPB	15 PPB
34-76A Room 233 Sink Faucet	8/5/16 11:14	8/8/2016	1608388-76A	LEAD	5 PPB	15 PPB
34-77A Room 233 Drinking Fountain	8/5/16 11:14	8/8/2016	1608388-77A	LEAD	<1.0 PPB	15 PPB
34-78A Room 232 Sink Faucet	8/5/16 11:16	8/8/2016	1608388-78A	LEAD	5 PPB	15 PPB
34-79A Room 232 Drinking Fountain	8/5/16 11:16	8/8/2016	1608388-79A	LEAD	<1.0 PPB	15 PPB
34-80A Room 231 Sink Faucet	8/5/16 11:19	8/8/2016	1608388-80A	LEAD	7 PPB	15 PPB
34-81A Room 231 Drinking Fountain	8/5/16 11:19	8/8/2016	1608388-81A	LEAD	1 PPB	15 PPB
34-82A Room 230 Sink Faucet	8/5/16 11:22	8/8/2016	1608388-82A	LEAD	2 PPB	15 PPB
34-83A Room 230 Drinking Fountain	8/5/16 11:22	8/8/2016	1608388-83A	LEAD	<1.0 PPB	15 PPB
34-84A Room 229 Sink Faucet	8/5/16 11:12	8/8/2016	1608388-84A	LEAD	<1.0 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Leslie Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
34-85A Hall Outside 229 Drinking Fountain	8/5/16 11:20	8/8/2016	1608388-85A	LEAD	<1.0 PPB	15 PPB
34-86A Hall Outside 229 Drinking Fountain	8/5/16 11:20	8/8/2016	1608388-86A	LEAD	<1.0 PPB	15 PPB
34-87A Room 228 Sink Faucet	8/5/16 11:25	8/8/2016	1608388-87A	LEAD	8 PPB	15 PPB
34-88A Room 228 Drinking Fountain	8/5/16 11:25	8/8/2016	1608388-88A	LEAD	2 PPB	15 PPB
34-89A Room 224 Sink Faucet	8/5/16 11:29	8/8/2016	1608388-89A	LEAD	3 PPB	15 PPB
34-90A Room 224 Drinking Fountain	8/5/16 11:29	8/8/2016	1608388-90A	LEAD	<1.0 PPB	15 PPB
34-91A Room 225 Sink Faucet	8/5/16 11:32	8/8/2016	1608388-91A	LEAD	7 PPB	15 PPB
34-92A Room 225 Drinking Fountain	8/5/16 11:32	8/8/2016	1608388-92A	LEAD	<1.0 PPB	15 PPB
34-93A Room 227 Sink Faucet	8/5/16 11:31	8/8/2016	1608388-93A	LEAD	4 PPB	15 PPB
34-94A Room 227 Drinking Fountain	8/5/16 11:31	8/8/2016	1608388-94A	LEAD	<1.0 PPB	15 PPB
34-95A Room 226 Sink Faucet	8/5/16 11:35	8/8/2016	1608388-95A	LEAD	5 PPB	15 PPB
34-96A Room 226 Drinking Fountain	8/5/16 11:35	8/8/2016	1608388-96A	LEAD	<1.0 PPB	15 PPB
34-97A Room 113 Sink Faucet	8/5/16 12:11	8/8/2016	1608388-97A	LEAD	4 PPB	15 PPB
34-98A Ice Machine Kitchen	8/5/16 8:07	8/8/2016	1608388-98A	LEAD	<1.0 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level