

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Liberty Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
027-01A Kitchen Food Prep Sink Faucet	7/29/16 7:28	8/5/2016	1608152-01A	COPPER	0.1 PPM	1.3 PPM
027-02A Kitchen Food Prep Sink Faucet	7/29/16 7:29	8/5/2016	1608152-02A	COPPER	0.1 PPM	1.3 PPM
027-03A Room 20 Sink Faucet	7/29/16 7:38	8/5/2016	1608152-03A	COPPER	0.1 PPM	1.3 PPM
027-04A Room 20 Drinking Fountain	7/29/16 7:38	8/5/2016	1608152-04A	COPPER	0.3 PPM	1.3 PPM
027-05A Room 21 Sink Faucet	7/29/16 7:42	8/5/2016	1608152-05A	COPPER	0.3 PPM	1.3 PPM
027-06A Room 21 Drinking Fountain	7/29/16 7:42	8/5/2016	1608152-06A	COPPER	0.5 PPM	1.3 PPM
027-07A Room 22 Sink Faucet	7/29/16 7:45	8/5/2016	1608152-07A	COPPER	0.4 PPM	1.3 PPM
027-08A Room 22 Drinking Fountain	7/29/16 7:45	8/5/2016	1608152-08A	COPPER	0.8 PPM	1.3 PPM
027-09A Media Break Area Sink Faucet	7/29/16 7:52	8/5/2016	1608152-09A	COPPER	0.5 PPM	1.3 PPM
027-10A Hall Drinking Fountain 1	7/29/16 7:54	8/5/2016	1608152-10A	COPPER	0.4 PPM	1.3 PPM
027-11A Hall Drinking Fountain 2	7/29/16 7:55	8/5/2016	1608152-11A	COPPER	0.4 PPM	1.3 PPM
027-12A Room 14 Sink Faucet	7/29/16 7:59	8/5/2016	1608152-12A	COPPER	0.5 PPM	1.3 PPM
027-13A Room 14 Drinking Fountain	7/29/16 7:59	8/5/2016	1608152-13A	COPPER	0.6 PPM	1.3 PPM
027-14A Room 15 Sink Faucet	7/29/16 8:01	8/5/2016	1608152-14A	COPPER	0.1 PPM	1.3 PPM
027-15A Room 15 Drinking Fountain	7/29/16 8:01	8/5/2016	1608152-15A	COPPER	0.2 PPM	1.3 PPM
027-16A Room 16 Sink Faucet	7/29/16 8:03	8/5/2016	1608152-16A	COPPER	0.7 PPM	1.3 PPM
027-17A Room 16 Drinking Fountain	7/29/16 8:03	8/5/2016	1608152-17A	COPPER	0.6 PPM	1.3 PPM
027-18A Room 17 Sink Faucet	7/29/16 8:06	8/5/2016	1608152-18A	COPPER	0.3 PPM	1.3 PPM
027-19A Room 17 Drinking Fountain	7/29/16 8:06	8/5/2016	1608152-19A	COPPER	0.7 PPM	1.3 PPM
027-20A Room 18 Sink Faucet	7/29/16 8:09	8/5/2016	1608152-20A	COPPER	0.3 PPM	1.3 PPM
027-21A Room 18 Drinking Fountain	7/29/16 8:09	8/5/2016	1608152-21A	COPPER	0.6 PPM	1.3 PPM
027-22A Room 19 Sink Faucet	7/29/16 8:12	8/5/2016	1608152-22A	COPPER	0.2 PPM	1.3 PPM
027-23A Room 19 Drinking Fountain	7/29/16 8:12	8/5/2016	1608152-23A	COPPER	0.7 PPM	1.3 PPM
027-24A Room 12 Sink Faucet	7/29/16 8:19	8/5/2016	1608152-24A	COPPER	0.2 PPM	1.3 PPM
027-25A Room 12 Drinking Fountain	7/29/16 8:19	8/5/2016	1608152-25A	COPPER	0.1 PPM	1.3 PPM
027-26A Room 11 Sink Faucet	7/29/16 8:22	8/5/2016	1608152-26A	COPPER	0.1 PPM	1.3 PPM
027-27A Room 11 Drinking Fountain	7/29/16 8:22	8/5/2016	1608152-27A	COPPER	0.2 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Liberty Elementary School

027-28A	Computer Lab 7 Sink Faucet	7/29/16 8:25	8/5/2016	1608152-28A	COPPER	0.3 PPM	1.3 PPM
027-29A	Computer Lab 7 Drinking Fountain	7/29/16 8:25	8/5/2016	1608152-29A	COPPER	0.6 PPM	1.3 PPM
027-30A	Room 6 Sink Faucet	7/29/16 8:28	8/5/2016	1608152-30A	COPPER	0.2 PPM	1.3 PPM
027-31A	Room 6 Drinking Fountain	7/29/16 8:28	8/5/2016	1608152-31A	COPPER	0.3 PPM	1.3 PPM
027-32A	Room 10 Sink Faucet	7/29/16 8:31	8/5/2016	1608152-32A	COPPER	0.2 PPM	1.3 PPM
027-33A	Room 10 Drinking Fountain	7/29/16 8:31	8/5/2016	1608152-33A	COPPER	0.2 PPM	1.3 PPM
027-34A	Staff Lounge Sink Faucet	7/29/16 8:33	8/5/2016	1608152-34A	COPPER	0.1 PPM	1.3 PPM
027-35A	Room 1 Sink Faucet	7/29/16 8:40	8/5/2016	1608152-35A	COPPER	0.3 PPM	1.3 PPM
027-36A	Room 1 Drinking Fountain	7/29/16 8:40	8/5/2016	1608152-36A	COPPER	0.7 PPM	1.3 PPM
027-37A	Hall Drinking Fountain 3	7/29/16 8:46	8/5/2016	1608152-37A	COPPER	0.6 PPM	1.3 PPM
027-38A	Room 2 Sink Faucet	7/29/16 8:50	8/5/2016	1608152-38A	COPPER	0.2 PPM	1.3 PPM
027-39A	Room 2 Drinking Fountain	7/29/16 8:50	8/5/2016	1608152-39A	COPPER	0.4 PPM	1.3 PPM
027-40A	Room 3 Sink Faucet	7/29/16 8:54	8/5/2016	1608152-40A	COPPER	0.3 PPM	1.3 PPM
027-41A	Room 3 Drinking Fountain	7/29/16 8:54	8/5/2016	1608152-41A	COPPER	0.6 PPM	1.3 PPM
027-42A	Room 5 Sink Faucet	7/29/16 8:57	8/5/2016	1608152-42A	COPPER	0.3 PPM	1.3 PPM
027-43A	Room 5 Drinking Fountain	7/29/16 8:57	8/5/2016	1608152-43A	COPPER	0.6 PPM	1.3 PPM
027-44A	Room 4 Sink Faucet	7/29/16 9:00	8/5/2016	1608152-44A	COPPER	0.2 PPM	1.3 PPM
027-45A	Room 4 Drinking Fountain	7/29/16 9:00	8/5/2016	1608152-45A	COPPER	0.5 PPM	1.3 PPM
027-46A	Room 23 Sink Faucet	7/29/16 9:07	8/5/2016	1608152-46A	COPPER	0.4 PPM	1.3 PPM
027-47A	Hall Drinking Fountain 4	7/29/16 9:09	8/5/2016	1608152-47A	COPPER	0.5 PPM	1.3 PPM
027-48A	Music Room Sink Faucet	7/29/16 9:10	8/5/2016	1608152-48A	COPPER	0.5 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level