

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
McKinley Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Limit
37-01A Ground Floor Girls Restroom Drinking Fountain	8/13/16 13:05	8/22/16 11:16	608151501	COPPER	0.3 PPM	1.3 PPM
37-02A Ground Floor Boys Restroom Drinking Fountain	8/13/16 13:09	8/22/16 11:16	608151502	COPPER	0.4 PPM	1.3 PPM
37-03A Room 7 (LRC) Sink Faucet	8/13/16 13:11	8/22/16 11:16	608151503	COPPER	0.4 PPM	1.3 PPM
37-05A Media Center Office (108B) Sink Faucet	8/13/16 13:14	8/22/16 11:16	608151504	COPPER	0.5 PPM	1.3 PPM
37-06A Room 6 Sink Faucet	8/13/16 13:21	8/22/16 11:18	608151505	COPPER	0.4 PPM	1.3 PPM
37-07A Room 6 Drinking Fountain	8/13/16 13:21	8/22/16 11:16	608151506	COPPER	0.4 PPM	1.3 PPM
37-08A Room 5 Sink Faucet	8/13/16 13:26	8/22/16 11:16	608151507	COPPER	0.4 PPM	1.3 PPM
37-09A Room 5 Drinking Fountain	8/13/16 13:26	8/22/16 11:16	608151508	COPPER	0.4 PPM	1.3 PPM
37-10A Room 4 Sink Faucet	8/13/16 13:29	8/22/16 11:16	608151509	COPPER	0.3 PPM	1.3 PPM
37-11A Room 4 Drinking Fountain	8/13/16 13:29	8/22/16 11:16	608151510	COPPER	0.4 PPM	1.3 PPM
37-12A Room 3 Sink Faucet	8/13/16 13:32	8/22/16 11:07	608151511	COPPER	0.4 PPM	1.3 PPM
37-13A Room 3 Drinking Fountain	8/13/16 13:32	8/22/16 11:07	608151512	COPPER	0.5 PPM	1.3 PPM
37-14A Room 114 Speech Sink Faucet	8/13/16 13:42	8/22/16 11:07	608151513	COPPER	0.5 PPM	1.3 PPM
37-15A Room 8 Sink Faucet	8/13/16 13:44	8/22/16 11:07	608151514	COPPER	0.4 PPM	1.3 PPM
37-16A Room 8 Drinking Fountain	8/13/16 13:44	8/22/16 11:07	608151515	COPPER	0.3 PPM	1.3 PPM
37-17A Multi-Purpose Room Drinking Fountain	8/13/16 13:47	8/22/16 11:08	608151516	COPPER	0.4 PPM	1.3 PPM
37-18A Kitchen Food Prep Sink Faucet	8/13/16 13:50	8/22/16 11:08	608151517	COPPER	0.1 PPM	1.3 PPM
37-19A Kitchen Storage Sink Faucet	8/13/16 13:51	8/22/16 11:08	608151518	COPPER	0.1 PPM	1.3 PPM
37-20A Room 2 Sink Faucet	8/13/16 13:59	8/22/16 11:08	608151519	COPPER	0.4 PPM	1.3 PPM
37-21A Room 2 Drinking Fountain	8/13/16 13:59	8/22/16 11:08	608151520	COPPER	0.5 PPM	1.3 PPM
37-22A Room 1 Sink Faucet	8/13/16 13:59	8/22/16 11:09	608151521	COPPER	0.4 PPM	1.3 PPM
37-23A Room 1 Drinking Fountain	8/13/16 13:52	8/22/16 11:09	608151522	COPPER	0.3 PPM	1.3 PPM
37-24A Health Room Sink Faucet	8/13/16 14:06	8/22/16 11:09	608151523	COPPER	0.3 PPM	1.3 PPM
37-25A Staff Break Room Sink Faucet	8/13/16 14:08	8/22/16 11:09	608151524	COPPER	0.3 PPM	1.3 PPM
37-26A Room 9 Sink Faucet	8/13/16 14:10	8/22/16 11:09	608151525	COPPER	0.3 PPM	1.3 PPM
37-27A Room 9 Drinking Fountain	8/13/16 14:10	8/22/16 11:09	608151526	COPPER	0.3 PPM	1.3 PPM
37-28A Room 10 Sink Faucet	8/13/16 14:13	8/22/16 11:09	608151527	COPPER	0.3 PPM	1.3 PPM
37-29A Room 10 Drinking Fountain	8/13/16 14:13	8/22/16 11:09	608151528	COPPER	0.1 PPM	1.3 PPM
37-30A Room 11 Sink Faucet	8/13/16 14:17	8/22/16 11:09	608151529	COPPER	0.4 PPM	1.3 PPM
37-31A Room 11 Drinking Fountain	8/13/16 14:17	8/22/16 11:09	608151530	COPPER	0.3 PPM	1.3 PPM
37-32A3rd Floor Hall Drinking Fountain	8/13/16 14:19	8/23/16 9:13	608151531	COPPER	0.6 PPM	1.3 PPM
37-33A Room 12 Sink Faucet	8/13/16 14:22	8/23/16 9:14	608151532	COPPER	0.5 PPM	1.3 PPM
37-34A Room 12 Drinking Fountain	8/13/16 14:22	8/23/16 9:14	608151533	COPPER	0.3 PPM	1.3 PPM
37-35A Room 13 Sink Faucet	8/13/16 14:24	8/23/16 9:14	608151534	COPPER	0.4 PPM	1.3 PPM
37-36A Room 13 Drinking Fountain	8/13/16 14:24	8/23/16 9:14	608151535	COPPER	0.3 PPM	1.3 PPM
37-37A Room 14 Sink Faucet	8/13/16 14:27	8/23/16 9:16	608151536	COPPER	0.5 PPM	1.3 PPM
37-38A Room 14 Drinking Fountain	8/13/16 14:27	8/23/16 9:16	608151537	COPPER	0.5 PPM	1.3 PPM
37-39A Room 15 Sink Faucet	8/13/16 14:26	8/23/16 9:16	608151538	COPPER	0.4 PPM	1.3 PPM
37-40A Room 15 Drinking Fountain	8/13/16 14:26	8/23/16 9:16	608151539	COPPER	0.5 PPM	1.3 PPM
37-41A Centennial Drinking Fountain (outside)	8/13/16 14:36	8/23/16 9:16	608151540	COPPER	0.3 PPM	1.3 PPM
37-42A Gymnasium Drinking Fountain	8/13/16 14:43	8/23/16 9:16	608151541	COPPER	0.3 PPM	1.3 PPM
37-43A Music Room Sink Faucet	8/13/16 14:39	8/23/16 9:17	608151542	COPPER	0.3 PPM	1.3 PPM
37-44A Music Room Drinking Fountain	8/13/16 14:39	8/23/16 9:17	608151543	COPPER	0.3 PPM	1.3 PPM
37-45A 1st Floor Hall by Room 5 Drinking Fountain	8/13/16 13:35	8/23/16 9:17	608151544	COPPER	0.5 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

**SKPS Action Level for Copper is 1.3 PPM**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
McKinley Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Limit
037-04A Room 7 Drinking Fountain	9/29/2016 5:40	10/3/2016	59451	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (C) Sample Data  
McKinley Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Limit
37-05C Media Center Office (108B) Sink Faucet	10/27/16 5:10	10/28/2016	65863	COPPER	0.5 PPM	1.3 PPM
37-08C Room 5 Sink Faucet	10/27/16 5:12	10/28/2016	65864	COPPER	0.5 PPM	1.3 PPM
37-26C Room 9 Sink Faucet	10/27/16 5:14	10/28/2016	65865	COPPER	0.3 PPM	1.3 PPM
37-33C Room 12 Sink Faucet	10/27/16 5:16	10/28/2016	65866	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level