

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
McKinley Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Limit
37-01A Ground Floor Girls Restroom Drinking Fountain	8/13/16 13:05	8/22/16 11:16	608151501	LEAD	3 PPB	15 PPB
37-02A Ground Floor Boys Restroom Drinking Fountain	8/13/16 13:09	8/22/16 11:16	608151502	LEAD	< 1 PPB	15 PPB
37-03A Room 7 (LRC) Sink Faucet	8/13/16 13:11	8/22/16 11:16	608151503	LEAD	1 PPB	15 PPB
37-05A Media Center Office (108B) Sink Faucet	8/13/16 13:14	8/22/16 11:16	608151504	LEAD	15 PPB	15 PPB
37-06A Room 6 Sink Faucet	8/13/16 13:21	8/22/16 11:18	608151505	LEAD	< 1 PPB	15 PPB
37-07A Room 6 Drinking Fountain	8/13/16 13:21	8/22/16 11:16	608151506	LEAD	1 PPB	15 PPB
37-08A Room 5 Sink Faucet	8/13/16 13:26	8/22/16 11:16	608151507	LEAD	67 PPB	15 PPB
37-09A Room 5 Drinking Fountain	8/13/16 13:26	8/22/16 11:16	608151508	LEAD	4 PPB	15 PPB
37-10A Room 4 Sink Faucet	8/13/16 13:29	8/22/16 11:16	608151509	LEAD	2 PPB	15 PPB
37-11A Room 4 Drinking Fountain	8/13/16 13:29	8/22/16 11:16	608151510	LEAD	1 PPB	15 PPB
37-12A Room 3 Sink Faucet	8/13/16 13:32	8/22/16 11:07	608151511	LEAD	< 1 PPB	15 PPB
37-13A Room 3 Drinking Fountain	8/13/16 13:32	8/22/16 11:07	608151512	LEAD	2 PPB	15 PPB
37-14A Room 114 Speach Sink Faucet	8/13/16 13:42	8/22/16 11:07	608151513	LEAD	< 1 PPB	15 PPB
37-15A Room 8 Sink Faucet	8/13/16 13:44	8/22/16 11:07	608151514	LEAD	1 PPB	15 PPB
37-16A Room 8 Drinking Fountain	8/13/16 13:44	8/22/16 11:07	608151515	LEAD	4 PPB	15 PPB
37-17A Multi-Purpose Room Drinking Fountain	8/13/16 13:47	8/22/16 11:08	608151516	LEAD	2 PPB	15 PPB
37-18A Kitchen Food Prep Sink Faucet	8/13/16 13:50	8/22/16 11:08	608151517	LEAD	< 1 PPB	15 PPB
37-19A Kitchen Storage Sink Faucet	8/13/16 13:51	8/22/16 11:08	608151518	LEAD	2 PPB	15 PPB
37-20A Room 2 Sink Faucet	8/13/16 13:59	8/22/16 11:08	608151519	LEAD	< 1 PPB	15 PPB
37-21A Room 2 Drinking Fountain	8/13/16 13:59	8/22/16 11:08	608151520	LEAD	< 1 PPB	15 PPB
37-22A Room 1 Sink Faucet	8/13/16 13:59	8/22/16 11:09	608151521	LEAD	1 PPB	15 PPB
37-23A Room 1 Drinking Fountain	8/13/16 13:52	8/22/16 11:09	608151522	LEAD	6 PPB	15 PPB
37-24A Health Room Sink Faucet	8/13/16 14:06	8/22/16 11:09	608151523	LEAD	< 1 PPB	15 PPB
37-25A Staff Break Room Sink Faucet	8/13/16 14:08	8/22/16 11:09	608151524	LEAD	< 1 PPB	15 PPB
37-26A Room 9 Sink Faucet	8/13/16 14:10	8/22/16 11:09	608151525	LEAD	16 PPB	15 PPB
37-27A Room 9 Drinking Fountain	8/13/16 14:10	8/22/16 11:09	608151526	LEAD	3 PPB	15 PPB
37-28A Room 10 Sink Faucet	8/13/16 14:13	8/22/16 11:09	608151527	LEAD	2 PPB	15 PPB
37-29A Room 10 Drinking Fountain	8/13/16 14:13	8/22/16 11:09	608151528	LEAD	< 1 PPB	15 PPB
37-30A Room 11 Sink Faucet	8/13/16 14:17	8/22/16 11:09	608151529	LEAD	3 PPB	15 PPB
37-31A Room 11 Drinking Fountain	8/13/16 14:17	8/22/16 11:09	608151530	LEAD	1 PPB	15 PPB
37-32A Third Floor Hall Drinking Fountain	8/13/16 14:19	8/23/16 9:13	608151531	LEAD	3 PPB	15 PPB
37-33A Room 12 Sink Faucet	8/13/16 14:22	8/23/16 9:14	608151532	LEAD	55 PPB	15 PPB
37-34A Room 12 Drinking Fountain	8/13/16 14:22	8/23/16 9:14	608151533	LEAD	2 PPB	15 PPB
37-35A Room 13 Sink Faucet	8/13/16 14:24	8/23/16 9:14	608151534	LEAD	4 PPB	15 PPB
37-36A Room 13 Drinking Fountain	8/13/16 14:24	8/23/16 9:14	608151535	LEAD	< 1 PPB	15 PPB
37-37A Room 14 Sink Faucet	8/13/16 14:27	8/23/16 9:16	608151536	LEAD	4 PPB	15 PPB
37-38A Room 14 Drinking Fountain	8/13/16 14:27	8/23/16 9:16	608151537	LEAD	< 1 PPB	15 PPB
37-39A Room 15 Sink Faucet	8/13/16 14:26	8/23/16 9:16	608151538	LEAD	4 PPB	15 PPB
37-40A Room 15 Drinking Fountain	8/13/16 14:26	8/23/16 9:16	608151539	LEAD	1 PPB	15 PPB
37-41A Centennial Drinking Fountain (outside)	8/13/16 14:36	8/23/16 9:16	608151540	LEAD	< 1 PPB	15 PPB
37-42A Gymnasium Drinking Fountain	8/13/16 14:43	8/23/16 9:16	608151541	LEAD	< 1 PPB	15 PPB
37-43A Music Room Sink Faucet	8/13/16 14:39	8/23/16 9:17	608151542	LEAD	4 PPB	15 PPB
37-44A Music Room Drinking Fountain	8/13/16 14:39	8/23/16 9:17	608151543	LEAD	< 1 PPB	15 PPB
37-45A 1st Floor Hall by Room 5 Drinking Fountain	8/13/16 13:35	8/23/16 9:17	608151544	LEAD	4 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
McKinley Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Limit
037-04A Room 7 Drinking Fountain	9/29/2016 5:40	10/3/2016	59451	LEAD	13 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
McKinley Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Limit
37-05B Media Center Office (108B) Sink Faucet	8/13/16 13:15	9/7/16 11:46	609010101	LEAD	2 PPB	15 PPB
37-08B Room 5 Sink Faucet	8/13/16 13:27	9/7/16 11:47	609010102	LEAD	7 PPB	15 PPB
37-26B Room 9 Sink Faucet	8/13/16 14:11	9/7/16 11:47	609010103	LEAD	1 PPB	15 PPB
37-33B Room 12 Sink Faucet	8/13/16 14:23	9/7/16 11:47	609010104	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (C) Sample Data
McKinley Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Limit
37-05C Media Center Office (108B) Sink Faucet	10/27/16 5:10	10/28/2016	65863	LEAD	11 PPB	15 PPB
37-08C Room 5 Sink Faucet	10/27/16 5:12	10/28/2016	65864	LEAD	5 PPB	15 PPB
37-26C Room 9 Sink Faucet	10/27/16 5:14	10/28/2016	65865	LEAD	8 PPB	15 PPB
37-33C Room 12 Sink Faucet	10/27/16 5:16	10/28/2016	65866	LEAD	4 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level