

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
McNary High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Tested For	Results	Action Level
038-01A Girls Locker Drinking Fountain (1)	7/30/16 11:00	8/10/16 18:43	608012301	LEAD	2 PPB	15 PPB
038-02A Girls Locker Drinking Fountain (2)	7/30/16 11:02	8/11/16 17:49	608012302	LEAD	< 1 PPB	15 PPB
038-03A Weight Room Sink Faucet	7/30/16 11:05	8/10/16 18:43	608012303	LEAD	6 PPB	15 PPB
038-04A Weight Room Drinking Fountain	7/30/16 11:07	8/10/16 18:43	608012304	LEAD	2 PPB	15 PPB
038-07A Boys Locker Drinking Fountain (1)	7/30/16 11:11	8/10/16 18:43	608012305	LEAD	8 PPB	15 PPB
038-08A Boys Locker Drinking Fountain (2)	7/30/16 11:13	8/10/16 18:43	608012306	LEAD	5 PPB	15 PPB
038-09A Boys Locker Drinking Fountain (3)	7/30/16 11:15	8/10/16 18:43	608012307	LEAD	5 PPB	15 PPB
038-10A Trainers Room Ice Maker	7/30/16 11:18	8/10/16 18:43	608012308	LEAD	< 1 PPB	15 PPB
038-11A Trainers Room Sink Faucet	7/30/16 11:20	8/10/16 18:43	608012309	LEAD	1 PPB	15 PPB
038-12A Room 129 Sink Faucet (1)	7/30/16 10:23	8/10/16 18:43	608012310	LEAD	3 PPB	15 PPB
038-13A Room 129 Sink Faucet (2)	7/30/16 10:25	8/10/16 18:44	608012311	LEAD	6 PPB	15 PPB
038-14A Home Economics 158 Sink Faucet (1)	7/30/16 10:30	8/10/16 18:44	608012312	LEAD	1 PPB	15 PPB
038-15A Home Economics 158 Sink Faucet (2)	7/30/16 10:32	8/10/16 18:44	608012313	LEAD	1 PPB	15 PPB
038-16A Home Economics 158 Sink Faucet (3)	7/30/16 10:34	8/10/16 18:44	608012314	LEAD	1 PPB	15 PPB
038-17A Home Economics 158 Sink Faucet (4)	7/30/16 10:36	8/10/16 18:44	608012315	LEAD	2 PPB	15 PPB
038-18A Home Economics 158 Sink Faucet (5)	7/30/16 10:38	8/10/16 18:44	608012316	LEAD	< 1 PPB	15 PPB
038-19A Home Economics 158 Sink Faucet (6)	7/30/16 10:40	8/10/16 18:44	608012317	LEAD	1 PPB	15 PPB
038-20A Home Economics 158 Sink Faucet (7)	7/30/16 10:42	8/10/16 18:44	608012318	LEAD	7 PPB	15 PPB
038-21A Home Economics 158 Ice Maker	7/30/16 10:44	8/10/16 18:44	608012319	LEAD	< 1 PPB	15 PPB
038-22A Kitchen Food Prep Sink Faucet (1)	7/30/16 10:47	8/10/16 18:44	608012320	LEAD	< 1 PPB	15 PPB
038-23A Kitchen Food Prep Sink Faucet (2)	7/30/16 10:49	8/10/16 18:44	608012321	LEAD	1 PPB	15 PPB
038-24A Kitchen Food Prep Sink Faucet (3)	7/30/16 10:51	8/10/16 18:44	608012322	LEAD	1 PPB	15 PPB
038-25A Kitchen Ice Maker	7/30/16 10:53	8/10/16 18:44	608012323	LEAD	< 1 PPB	15 PPB
038-26A Cafeteria Drinking Fountain (1)	7/30/16 10:55	8/10/16 18:44	608012324	LEAD	1 PPB	15 PPB
038-27A Cafeteria Drinking Fountain (2)	7/30/16 10:57	8/10/16 18:44	608012325	LEAD	2 PPB	15 PPB
038-28A Cafeteria Grill Sink Faucet	7/30/16 10:59	8/10/16 18:44	608012326	LEAD	2 PPB	15 PPB
038-29A Hallway Drinking Fountain 1	7/30/16 11:02	8/10/16 18:44	608012327	LEAD	8 PPB	15 PPB
038-30A Faculty Work Room Sink Faucet	7/30/16 11:04	8/10/16 18:45	608012328	LEAD	4 PPB	15 PPB
038-31A Celtic Shop Sink Faucet	7/30/16 10:49	8/10/16 18:45	608012329	LEAD	1 PPB	15 PPB
038-32A Make-up Sink Faucet (1)	7/30/16 10:51	8/10/16 18:45	608012330	LEAD	< 1 PPB	15 PPB
038-33A Make-up Sink Faucet (2)	7/30/16 10:53	8/10/16 18:45	608012331	LEAD	< 1 PPB	15 PPB
038-34A Library Break Room Sink Faucet	7/30/16 10:55	8/10/16 18:45	608012332	LEAD	3 PPB	15 PPB
038-35A Hallway Drinking Fountain 2	7/30/16 10:58	8/10/16 18:45	608012333	LEAD	1 PPB	15 PPB
038-36A Hallway Drinking Fountain 3	7/30/16 11:05	8/10/16 18:45	608012334	LEAD	2 PPB	15 PPB
038-37A Hallway Drinking Fountain 4	7/30/16 11:07	8/10/16 18:45	608012335	LEAD	2 PPB	15 PPB
038-38A Hallway Drinking Fountain 5	7/30/16 11:09	8/10/16 18:45	608012336	LEAD	4 PPB	15 PPB
038-39A Hallway Drinking Fountain 6	7/30/16 11:11	8/10/16 18:45	608012337	LEAD	2 PPB	15 PPB
038-40A Room 114 Sink Faucet	7/30/16 11:14	8/10/16 18:45	608012338	LEAD	5 PPB	15 PPB
038-41A Hallway Drinking Fountain 7	7/30/16 11:15	8/10/16 18:45	608012339	LEAD	3 PPB	15 PPB
038-42A Hallway Drinking Fountain 8	7/30/16 11:17	8/10/16 18:45	608012341	LEAD	2 PPB	15 PPB
038-43A Classroom 143 Sink Faucet	7/30/16 11:20	8/10/16 18:45	608012342	LEAD	8 PPB	15 PPB
038-44A Classroom 143 Drinking Fountain	7/30/16 11:22	8/10/16 18:45	608012343	LEAD	4 PPB	15 PPB
038-45A Classroom 145 Sink Faucet	7/30/16 11:25	8/10/16 18:45	608012344	LEAD	3 PPB	15 PPB
038-46A Classroom 145 Drinking Fountain	7/30/16 11:27	8/10/16 18:45	608012345	LEAD	4 PPB	15 PPB
038-47A Classroom 147 Sink Faucet	7/30/16 11:30	8/10/16 18:45	608012346	LEAD	3 PPB	15 PPB
038-48A Classroom 147 Drinking Fountain	7/30/16 11:32	8/10/16 18:45	608012347	LEAD	3 PPB	15 PPB
038-49A Hallway Drinking Fountain 9	7/30/16 11:36	8/10/16 18:45	608012348	LEAD	3 PPB	15 PPB
038-50A Hallway Drinking Fountain 10	7/30/16 11:38	8/10/16 18:46	608012349	LEAD	2 PPB	15 PPB
038-51A Classroom 231 Drinking Fountain	7/30/16 11:41	8/10/16 18:46	608012350	LEAD	7 PPB	15 PPB
038-52A Classroom 231 Sink Faucet	7/30/16 11:43	8/10/16 18:46	608012351	LEAD	7 PPB	15 PPB
038-53A Classroom 233 Sink Faucet	7/30/16 11:46	8/10/16 18:46	608012352	LEAD	800 PPB	15 PPB
038-54A Classroom 216 Sink Faucet	7/30/16 11:49	8/10/16 18:46	608012353	LEAD	2 PPB	15 PPB
038-55A Lounge Sink Faucet	7/30/16 11:51	8/10/16 18:46	608012354	LEAD	3 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
McNary High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Tested For	Results	Action Level
038-57A Classroom 210 Sink Faucet	7/30/16 11:55	8/10/16 18:46	608012355	LEAD	4 PPB	15 PPB
038-58A Hallway Drinking Fountain 9A	7/30/16 11:57	8/10/16 18:46	608012356	LEAD	2 PPB	15 PPB
038-59A Hallway Drinking Fountain 10A	7/30/16 11:58	8/10/16 18:46	608012357	LEAD	3 PPB	15 PPB
038-60A Hallway Drinking Fountain 11	7/30/16 12:01	8/10/16 18:46	608012358	LEAD	3 PPB	15 PPB
038-61A Hallway Drinking Fountain 12	7/30/16 12:03	8/10/16 18:46	608012359	LEAD	3 PPB	15 PPB
038-62A Room 254 Sink Faucet	7/30/16 12:06	8/10/16 18:46	608012360	LEAD	6 PPB	15 PPB
038-63A Hallway Drinking Fountain 13	7/30/16 12:09	8/10/16 18:46	608012361	LEAD	10 PPB	15 PPB
038-64A Hallway Drinking Fountain 14	7/30/16 12:11	8/10/16 18:46	608012362	LEAD	9 PPB	15 PPB
038-65A Upper Gymnasium Drinking Fountain (1)	7/30/16 12:14	8/10/16 18:46	608012363	LEAD	6 PPB	15 PPB
038-66A Upper Gymnasium Drinking Fountain (1)	7/30/16 12:16	8/10/16 18:46	608012364	LEAD	4 PPB	15 PPB
038-67A Hallway Drinking Fountain 15	7/30/16 12:20	8/10/16 18:46	608012365	LEAD	3 PPB	15 PPB
038-68A Hallway Drinking Fountain 16	7/30/16 12:22	8/10/16 18:46	608012366	LEAD	3 PPB	15 PPB
038-69A Room 245 Sink Faucet	7/30/16 12:25	8/10/16 18:46	608012367	LEAD	11 PPB	15 PPB
038-70A Hallway Drinking Fountain 15A	7/30/16 11:00	8/10/16 18:46	608012368	LEAD	3 PPB	15 PPB
038-71A Hallway Drinking Fountain 16A	7/30/16 11:02	8/10/16 18:47	608012369	LEAD	4 PPB	15 PPB
038-72A Stadium Concessions Sink Faucet (1)	7/30/16 11:10	8/10/16 18:47	608012370	LEAD	2 PPB	15 PPB
038-73A Stadium Concessions Sink Faucet (2)	7/30/16 11:12	8/10/16 18:47	608012371	LEAD	3 PPB	15 PPB
038-74A Stadium Concessions Sink Faucet (3)	7/30/16 11:14	8/10/16 18:47	608012372	LEAD	7 PPB	15 PPB
038-75A Pedestal Drinking Fountain (Baseball Field)	7/30/16 11:17	8/10/16 18:47	608012373	LEAD	< 1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
McNary High School

Sample Identification # and Location	Date & Time Collected	Date Analyzed	Container ID	Tested For	Results	Action Level
038-89A Training Room Whirlpool Wall Mount Fixture	6/9/17 5:01	6/13/2017	31024	LEAD	2 PPB	15 PPB
038-90A Room 244 Sink Faucet	6/9/17 5:13	6/13/2017	31025	LEAD	10 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
 Lead Water Sampling Results
 First Draw (A) Sample Data
 McNary High School

Sample Identification # and Location	Date & Time Collected	Date Analyzed	Container ID	Tested For	Results	Action Level
038-91A Room 265 Sink Faucet 1 (left)	1/5/2018 6:36:00AM	1/8/2018	886	LEAD	5 PPB	15 PPB
038-92A Room 265 Sink Faucet 2 (right)	1/5/2018 6:38:00AM	1/8/2018	887	LEAD	4 PPB	15 PPB
038-93A Room 266 Sink Faucet	1/5/2018 6:40:00AM	1/8/2018	888	LEAD	46 PPB	15 PPB
038-94A Cafeteria Drinking Fountain w/95	1/5/2018 6:50:00AM	1/8/2018	889	LEAD	<1 PPB	15 PPB
038-95A Cafeteria Bottle Filler w/94	1/5/2018 6:52:00AM	1/8/2018	890	LEAD	<1 PPB	15 PPB
038-96A 2nd Floor Hall Drinking Fountain w/97	1/5/2018 6:47:00AM	1/8/2018	891	LEAD	<1 PPB	15 PPB
038-97A 2nd Floor Hall Bottle Filler w/96	1/5/2018 6:49:00AM	1/8/2018	892	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (C) Sample Data
McNary High School

Sample Identification # and Location	Date & Time Collected	Date Analyzed	Container ID	Tested For	Results	Action Level
038-93C Classroom 266 Sink Faucet	2/2/2018 5:27:00AM	2/6/2018	7734	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level