

Salem Keizer School District
Copper Water Sampling Results
A (First Draw) Sample Data
Miller Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
39-01A Kitchen Sink Faucet	7/26/16 14:30	8/2/16 15:43	607271601	COPPER	0.1 PPM	1.3 PPM
39-02A Gymnasium Bottle Fill Station	7/26/16 14:32	8/2/16 15:43	607271602	COPPER	0.3 PPM	1.3 PPM
39-03A Gymnasium Drinking Fountain	7/26/16 14:34	8/2/16 15:43	607271603	COPPER	0.3 PPM	1.3 PPM
39-04A Music Room Sink Faucet	7/26/16 14:36	8/2/16 17:09	607271604	COPPER	0.3 PPM	1.3 PPM
39-05A Music Room Drining Fountain	7/26/16 14:38	8/2/16 17:09	607271605	COPPER	0.4 PPM	1.3 PPM
39-06A Cafeteria Hall Restroom Drinking Fountain (Left)	7/26/16 14:40	8/2/16 17:09	607271606	COPPER	0.2 PPM	1.3 PPM
39-07A Cafeteria Hall Restroom Drinking Fountain (Right)	7/26/16 14:42	8/2/16 17:09	607271607	COPPER	0.2 PPM	1.3 PPM
39-08A Health Room Sink Faucet	7/26/16 14:44	8/2/16 17:09	607271608	COPPER	0.3 PPM	1.3 PPM
39-09A Health Room Drinking Fountain	7/26/16 14:46	8/2/16 17:10	607271609	COPPER	0.2 PPM	1.3 PPM
39-10A Office Work Room Sink Faucet	7/26/16 14:48	8/2/16 17:10	607271610	COPPER	0.2 PPM	1.3 PPM
39-11A Office Work Room Drinking Fountain	7/26/16 14:50	8/2/16 17:10	607271611	COPPER	0.2 PPM	1.3 PPM
39-12A Staff Lounge Sink Faucet	7/26/16 14:52	8/2/16 17:11	607271612	COPPER	0.3 PPM	1.3 PPM
39-13A A-1 Sink Faucet	7/26/16 14:55	8/2/16 17:36	607271613	COPPER	0.4 PPM	1.3 PPM
39-14A A-1 Drinking Fountain	7/26/16 14:55	8/2/16 17:17	607271614	COPPER	0.3 PPM	1.3 PPM
39-15A A-2 Sink Faucet	7/26/16 14:57	8/2/16 17:17	607271615	COPPER	0.2 PPM	1.3 PPM
39-16A A-2 Drinking Fountain	7/26/16 14:57	8/2/16 17:17	607271616	COPPER	0.3 PPM	1.3 PPM
39-17A A-3 Sink Faucet	7/26/16 14:59	8/2/16 17:17	607271617	COPPER	0.4 PPM	1.3 PPM
39-18A A-3 Drinking Fountain	7/26/16 14:59	8/2/16 17:17	607271618	COPPER	0.3 PPM	1.3 PPM
39-19A A-4 Sink Faucet	7/26/16 15:01	8/2/16 17:17	607271619	COPPER	0.3 PPM	1.3 PPM
39-20A A-4 Drinking Fountain	7/26/16 15:01	8/2/16 17:17	607271620	COPPER	0.3 PPM	1.3 PPM
39-21A A-5 Sink Faucet	7/26/16 15:03	8/2/16 17:17	607271621	COPPER	0.3 PPM	1.3 PPM
39-22A A-5 Drinking Fountain	7/26/16 15:03	8/2/16 17:18	607271622	COPPER	0.3 PPM	1.3 PPM
39-23A A-6 Sink Faucet	7/26/16 15:05	8/2/16 17:18	607271623	COPPER	0.3 PPM	1.3 PPM
39-24A A-6 Drink Fountain	7/26/16 15:05	8/2/16 17:22	607271624	COPPER	0.4 PPM	1.3 PPM
39-25A A-7 Sink Faucet	7/26/16 15:07	8/2/16 17:22	607271625	COPPER	0.4 PPM	1.3 PPM
39-26A A-7 Drinking Fountain	7/26/16 15:07	8/2/16 17:23	607271626	COPPER	0.4 PPM	1.3 PPM
39-27A Library Sink Faucet	7/26/16 15:09	8/2/16 17:23	607271627	COPPER	0.4 PPM	1.3 PPM
39-28A C-1 Sink Faucet	7/26/16 15:11	8/2/16 17:23	607271628	COPPER	0.3 PPM	1.3 PPM
39-29A C-1 Drinking Fountain	7/26/16 15:11	8/2/16 17:23	607271629	COPPER	0.4 PPM	1.3 PPM
39-30A C-2 Sink Faucet	7/26/16 15:13	8/2/16 17:23	607271630	COPPER	0.3 PPM	1.3 PPM
39-31A C-2 Drinking Fountain	7/26/16 15:13	8/2/16 17:23	607271631	COPPER	0.5 PPM	1.3 PPM
39-32A C-3 Sink Faucet	7/26/16 15:15	8/2/16 17:23	607271632	COPPER	0.3 PPM	1.3 PPM
39-33A C-3 Drinking Fountain	7/26/16 15:15	8/2/16 17:23	607271633	COPPER	0.4 PPM	1.3 PPM
39-34A C-4 Sink Faucet	7/26/16 15:17	8/2/16 17:29	607271634	COPPER	0.4 PPM	1.3 PPM
39-35A C-4 Drinking Fountain	7/26/16 15:17	8/2/16 17:29	607271635	COPPER	0.5 PPM	1.3 PPM
39-36A C-5 Sink Faucet	7/26/16 15:19	8/2/16 17:29	607271636	COPPER	0.4 PPM	1.3 PPM
39-37A C-5 Drinking Fountain	7/26/16 15:19	8/2/16 17:29	607271637	COPPER	0.4 PPM	1.3 PPM
39-38A C-6 Sink Faucet	7/26/16 15:21	8/2/16 17:30	607271638	COPPER	0.4 PPM	1.3 PPM
39-39A C-6 Drinking Fountain	7/26/16 15:21	8/2/16 17:30	607271639	COPPER	0.5 PPM	1.3 PPM
39-40A B-1 Sink Faucet	7/26/16 15:23	8/2/16 17:30	607271640	COPPER	0.4 PPM	1.3 PPM
39-41A B-1 Drinking Fountain	7/26/16 15:23	8/2/16 17:30	607271641	COPPER	0.6 PPM	1.3 PPM
39-42A B-2 Sink Faucet	7/26/16 15:25	8/2/16 17:30	607271642	COPPER	0.4 PPM	1.3 PPM
39-43A B-2 Drinking Fountain	7/26/16 15:25	8/2/16 17:30	607271643	COPPER	0.5 PPM	1.3 PPM
39-44A B-3 Sink Faucet	7/26/16 15:27	8/2/16 17:35	607271644	COPPER	0.4 PPM	1.3 PPM
39-45A B-3 Drinking Fountain	7/26/16 15:27	8/2/16 17:35	607271645	COPPER	0.4 PPM	1.3 PPM
39-46A B-4 Sink Faucet	7/26/16 15:29	8/2/16 17:35	607271646	COPPER	0.5 PPM	1.3 PPM
39-47A B-4 Drinking Fountain	7/26/16 15:29	8/2/16 17:35	607271647	COPPER	0.5 PPM	1.3 PPM
39-48A B-5 Sink Faucet	7/26/16 15:31	8/2/16 17:35	607271648	COPPER	0.5 PPM	1.3 PPM
39-49A B-5 Drinking Fountain	7/26/16 15:31	8/2/16 17:35	607271649	COPPER	0.4 PPM	1.3 PPM
39-50A B-6 Sink Faucet	7/26/16 15:33	8/2/16 17:35	607271650	COPPER	0.3 PPM	1.3 PPM
39-51A B-6 Drinking Fountain	7/26/16 15:33	8/2/16 17:35	607271651	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level