

Salem Keizer School District
Lead Water Sampling Results
A (First Draw) Sample Data
Miller Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
39-01A Kitchen Sink Faucet	7/26/16 14:30	8/2/16 15:43	607271601	LEAD	2 PPB	15 PPB
39-02A Gymnasium Bottle Fill Station	7/26/16 14:32	8/2/16 15:43	607271602	LEAD	1 PPB	15 PPB
39-03A Gymnasium Drinking Fountain	7/26/16 14:34	8/2/16 15:43	607271603	LEAD	1 PPB	15 PPB
39-04A Music Room Sink Faucet	7/26/16 14:36	8/2/16 17:09	607271604	LEAD	3 PPB	15 PPB
39-05A Music Room Drining Fountain	7/26/16 14:38	8/2/16 17:09	607271605	LEAD	< 1 PPB	15 PPB
39-06A Cafeteria Hall Restroom Drinking Fountain (Left)	7/26/16 14:40	8/2/16 17:09	607271606	LEAD	< 1 PPB	15 PPB
39-07A Cafeteria Hall Restroom Drinking Fountain (Right)	7/26/16 14:42	8/2/16 17:09	607271607	LEAD	< 1 PPB	15 PPB
39-08A Health Room Sink Faucet	7/26/16 14:44	8/2/16 17:09	607271608	LEAD	3 PPB	15 PPB
39-09A Health Room Drinking Fountain	7/26/16 14:46	8/2/16 17:10	607271609	LEAD	< 1 PPB	15 PPB
39-10A Office Work Room Sink Faucet	7/26/16 14:48	8/2/16 17:10	607271610	LEAD	4 PPB	15 PPB
39-11A Office Work Room Drinking Fountain	7/26/16 14:50	8/2/16 17:10	607271611	LEAD	< 1 PPB	15 PPB
39-12A Staff Lounge Sink Faucet	7/26/16 14:52	8/2/16 17:11	607271612	LEAD	< 1 PPB	15 PPB
39-13A A-1 Sink Faucet	7/26/16 14:55	8/2/16 17:36	607271613	LEAD	3 PPB	15 PPB
39-14A A-1 Drinking Fountain	7/26/16 14:55	8/2/16 17:17	607271614	LEAD	< 1 PPB	15 PPB
39-15A A-2 Sink Faucet	7/26/16 14:57	8/2/16 17:17	607271615	LEAD	2 PPB	15 PPB
39-16A A-2 Drinking Fountains	7/26/16 14:57	8/2/16 17:17	607271616	LEAD	< 1 PPB	15 PPB
39-17A A-3 Sink Faucet	7/26/16 14:59	8/2/16 17:17	607271617	LEAD	1 PPB	15 PPB
39-18A A-3 Drinking Fountain	7/26/16 14:59	8/2/16 17:17	607271618	LEAD	< 1 PPB	15 PPB
39-19A A-4 Sink Faucet	7/26/16 15:01	8/2/16 17:17	607271619	LEAD	1 PPB	15 PPB
39-20A A-4 Drinking Fountain	7/26/16 15:01	8/2/16 17:17	607271620	LEAD	< 1 PPB	15 PPB
39-21A A-5 Sink Faucet	7/26/16 15:03	8/2/16 17:17	607271621	LEAD	5 PPB	15 PPB
39-22A A-5 Drinking Fountains	7/26/16 15:03	8/2/16 17:18	607271622	LEAD	< 1 PPB	15 PPB
39-23A A-6 Sink Faucet	7/26/16 15:05	8/2/16 17:18	607271623	LEAD	6 PPB	15 PPB
39-24A A-6 Drinking Fountain	7/26/16 15:05	8/2/16 17:22	607271624	LEAD	2 PPB	15 PPB
39-25A A-7 Sink Faucet	7/26/16 15:07	8/2/16 17:22	607271625	LEAD	< 1 PPB	15 PPB
39-26A A-7 Drinking Fountain	7/26/16 15:07	8/2/16 17:23	607271626	LEAD	5 PPB	15 PPB
39-27A Library Sink Faucet	7/26/16 15:09	8/2/16 17:23	607271627	LEAD	< 1 PPB	15 PPB
39-28A C-1 Sink Faucet	7/26/16 15:11	8/2/16 17:23	607271628	LEAD	2 PPB	15 PPB
39-29A C-1 Drinking Fountain	7/26/16 15:11	8/2/16 17:23	607271629	LEAD	< 1 PPB	15 PPB
39-30A C-2 Sink Faucet	7/26/16 15:13	8/2/16 17:23	607271630	LEAD	3 PPB	15 PPB
39-31A C-2 Drinking Fountain	7/26/16 15:13	8/2/16 17:23	607271631	LEAD	< 1 PPB	15 PPB
39-32A C-3 Sink Faucet	7/26/16 15:15	8/2/16 17:23	607271632	LEAD	2 PPB	15 PPB
39-33A C-3 Drinking Fountain	7/26/16 15:15	8/2/16 17:23	607271633	LEAD	< 1 PPB	15 PPB
39-34A C-4 Sink Faucet	7/26/16 15:17	8/2/16 17:29	607271634	LEAD	2 PPB	15 PPB
39-35A C-4 Drinking Fountain	7/26/16 15:17	8/2/16 17:29	607271635	LEAD	< 1 PPB	15 PPB
39-36A C-5 Sink Faucet	7/26/16 15:19	8/2/16 17:29	607271636	LEAD	1 PPB	15 PPB
39-37A C-5 Drinking Fountain	7/26/16 15:19	8/2/16 17:29	607271637	LEAD	< 1 PPB	15 PPB
39-38A C-6 Sink Faucet	7/26/16 15:21	8/2/16 17:30	607271638	LEAD	2 PPB	15 PPB
39-39A C-6 Drinking Fountain	7/26/16 15:21	8/2/16 17:30	607271639	LEAD	< 1 PPB	15 PPB
39-40A B-1 Sink Faucet	7/26/16 15:23	8/2/16 17:30	607271640	LEAD	2 PPB	15 PPB
39-41A B-1 Drinking Fountain	7/26/16 15:23	8/2/16 17:30	607271641	LEAD	< 1 PPB	15 PPB
39-42A B-2 Sink Faucet	7/26/16 15:25	8/2/16 17:30	607271642	LEAD	2 PPB	15 PPB
39-43A B-2 Drinking Fountain	7/26/16 15:25	8/2/16 17:30	607271643	LEAD	5 PPB	15 PPB
39-44A B-3 Sink Faucet	7/26/16 15:27	8/2/16 17:35	607271644	LEAD	3 PPB	15 PPB
39-45A B-3 Drinking Fountain	7/26/16 15:27	8/2/16 17:35	607271645	LEAD	< 1 PPB	15 PPB
39-46A B-4 Sink Faucet	7/26/16 15:29	8/2/16 17:35	607271646	LEAD	2 PPB	15 PPB
39-47A B-4 Drinking Fountain	7/26/16 15:29	8/2/16 17:35	607271647	LEAD	< 1 PPB	15 PPB
39-48A B-5 Sink Faucet	7/26/16 15:31	8/2/16 17:35	607271648	LEAD	4 PPB	15 PPB
39-49A B-5 Drinking Fountain	7/26/16 15:31	8/2/16 17:35	607271649	LEAD	< 1 PPB	15 PPB
39-50A B-6 Sink Faucet	7/26/16 15:33	8/2/16 17:35	607271650	LEAD	2 PPB	15 PPB
39-51A B-6 Drinking Fountain	7/26/16 15:33	8/2/16 17:35	607271651	LEAD	< 1 PPB	15 PPB

Salem Keizer School District
Lead Water Sampling Results
A (First Draw) Sample Data
Miller Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
--------------------------------------	-------------------	--------------------	--------------	------------	---------	--------------

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level