

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Results
Morningside Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Tested For	Result	Action Level
030-01A	Room 19 Sink Faucet	7/14/16 12:02	7/24/2016	1607815-01A	LEAD 2	PPB 15 PPB
030-02A	Room 19 Drinking Fountain	7/14/16 12:04	7/24/2016	1607815-02A	LEAD 4	PPB 15 PPB
030-03A	Hall 80 Refrigerated Drinking Fountain 1	7/14/16 12:07	7/24/2016	1607815-03A	LEAD <1.0	PPB 15 PPB
030-04A	Room 18 Sink Faucet	7/14/16 12:10	7/24/2016	1607815-04A	LEAD 6	PPB 15 PPB
030-05A	Room 18 Drinking Fountain	7/14/16 12:12	7/24/2016	1607815-05A	LEAD 3	PPB 15 PPB
030-06A	Room 16 Sink Faucet	7/14/16 12:15	7/24/2016	1607815-06A	LEAD 1	PPB 15 PPB
030-07A	Room 16 Drinking Fountain	7/14/16 12:17	7/24/2016	1607815-07A	LEAD 4	PPB 15 PPB
030-08A	Room 17 Sink Faucet	7/14/16 12:20	7/24/2016	1607815-08A	LEAD 2	PPB 15 PPB
030-09A	Room 17 Drinking Fountain	7/14/16 12:22	7/24/2016	1607815-09A	LEAD 4	PPB 15 PPB
030-10A	Speech Room 63 Sink Faucet	7/14/16 12:26	7/24/2016	1607815-10A	LEAD <1.0	PPB 15 PPB
030-11A	Room 9 Sink Faucet	7/14/16 12:29	7/24/2016	1607815-11A	LEAD 2	PPB 15 PPB
030-12A	Room 9 Drinking Fountain	7/14/16 12:31	7/24/2016	1607815-12A	LEAD 2	PPB 15 PPB
030-13A	Room 8 Sink Faucet	7/14/16 12:35	7/24/2016	1607815-13A	LEAD 2	PPB 15 PPB
030-14A	Room 8 Drinking Fountain	7/14/16 12:37	7/24/2016	1607815-14A	LEAD 2	PPB 15 PPB
030-15A	Room 7 Sink Faucet	7/14/16 12:40	7/24/2016	1607815-15A	LEAD 2	PPB 15 PPB
030-16A	Room 7 Drinking Fountain	7/14/16 12:42	7/24/2016	1607815-16A	LEAD 4	PPB 15 PPB
030-17A	Hall 41 Drinking Fountain	7/14/16 12:44	7/24/2016	1607815-17A	LEAD 4	PPB 15 PPB
030-18A	Room 10 Sink Faucet	7/14/16 12:48	7/24/2016	1607815-18A	LEAD 3	PPB 15 PPB
030-19A	Room 10 Drinking Fountain	7/14/16 12:50	7/24/2016	1607815-19A	LEAD 2	PPB 15 PPB
030-20A	Room 6 Sink Faucet	7/14/16 12:53	7/24/2016	1607815-20A	LEAD 2	PPB 15 PPB
030-21A	Room 6 Drinking Fountain	7/14/16 12:55	7/24/2016	1607815-21A	LEAD 5	PPB 15 PPB
030-22A	Room 11 Sink Faucet	7/14/16 12:59	7/24/2016	1607815-22A	LEAD 3	PPB 15 PPB
030-23A	Room 11 Drinking Fountain	7/14/16 13:01	7/24/2016	1607815-23A	LEAD 2	PPB 15 PPB
030-24A	Room 5 Sink Faucet	7/14/16 13:04	7/24/2016	1607815-24A	LEAD 2	PPB 15 PPB
030-25A	Room 5 Drinking Fountain	7/14/16 13:06	7/24/2016	1607815-25A	LEAD 3	PPB 15 PPB
030-26A	Room 4 Sink Faucet	7/14/16 13:10	7/24/2016	1607815-26A	LEAD 2	PPB 15 PPB
030-27A	Room 4 Drinking Fountain	7/14/16 13:12	7/24/2016	1607815-27A	LEAD 3	PPB 15 PPB
030-28A	Hall 47 Drinking Fountain 3	7/14/16 13:15	7/24/2016	1607815-28A	LEAD 3	PPB 15 PPB
030-29A	Room 3 Sink Faucet	7/14/16 13:19	7/24/2016	1607815-29A	LEAD 1	PPB 15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Results
Morningside Elementary School

030-30A	Room 3 Drinking Fountain	7/14/16 13:21	7/24/2016	1607815-30A	LEAD	3	PPB	15 PPB
030-31A	Room 12 Sink Faucet	7/14/16 13:25	7/24/2016	1607815-31A	LEAD	2	PPB	15 PPB
030-32A	Room 12 Drinking Fountain	7/14/16 13:27	7/24/2016	1607815-32A	LEAD	3	PPB	15 PPB
030-33A	Room 2 Sink Faucet	7/14/16 13:30	7/24/2016	1607815-33A	LEAD	3	PPB	15 PPB
030-34A	Room 2 Drinking Fountain	7/14/16 13:32	7/24/2016	1607815-34A	LEAD	2	PPB	15 PPB
030-35A	Room 13 Sink Faucet	7/14/16 13:36	7/24/2016	1607815-35A	LEAD	<1.0	PPB	15 PPB
030-36A	Room 13 Drinking Fountain	7/14/16 13:38	7/24/2016	1607815-36A	LEAD	3	PPB	15 PPB
030-37A	Room 1 Sink Faucet	7/14/16 13:43	7/24/2016	1607815-37A	LEAD	<1.0	PPB	15 PPB
030-38A	Room 1 Drinking Fountain	7/14/16 13:45	7/24/2016	1607815-38A	LEAD	3	PPB	15 PPB
030-39A	Room 14 Sink Faucet	7/14/16 13:49	7/24/2016	1607815-39A	LEAD	1	PPB	15 PPB
030-40A	Room 14 Drinking Fountain	7/14/16 13:51	7/24/2016	1607815-40A	LEAD	<1.0	PPB	15 PPB
030-41A	Room 15 Sink Faucet	7/14/16 13:55	7/24/2016	1607815-41A	LEAD	2	PPB	15 PPB
030-42A	Room 15 Drinking Fountain	7/14/16 13:57	7/24/2016	1607815-42A	LEAD	3	PPB	15 PPB
030-43A	Music Room Sink Faucet	7/14/16 14:03	7/24/2016	1607815-43A	LEAD	6	PPB	15 PPB
030-44A	Hall Refrigerated Drinking Fountain	7/14/16 14:00	7/24/2016	1607815-44A	LEAD	<1.0	PPB	15 PPB
030-45A	Kitchen Food Prep Sink Faucet	7/14/16 14:06	7/24/2016	1607815-45A	LEAD	2	PPB	15 PPB
030-46A	Multi-Purpose Room Drinking Fountain	7/14/16 14:09	7/24/2016	1607815-46A	LEAD	3	PPB	15 PPB
030-47A	Hall 20 Drinking Fountain 5	7/14/16 14:17	7/24/2016	1607815-47A	LEAD	2	PPB	15 PPB
030-48A	Staff Lounge Sink Faucet	7/14/16 14:22	7/24/2016	1607815-48A	LEAD	<1.0	PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level