

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Myers Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level	
63-01A	Room 10 Faculty Sink Faucet	8/6/16 8:00	8/14/2016	1608459-01A	COPPER	0.0 PPM	1.3 PPM
63-02A	Hall Near Gymnasium Water Fountain 1	8/6/16 8:02	8/14/2016	1608459-02A	COPPER	0.1 PPM	1.3 PPM
63-03A	Gymnasium by Double Doors Drinking Fountain 2	8/6/16 8:03	8/14/2016	1608459-03A	COPPER	0.0 PPM	1.3 PPM
63-04A	Hall by Boiler Room Restroom Drinking Fountain 3	8/6/16 8:06	8/14/2016	1608459-04A	COPPER	0.0 PPM	1.3 PPM
63-05A	Room 115 Sink Faucet	8/6/16 8:08	8/10/2016	1608459-05A	COPPER	0.0 PPM	1.3 PPM
63-06A	Room 116 Sink Faucet	8/6/16 8:11	8/10/2016	1608459-06A	COPPER	0.0 PPM	1.3 PPM
63-07A	Room 116 Drinking Fountain	8/6/16 8:11	8/14/2016	1608459-07A	COPPER	0.0 PPM	1.3 PPM
63-08A	Room 117 Sink Faucet	8/6/16 8:13	8/14/2016	1608459-08A	COPPER	0.0 PPM	1.3 PPM
63-09A	Room 117 Drinking Fountain	8/6/16 8:13	8/14/2016	1608459-09A	COPPER	0.0 PPM	1.3 PPM
63-10A	Room 118 Sink Faucet	8/6/16 8:17	8/14/2016	1608459-10A	COPPER	0.0 PPM	1.3 PPM
63-11A	Room 118 Drinking Fountain	8/6/16 8:17	8/14/2016	1608459-11A	COPPER	0.0 PPM	1.3 PPM
63-12A	Room 119 Sink Faucet	8/6/16 8:19	8/14/2016	1608459-12A	COPPER	0.0 PPM	1.3 PPM
63-13A	Room 119 Drinking Fountain	8/6/16 8:19	8/14/2016	1608459-13A	COPPER	0.0 PPM	1.3 PPM
63-14A	Room 120 Sink Faucet	8/6/16 8:24	8/10/2016	1608459-14A	COPPER	0.2 PPM	1.3 PPM
63-15A	Room 120 Drinking Fountain	8/6/16 8:24	8/14/2016	1608459-15A	COPPER	0.0 PPM	1.3 PPM
63-16A	Room 121 Sink Faucet	8/6/16 8:22	8/10/2016	1608459-16A	COPPER	0.2 PPM	1.3 PPM
63-17A	Room 122 Drinking Fountain	8/6/16 8:27	8/14/2016	1608459-17A	COPPER	0.1 PPM	1.3 PPM
63-18A	Entry to Girls Restroom Drinking Fountain 4	8/6/16 8:29	8/14/2016	1608459-18A	COPPER	0.0 PPM	1.3 PPM
63-19A	Health Room Sink Faucet	8/6/16 8:32	8/10/2016	1608459-19A	COPPER	0.0 PPM	1.3 PPM
63-20A	Health Room Drinking Fountain	8/6/16 8:32	8/14/2016	1608459-20A	COPPER	0.1 PPM	1.3 PPM
63-21A	Supply Hall (132) Sink Faucet	8/6/16 8:34	8/10/2016	1608459-21A	COPPER	0.0 PPM	1.3 PPM
63-22A	AV Storage Room 100 Sink Faucet	8/6/16 8:36	8/14/2016	1608459-22A	COPPER	0.0 PPM	1.3 PPM
63-23A	Room 101 Sink Faucet	8/6/16 8:43	8/14/2016	1608459-23A	COPPER	0.0 PPM	1.3 PPM
63-24A	Room 101 Drinking Fountain	8/6/16 8:43	8/14/2016	1608459-24A	COPPER	0.0 PPM	1.3 PPM
63-25A	Room 102 Sink Faucet	8/6/16 8:46	8/14/2016	1608459-25A	COPPER	0.0 PPM	1.3 PPM
63-26A	Room 102 Drinking Fountain	8/6/16 8:46	8/14/2016	1608459-26A	COPPER	0.0 PPM	1.3 PPM
63-27A	Room 103 Sink Faucet	8/6/16 8:48	8/10/2016	1608459-27A	COPPER	0.1 PPM	1.3 PPM
63-28A	Room 103 Drinking Fountain	8/6/16 8:48	8/14/2016	1608459-28A	COPPER	0.2 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Myers Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
63-29A Hall to Restroom Drinking Fountain	8/6/16 8:54	8/14/2016	1608459-29A	COPPER	0.0 PPM	1.3 PPM
63-30A Room 105 Sink Faucet	8/6/16 8:56	8/10/2016	1608459-30A	COPPER	0.2 PPM	1.3 PPM
63-31A Room 105 Drinking Fountain	8/6/16 8:56	8/14/2016	1608459-31A	COPPER	0.2 PPM	1.3 PPM
63-32A Room 104 Sink Faucet	8/6/16 8:59	8/10/2016	1608459-32A	COPPER	0.1 PPM	1.3 PPM
63-33A Room 104 Drinking Fountain	8/6/16 8:59	8/14/2016	1608459-33A	COPPER	0.2 PPM	1.3 PPM
63-34A Room 106 Sink Faucet	8/6/16 9:02	8/10/2016	1608459-34A	COPPER	0.2 PPM	1.3 PPM
63-35A Room 106 Drinking Fountain	8/6/16 9:02	8/14/2016	1608459-35A	COPPER	0.1 PPM	1.3 PPM
63-36A Room 107 Sink Faucet	8/6/16 9:05	8/10/2016	1608459-36A	COPPER	0.1 PPM	1.3 PPM
63-37A Room 107 Drinking Fountain	8/6/16 9:05	8/14/2016	1608459-37A	COPPER	0.3 PPM	1.3 PPM
63-38A Room 110 Sink Faucet	8/6/16 9:09	8/10/2016	1608459-38A	COPPER	0.3 PPM	1.3 PPM
63-39A Room 110 Drinking Fountain	8/6/16 9:09	8/14/2016	1608459-39A	COPPER	0.3 PPM	1.3 PPM
63-40A Room 108 Sink Faucet	8/6/16 9:13	8/10/2016	1608459-40A	COPPER	0.3 PPM	1.3 PPM
63-41A Room 108 Drinking Fountain	8/6/16 9:13	8/14/2016	1608459-41A	COPPER	0.3 PPM	1.3 PPM
63-42A Room 109 Sink Faucet	8/6/16 9:20	8/14/2016	1608459-42A	COPPER	0.2 PPM	1.3 PPM
63-43A Room 109 Drinking Fountain	8/6/16 9:20	8/14/2016	1608459-43A	COPPER	0.2 PPM	1.3 PPM
63-44A Room 112 Sink Faucet	8/6/16 9:24	8/14/2016	1608459-44A	COPPER	0.1 PPM	1.3 PPM
63-45A Room 112 Drinking Fountain	8/6/16 9:24	8/14/2016	1608459-45A	COPPER	0.1 PPM	1.3 PPM
63-46A Room 111 Sink Faucet	8/6/16 9:27	8/10/2016	1608459-46A	COPPER	0.2 PPM	1.3 PPM
63-47A Room 111 Drinking Fountain	8/6/16 9:27	8/14/2016	1608459-47A	COPPER	0.4 PPM	1.3 PPM
63-48A Room 113 Sink Faucet	8/6/16 9:32	8/10/2016	1608459-48A	COPPER	0.0 PPM	1.3 PPM
63-49A Room 113 Drinking Fountain	8/6/16 9:32	8/14/2016	1608459-49A	COPPER	0.0 PPM	1.3 PPM
63-50A Portable Room 131 Drinking Fountain	8/6/16 9:42	8/14/2016	1608459-50A	COPPER	0.0 PPM	1.3 PPM
63-51A Portable Room 131 Sink Faucet	8/6/16 9:42	8/14/2016	1608459-51A	COPPER	0.0 PPM	1.3 PPM
63-52A Portable Room 132 Drinking Fountain	8/6/16 9:45	8/14/2016	1608459-52A	COPPER	0.0 PPM	1.3 PPM
63-53A Portable Room 132 Sink Faucet	8/6/16 9:45	8/14/2016	1608459-53A	COPPER	0.0 PPM	1.3 PPM
63-54A Portable Room 133 Sink Faucet	8/6/16 9:50	8/10/2016	1608459-54A	COPPER	0.1 PPM	1.3 PPM
63-55A Portable Room 133 Drinking Fountain	8/6/16 9:50	8/14/2016	1608459-55A	COPPER	0.1 PPM	1.3 PPM
63-56A Portable Room 134 Sink Faucet	8/6/16 9:52	8/10/2016	1608459-56A	COPPER	0.0 PPM	1.3 PPM

Salem-Keizer Public Schools
 Copper Water Sampling Results
 First Draw (A) Sample Data
 Myers Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
63-57A Portable Room 134 Drinking Fountain	8/6/16 9:52	8/10/2016	1608459-57A	COPPER	0.0 PPM	1.3 PPM
63-58A Food Service Galley Dish Sink Faucet	8/6/16 9:58	8/14/2016	1608459-58A	COPPER	0.0 PPM	1.3 PPM
63-59A Drinking Fountain Across from Room 116 5	8/6/16 9:36	8/14/2016	1608459-59A	COPPER	0.0 PPM	1.3 PPM
63-60A Room 113 2nd Sink Faucet (Without Drinking Fountain)	8/6/16 9:34	8/14/2016	1608459-60A	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (C) Sample Data
Myers Elementary School

Sample Identification # and Location		Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
63-08C	Room 117 Sink Faucet	1/6/17 5:43	1/9/2017	782	COPPER	0.2 PPM	1.3 PPM
63-10C	Room 118 Sink Faucet	1/6/17 5:45	1/9/2017	783	COPPER	1.4 PPM	1.3 PPM
63-14C	Room 120 Sink Faucet	1/6/17 5:47	1/9/2017	784	COPPER	0.3 PPM	1.3 PPM
63-16C	Room 121 Sink Faucet	1/6/17 5:49	1/9/2017	785	COPPER	0.2 PPM	1.3 PPM
63-22C	AV Storage Room 100 Sink Faucet	1/6/17 5:54	1/9/2017	786	COPPER	0.0 PPM	1.3 PPM
63-25C	Room 102 Sink Faucet	1/6/17 5:59	1/9/2017	787	COPPER	0.1 PPM	1.3 PPM
63-30C	Room 105 Sink Faucet	1/6/17 6:01	1/9/2017	788	COPPER	0.3 PPM	1.3 PPM
63-59C	Drinking Fountain Across from Room 116 (5)	1/6/17 5:56	1/9/2017	789	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
Flushed (D) Sample Data
Myers Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
63-08D Room 117 Sink Faucet	1/6/2017 5:44	2/1/2017	4398	COPPER	<0.005 PPM	1.3 PPM
63-10D Room 118 Sink Faucet	1/6/2017 5:46	2/1/2017	4399	COPPER	0.0 PPM	1.3 PPM
63-59D Drinking Fountain Across from Room 116 (5)	1/6/2017 5:57	2/1/2017	4400	COPPER	<0.005 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (E) Sample Data
Myers Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
63-08E Room 117 Sink Faucet	4/6/2017 6:16	4/11/2017	18114	COPPER	0.6 PPM	1.3 PPM
63-10E Room 118 Sink Faucet	4/6/2017 6:19	4/11/2017	18115	COPPER	1.7 PPM	1.3 PPM
63-59E Drinking Fountain Across from Rm 116 (5)	4/6/2017 6:22	4/11/2017	18116	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (G) Sample Data
Myers Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
63-08G Room 117 Sink Faucet	1/5/2018 8:27:00AM	1/8/2018	910	COPPER	0.0 PPM	1.3 PPM
63-10G Room 118 Sink Faucet	1/5/2018 8:29:00AM	1/8/2018	911	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (I) Sample Data
Myers Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
63-08I Room 117 Sink Faucet	2/2/2018 6:00:00AM	2/6/2018	7768	COPPER	0.0 PPM	1.3 PPM
63-10I Room 118 Sink Faucet	2/2/2018 6:03:00AM	2/6/2018	7770	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level