

Salem Keizer School District
Copper Water Sampling Results
A (First Draw) Sample Data
Parrish Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
044-01A Kitchen Food Prep Sink Faucet	7/26/16 8:10	7/29/16 12:37	607271001	COPPER	0.4 PPM	1.3 PPM
044-03A Kitchen Water Fountain 1	7/26/16 8:13	7/29/16 12:37	607271002	COPPER	0.4 PPM	1.3 PPM
044-04A Kitchen Water Fountain 2	7/26/16 8:13	7/29/16 12:37	607271003	COPPER	0.4 PPM	1.3 PPM
044-05A Office Workroom Refridgerator Ice Maker	7/26/16 8:18	7/29/16 12:37	607271004	COPPER	0.5 PPM	1.3 PPM
044-06A Office Workroom Sink Faucet	7/26/16 8:19	7/29/16 12:37	607271005	COPPER	0.3 PPM	1.3 PPM
044-09A Room 104 Sink Faucet	7/26/16 8:22	7/29/16 12:42	607271006	COPPER	0.2 PPM	1.3 PPM
044-10A Home Economics Sink Faucet	7/26/16 8:25	7/29/16 12:42	607271007	COPPER	0.3 PPM	1.3 PPM
044-11A Home Economics Sink Faucet	7/26/16 8:27	7/29/16 12:43	607271008	COPPER	0.3 PPM	1.3 PPM
044-12A Home Economics Sink Faucet	7/26/16 8:29	7/29/16 12:43	607271009	COPPER	0.3 PPM	1.3 PPM
044-13A Home Economics Sink Faucet	7/26/16 8:32	7/29/16 12:43	607271010	COPPER	0.3 PPM	1.3 PPM
044-14A Home Economics Sink Faucet	7/26/16 8:34	7/29/16 12:43	607271011	COPPER	0.4 PPM	1.3 PPM
044-15A Home Economics Sink Faucet	7/26/16 8:37	7/29/16 12:43	607271012	COPPER	0.4 PPM	1.3 PPM
044-16A Hallway Drinking Fountain 1	7/26/16 8:40	7/29/16 12:43	607271013	COPPER	0.6 PPM	1.3 PPM
044-17A Hallway Drinking Fountain 2	7/26/16 8:45	7/29/16 12:43	607271014	COPPER	0.6 PPM	1.3 PPM
044-18A Hallway Drinking Fountain 3	7/26/16 8:47	7/29/16 12:43	607271015	COPPER	0.4 PPM	1.3 PPM
044-19A Library Break Area Sink Faucet	7/26/16 9:41	7/29/16 12:46	607271016	COPPER	0.5 PPM	1.3 PPM
044-20A Teaches Lounge Sink Faucet	7/26/16 9:10	7/29/16 12:46	607271017	COPPER	0.6 PPM	1.3 PPM
044-21A Hallway Drinking Fountain 4	7/26/16 9:13	7/29/16 12:46	607271018	COPPER	0.7 PPM	1.3 PPM
044-22A Hallway Drinking Fountain 5	7/26/16 9:15	7/29/16 12:46	607271019	COPPER	0.7 PPM	1.3 PPM
044-23A Hallway Drinking Fountain 6	7/26/16 8:56	7/29/16 12:46	607271020	COPPER	0.4 PPM	1.3 PPM
044-24A Hallway Drinking Fountain 7	7/26/16 8:58	7/29/16 12:46	607271021	COPPER	0.3 PPM	1.3 PPM
044-25A Gymnasium Drinking Fountain 1	7/26/16 9:01	7/29/16 12:46	607271022	COPPER	0.5 PPM	1.3 PPM
044-27A Fitness Center Drinking Fountain	7/26/16 9:27	7/29/16 12:46	607271023	COPPER	1.0 PPM	1.3 PPM
044-28A Classroom 225 Sink Faucet	7/26/16 9:35	7/29/16 12:46	607271024	COPPER	0.6 PPM	1.3 PPM
044-29A Hallway Drinking Fountain 8	7/26/16 9:31	7/29/16 12:47	607271025	COPPER	0.5 PPM	1.3 PPM
044-30A Hallway Drinking Fountain 9	7/26/16 9:33	7/29/16 12:49	607271026	COPPER	0.3 PPM	1.3 PPM
044-31A Hallway Drinking Fountain by Media	7/26/16 8:53	7/29/16 12:49	607271027	COPPER	0.7 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem Keizer School District
Copper Water Sampling Results
A (First Draw) Sample Data
Parrish Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
044-02A Kitchen Ice Maker	9/23/2016 5:09	9/26/2016	58307	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer School District
Copper Water Sampling Results
First Draw (A) Sample Data
Parrish Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
044-07A Classroom 101 Sink Faucet	10/14/2016 4:51	10/18/2016	63263	COPPER	0.2 PPM	1.3 PPM
044-08A Classroom 102 Sink Faucet	10/14/2016 4:55	10/18/2016	63264	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level