

Salem Keizer School District
Lead Water Sampling Results
A (First Draw) Sample Data
Parrish Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
044-01A Kitchen Food Prep Sink Faucet	7/26/16 8:10	7/29/16 12:37	607271001	LEAD	3 PPB	15 PPB
044-03A Kitchen Water Fountain 1	7/26/16 8:13	7/29/16 12:37	607271002	LEAD	7 PPB	15 PPB
044-04A Kitchen Water Fountain 2	7/26/16 8:13	7/29/16 12:37	607271003	LEAD	5 PPB	15 PPB
044-05A Office Workroom Refridgerator Ice Maker	7/26/16 8:18	7/29/16 12:37	607271004	LEAD	4 PPB	15 PPB
044-06A Office Workroom Sink Faucet	7/26/16 8:19	7/29/16 12:37	607271005	LEAD	< 1 PPB	15 PPB
044-09A Room 104 Sink Faucet	7/26/16 8:22	7/29/16 12:42	607271006	LEAD	7 PPB	15 PPB
044-10A Home Economics Sink Faucet	7/26/16 8:25	7/29/16 12:42	607271007	LEAD	< 1 PPB	15 PPB
044-11A Home Economics Sink Faucet	7/26/16 8:27	7/29/16 12:43	607271008	LEAD	< 1 PPB	15 PPB
044-12A Home Economics Sink Faucet	7/26/16 8:29	7/29/16 12:43	607271009	LEAD	1 PPB	15 PPB
044-13A Home Economics Sink Faucet	7/26/16 8:32	7/29/16 12:43	607271010	LEAD	1 PPB	15 PPB
044-14A Home Economics Sink Faucet	7/26/16 8:34	7/29/16 12:43	607271011	LEAD	< 1 PPB	15 PPB
044-15A Home Economics Sink Faucet	7/26/16 8:37	7/29/16 12:43	607271012	LEAD	2 PPB	15 PPB
044-16A Hallway Drinking Fountain 1	7/26/16 8:40	7/29/16 12:43	607271013	LEAD	< 1 PPB	15 PPB
044-17A Hallway Drinking Fountain 2	7/26/16 8:45	7/29/16 12:43	607271014	LEAD	1 PPB	15 PPB
044-18A Hallway Drinking Fountain 3	7/26/16 8:47	7/29/16 12:43	607271015	LEAD	< 1 PPB	15 PPB
044-19A Library Break Area Sink Faucet	7/26/16 9:41	7/29/16 12:46	607271016	LEAD	4 PPB	15 PPB
044-20A Teaches Lounge Sink Faucet	7/26/16 9:10	7/29/16 12:46	607271017	LEAD	1 PPB	15 PPB
044-21A Hallway Drinking Fountain 4	7/26/16 9:13	7/29/16 12:46	607271018	LEAD	< 1 PPB	15 PPB
044-22A Hallway Drinking Fountain 5	7/26/16 9:15	7/29/16 12:46	607271019	LEAD	< 1 PPB	15 PPB
044-23A Hallway Drinking Fountain 6	7/26/16 8:56	7/29/16 12:46	607271020	LEAD	< 1 PPB	15 PPB
044-24A Hallway Drinking Fountain 7	7/26/16 8:58	7/29/16 12:46	607271021	LEAD	< 1 PPB	15 PPB
044-25A Gymnasium Drinking Fountain 1	7/26/16 9:01	7/29/16 12:46	607271022	LEAD	2 PPB	15 PPB
044-27A Fitness Center Drinking Fountain	7/26/16 9:27	7/29/16 12:46	607271023	LEAD	< 1 PPB	15 PPB
044-28A Classroom 225 Sink Faucet	7/26/16 9:35	7/29/16 12:46	607271024	LEAD	1 PPB	15 PPB
044-29A Hallway Drinking Fountain 8	7/26/16 9:31	7/29/16 12:47	607271025	LEAD	1 PPB	15 PPB
044-30A Hallway Drinking Fountain 9	7/26/16 9:33	7/29/16 12:49	607271026	LEAD	1 PPB	15 PPB
044-31A Hallway Drinking Fountain by Media	7/26/16 8:53	7/29/16 12:49	607271027	LEAD	< 1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem Keizer School District
Lead Water Sampling Results
First Draw (A) Sample Data
Parrish Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
044-02A Kitchen Ice Maker	9/23/2016 5:09	9/26/2016	58307	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer School District
Lead Water Sampling Results
First Draw (A) Sample Data
Parrish Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
044-07A Classroom 101 Sink Faucet	10/14/2016 4:51	10/18/2016	63263	LEAD	3 PPB	15 PPB
044-08A Classroom 102 Sink Faucet	10/14/2016 4:55	10/18/2016	63264	LEAD	5 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level