

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Pringle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
032-01A Music Room Sink Faucet	7/20/16 8:17	7/28/2016	1607975-01A	COPPER	0.3 PPM	1.3 PPM
032-02A Bathroom 52/53 Drinking Fountain	7/20/16 8:20	7/28/2016	1607975-02A	COPPER	0.2 PPM	1.3 PPM
032-03A Room 25 Drinking Fountain	7/20/16 8:23	7/28/2016	1607975-03A	COPPER	0.2 PPM	1.3 PPM
032-04A Room 25 Sink Faucet 1	7/20/16 8:25	7/28/2016	1607975-04A	COPPER	0.3 PPM	1.3 PPM
032-05A Room 25 Sink Faucet 2	7/20/16 8:27	7/28/2016	1607975-05A	COPPER	0.2 PPM	1.3 PPM
032-06A Hallway Corridor 22 Drinking Fountain	7/20/16 8:30	7/28/2016	1607975-06A	COPPER	0.3 PPM	1.3 PPM
032-07A Room LRC Sink Faucet	7/20/16 8:33	7/28/2016	1607975-07A	COPPER	0.3 PPM	1.3 PPM
032-08A Health Room Sink Faucet	7/20/16 8:12	7/28/2016	1607975-08A	COPPER	0.2 PPM	1.3 PPM
032-09A Health Room Drinking Fountain	7/20/16 8:14	7/28/2016	1607975-09A	COPPER	0.3 PPM	1.3 PPM
032-10A Staff Lounge Sink Faucet	7/20/16 8:15	7/28/2016	1607975-10A	COPPER	0.2 PPM	1.3 PPM
032-11A Room 3 Sink Faucet	7/20/16 8:45	7/28/2016	1607975-11A	COPPER	0.3 PPM	1.3 PPM
032-12A Room 3 Drinking Fountain	7/20/16 8:47	7/28/2016	1607975-12A	COPPER	0.2 PPM	1.3 PPM
032-13A Room 5 Sink Faucet	7/20/16 8:50	7/28/2016	1607975-13A	COPPER	0.2 PPM	1.3 PPM
032-14A Room 5 Drinking Fountain	7/20/16 8:52	7/28/2016	1607975-14A	COPPER	0.2 PPM	1.3 PPM
032-15A Room 4 Sink Faucet	7/20/16 8:55	7/28/2016	1607975-15A	COPPER	0.2 PPM	1.3 PPM
032-16A Room 4 Drinking Fountain	7/20/16 8:57	7/28/2016	1607975-16A	COPPER	0.2 PPM	1.3 PPM
032-17A Room 6 Sink Faucet	7/20/16 9:03	7/28/2016	1607975-17A	COPPER	0.2 PPM	1.3 PPM
032-18A Room 6 Drinking Fountain	7/20/16 9:05	7/28/2016	1607975-18A	COPPER	0.2 PPM	1.3 PPM
032-19A Room 14 Sink Faucet	7/20/16 9:11	7/29/2016	1607975-19A	COPPER	7.9 PPM	1.3 PPM
032-20A Room 14 Drinking Fountain	7/20/16 9:13	7/28/2016	1607975-20A	COPPER	0.3 PPM	1.3 PPM
032-21A Room 13 Sink Faucet	7/20/16 9:16	7/28/2016	1607975-21A	COPPER	0.4 PPM	1.3 PPM
032-22A Room 13 Drinking Fountain	7/20/16 9:18	7/28/2016	1607975-22A	COPPER	0.3 PPM	1.3 PPM
032-23A Room 12 Sink Faucet	7/20/16 9:22	7/28/2016	1607975-23A	COPPER	0.6 PPM	1.3 PPM
032-24A Room 12 Drinking Fountain	7/20/16 9:24	7/28/2016	1607975-24A	COPPER	0.5 PPM	1.3 PPM
032-25A Room 11 Sink Faucet	7/20/16 9:29	7/29/2016	1607975-25A	COPPER	2.4 PPM	1.3 PPM
032-26A Room 11 Drinking Fountain	7/20/16 9:31	7/28/2016	1607975-26A	COPPER	0.5 PPM	1.3 PPM
032-27A Room 10 Sink Faucet	7/20/16 9:44	7/29/2016	1607975-27A	COPPER	1.5 PPM	1.3 PPM

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Pringle Elementary School

032-28A	Room 10 Drinking Fountain	7/20/16 9:46	7/28/2016	1607975-28A	COPPER	0.4 PPM	1.3 PPM
032-29A	Room 9 Sink Faucet	7/20/16 9:50	7/28/2016	1607975-29A	COPPER	0.4 PPM	1.3 PPM
032-30A	Room 9 Drinking Fountain	7/20/16 9:52	7/28/2016	1607975-30A	COPPER	0.4 PPM	1.3 PPM
032-31A	Room 8 Sink Faucet	7/20/16 9:57	7/28/2016	1607975-31A	COPPER	0.2 PPM	1.3 PPM
032-32A	Room 8 Drinking Fountain	7/20/16 9:59	7/28/2016	1607975-32A	COPPER	0.3 PPM	1.3 PPM
032-33A	Room 7 Sink Faucet	7/20/16 10:06	7/28/2016	1607975-33A	COPPER	0.2 PPM	1.3 PPM
032-34A	Room 7 Drinking Fountain	7/20/16 10:08	7/28/2016	1607975-34A	COPPER	0.3 PPM	1.3 PPM
032-35A	Food Service Food Prep Sink Faucet	7/20/16 10:15	7/28/2016	1607975-35A	COPPER	0.3 PPM	1.3 PPM
032-36A	Room 15 Sink Faucet	7/20/16 10:18	7/28/2016	1607975-36A	COPPER	0.2 PPM	1.3 PPM
032-37A	Room 15 Drinking Fountain	7/20/16 10:20	7/28/2016	1607975-37A	COPPER	0.2 PPM	1.3 PPM
032-38A	Room 23 Sink Faucet	7/20/16 10:23	7/28/2016	1607975-38A	COPPER	0.4 PPM	1.3 PPM
032-39A	Room 23 Drinking Fountain	7/20/16 10:25	7/28/2016	1607975-39A	COPPER	0.3 PPM	1.3 PPM
032-40A	Room 22 Sink Faucet	7/20/16 10:28	7/28/2016	1607975-40A	COPPER	0.3 PPM	1.3 PPM
032-41A	Room 22 Drinking Fountain	7/20/16 10:30	7/28/2016	1607975-41A	COPPER	0.4 PPM	1.3 PPM
032-42A	Room 21 Sink Faucet	7/20/16 10:34	7/28/2016	1607975-42A	COPPER	0.3 PPM	1.3 PPM
032-43A	Room 21 Drinking Fountain	7/20/16 10:36	7/28/2016	1607975-43A	COPPER	0.4 PPM	1.3 PPM
032-44A	Room 20 Sink Faucet	7/20/16 10:39	7/28/2016	1607975-44A	COPPER	0.4 PPM	1.3 PPM
032-45A	Room 20 Drinking Fountain	7/20/16 10:41	7/28/2016	1607975-45A	COPPER	0.4 PPM	1.3 PPM
032-46A	Room 19 Sink Faucet	7/20/16 10:45	7/28/2016	1607975-46A	COPPER	0.3 PPM	1.3 PPM
032-47A	Room 19 Drinking Fountain	7/20/16 10:47	7/28/2016	1607975-47A	COPPER	0.3 PPM	1.3 PPM
032-48A	Room 18 Sink Faucet	7/20/16 10:50	7/28/2016	1607975-48A	COPPER	0.3 PPM	1.3 PPM
032-49A	Room 18 Drinking Fountain	7/20/16 10:52	7/28/2016	1607975-49A	COPPER	0.3 PPM	1.3 PPM
032-50A	Primary Den Drinking Fountain	7/20/16 10:55	7/28/2016	1607975-50A	COPPER	0.5 PPM	1.3 PPM
032-51A	Room 2 Sink Faucet	7/20/16 10:58	7/28/2016	1607975-51A	COPPER	0.2 PPM	1.3 PPM
032-52A	Room 2 Drinking Fountain	7/20/16 11:00	7/28/2016	1607975-52A	COPPER	0.3 PPM	1.3 PPM
032-53A	Room 1 Sink Faucet	7/20/16 11:02	7/28/2016	1607975-53A	COPPER	0.3 PPM	1.3 PPM
032-54A	Room 1 Drinking Fountain	7/20/16 11:04	7/28/2016	1607975-54A	COPPER	0.3 PPM	1.3 PPM
032-55A	Room DLC 16 Sink Faucet	7/20/16 11:07	7/28/2016	1607975-55A	COPPER	0.2 PPM	1.3 PPM
032-56A	Room DLC 16 Drinking Fountain	7/20/16 11:09	7/28/2016	1607975-56A	COPPER	0.4 PPM	1.3 PPM

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Pringle Elementary School

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Copper Water Sampling Results  
Flushed (B) Sample Data  
Pringle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
032-01B Music Room Sink Faucet	7/20/16 8:18	8/16/2016	1607976-01A	COPPER	0.6 PPM	1.3 PPM
032-03B Room 25 Drinking Fountain	7/20/16 8:24	8/16/2016	1607976-03A	COPPER	0.3 PPM	1.3 PPM
032-08B Health Room Sink Faucet	7/20/16 8:13	8/16/2016	1607976-08A	COPPER	0.3 PPM	1.3 PPM
032-09B Health Room Drinking Fountain	7/20/16 8:15	8/16/2016	1607976-09A	COPPER	0.3 PPM	1.3 PPM
032-15B Room 4 Sink Faucet	7/20/16 8:56	8/16/2016	1607976-15A	COPPER	0.2 PPM	1.3 PPM
032-19B Room 14 Sink Faucet	7/20/16 9:12	8/16/2016	1607976-19A	COPPER	0.3 PPM	1.3 PPM
032-21B Room 13 Sink Faucet	7/20/16 9:17	8/16/2016	1607976-21A	COPPER	0.3 PPM	1.3 PPM
032-23B Room 12 Sink Faucet	7/20/16 9:23	8/16/2016	1607976-23A	COPPER	0.4 PPM	1.3 PPM
032-25B Room 11 Sink Faucet	7/20/16 9:30	8/16/2016	1607976-25A	COPPER	0.5 PPM	1.3 PPM
032-27B Room 10 Sink Faucet	7/20/16 9:45	8/16/2016	1607976-27A	COPPER	0.4 PPM	1.3 PPM
032-28B Room 10 Drinking Faucet	7/20/16 9:47	8/16/2016	1607976-28A	COPPER	0.4 PPM	1.3 PPM
032-29B Room 9 Sink Faucet	7/20/16 9:51	8/16/2016	1607976-29A	COPPER	0.4 PPM	1.3 PPM
032-31B Room 8 Sink Faucet	7/20/16 9:58	8/16/2016	1607976-31A	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

**SKPS Action Level for Copper is 1.3 PPM**

**Highlighted samples are at or exceed the Salem-Keizer**

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (C) Sample Data  
Pringle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
032-01C Music Room Sink Faucet	9/22/2016 4:48	9/26/2016	57933	COPPER	0.5 PPM	1.3 PPM
032-03C Room 25 Drinking Fountain	9/22/2016 4:51	9/26/2016	57934	COPPER	0.2 PPM	1.3 PPM
032-08C Health Room Sink Faucet	9/22/2016 4:54	9/26/2016	57935	COPPER	0.2 PPM	1.3 PPM
032-09C Health Room Drinking Fountain	9/22/2016 4:55	9/26/2016	57936	COPPER	0.2 PPM	1.3 PPM
032-15C Room 4 Sink Faucet	9/22/2016 4:59	9/26/2016	57937	COPPER	0.2 PPM	1.3 PPM
032-19C Room 14 Sink Faucet	9/22/2016 5:02	9/26/2016	57938	COPPER	0.3 PPM	1.3 PPM
032-21C Room 13 Sink Faucet	9/22/2016 5:04	9/26/2016	57939	COPPER	0.4 PPM	1.3 PPM
032-23C Room 12 Sink Faucet	9/22/2016 5:06	9/26/2016	57940	COPPER	0.3 PPM	1.3 PPM
032-25C Room 11 Sink Faucet	9/22/2016 5:08	9/26/2016	57941	COPPER	0.3 PPM	1.3 PPM
032-27C Room 10 Sink Faucet	9/22/2016 5:11	9/26/2016	57942	COPPER	0.3 PPM	1.3 PPM
032-28C Room 10 Drinking Fountain	9/22/2016 5:11	9/26/2016	57943	COPPER	0.3 PPM	1.3 PPM
032-29C Room 9 Sink Faucet	9/22/2016 5:14	9/26/2016	57944	COPPER	0.6 PPM	1.3 PPM
032-31C Room 8 Sink Faucet	9/22/2016 5:16	9/26/2016	57945	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Copper Water Sampling Results  
Flushed (D) Sample Data  
Pringle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
032-08D Health Room Sink Faucet	9/21/2016 4:55	10/3/2016	59928	COPPER	0.2 PPM	1.3 PPM
032-09D Health Room Drinking Fountain	9/21/2016 4:56	10/3/2016	59929	COPPER	0.2 PPM	1.3 PPM
032-25D Room 11 Sink Faucet	9/21/2016 5:09	10/3/2016	59930	COPPER	0.3 PPM	1.3 PPM
032-27D Room 10 Sink Faucet	9/21/2016 5:12	10/3/2016	59931	COPPER	0.3 PPM	1.3 PPM
032-29D Room 9 Sink Faucet	9/21/2016 5:15	10/3/2016	59932	COPPER	0.3 PPM	1.3 PPM
032-31D Room 8 Sink Faucet	9/21/2016 5:17	10/3/2016	59933	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (E) Sample Data  
Pringle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
032-08E Health Room Sink Faucet	4/6/2017 7:17	4/11/2017	18118	COPPER	0.1 PPM	1.3 PPM
032-09E Health Room Drinking Fountain	4/6/2017 7:19	4/11/2017	18119	COPPER	0.2 PPM	1.3 PPM
032-25E Room 11 Sink Faucet	4/6/2017 7:24	4/11/2017	18120	COPPER	0.3 PPM	1.3 PPM
032-27E Room 10 Sink Faucet	4/6/2017 7:26	4/11/2017	18121	COPPER	0.3 PPM	1.3 PPM
032-29E Room 9 Sink Faucet	4/6/2017 7:29	4/11/2017	18122	COPPER	0.3 PPM	1.3 PPM
032-31E Room 8 Sink Faucet	4/6/2017 7:31	4/11/2017	18123	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (G) Sample Data  
Pringle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
032-25G Room 11 Sink Faucet	9/1/2017 8:01	9/5/2017	50663	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level



Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (G) Sample Data  
Pringle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
032-08G Health Room Sink Faucet	8/4/2017 7:50:00AM	8/7/2017	43363	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (I) Sample Data  
Pringle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
032-08I Health Room Sink Faucet	9/1/2017 7:57	9/5/2017	50662	COPPER	0.2 PPM	1.3 PPM
032-09I Health Room Drinking Fountain	9/1/2017 7:58	9/5/2017	50664	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level