

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Pringle Elementary School

Sample Identification # and Location		Date Sampled	Date Analyzed	Container ID	Tested For	Results		Action Level
032-01A	Music Room Sink Faucet	7/20/2016	7/28/2016	1607975-01A	LEAD	15	PPB	15 PPB
032-02A	Bathroom 52/53 Drinking Fountain	7/20/2016	7/28/2016	1607975-02A	LEAD	<1.0	PPB	15 PPB
032-03A	Room 25 Drinking Fountain	7/20/2016	7/28/2016	1607975-03A	LEAD	19	PPB	15 PPB
032-04A	Room 25 Sink Faucet 1	7/20/2016	7/28/2016	1607975-04A	LEAD	6	PPB	15 PPB
032-05A	Room 25 Sink Faucet 2	7/20/2016	7/28/2016	1607975-05A	LEAD	11	PPB	15 PPB
032-06A	Hallway Corridor 22 Drinking Fountain	7/20/2016	7/28/2016	1607975-06A	LEAD	6	PPB	15 PPB
032-07A	Room LRC Sink Faucet	7/20/2016	7/28/2016	1607975-07A	LEAD	6	PPB	15 PPB
032-08A	Health Room Sink Faucet	7/20/2016	7/28/2016	1607975-08A	LEAD	120	PPB	15 PPB
032-09A	Health Room Drinking Fountain	7/20/2016	7/28/2016	1607975-09A	LEAD	33	PPB	15 PPB
032-10A	Staff Lounge Sink Faucet	7/20/2016	7/28/2016	1607975-10A	LEAD	3	PPB	15 PPB
032-11A	Room 3 Sink Faucet	7/20/2016	7/28/2016	1607975-11A	LEAD	12	PPB	15 PPB
032-12A	Room 3 Drinking Fountain	7/20/2016	7/28/2016	1607975-12A	LEAD	6	PPB	15 PPB
032-13A	Room 5 Sink Faucet	7/20/2016	7/28/2016	1607975-13A	LEAD	14	PPB	15 PPB
032-14A	Room 5 Drinking Fountain	7/20/2016	7/28/2016	1607975-14A	LEAD	3	PPB	15 PPB
032-15A	Room 4 Sink Faucet	7/20/2016	7/28/2016	1607975-15A	LEAD	17	PPB	15 PPB
032-16A	Room 4 Drinking Fountain	7/20/2016	7/28/2016	1607975-16A	LEAD	5	PPB	15 PPB
032-17A	Room 6 Sink Faucet	7/20/2016	7/28/2016	1607975-17A	LEAD	10	PPB	15 PPB
032-18A	Room 6 Drinking Fountain	7/20/2016	7/28/2016	1607975-18A	LEAD	6	PPB	15 PPB
032-19A	Room 14 Sink Faucet	7/20/2016	7/29/2016	1607975-19A	LEAD	430	PPB	15 PPB
032-20A	Room 14 Drinking Fountain	7/20/2016	7/28/2016	1607975-20A	LEAD	4	PPB	15 PPB
032-21A	Room 13 Sink Faucet	7/20/2016	7/28/2016	1607975-21A	LEAD	20	PPB	15 PPB
032-22A	Room 13 Drinking Fountain	7/20/2016	7/28/2016	1607975-22A	LEAD	5	PPB	15 PPB
032-23A	Room 12 Sink Faucet	7/20/2016	7/29/2016	1607975-23A	LEAD	800	PPB	15 PPB
032-24A	Room 12 Drinking Fountain	7/20/2016	7/28/2016	1607975-24A	LEAD	4	PPB	15 PPB
032-25A	Room 11 Sink Faucet	7/20/2016	7/29/2016	1607975-25A	LEAD	14000	PPB	15 PPB
032-26A	Room 11 Drinking Fountain	7/20/2016	7/28/2016	1607975-26A	LEAD	4	PPB	15 PPB
032-27A	Room 10 Sink Faucet	7/20/2016	7/29/2016	1607975-27A	LEAD	1200	PPB	15 PPB
032-28A	Room 10 Drinking Fountain	7/20/2016	7/28/2016	1607975-28A	LEAD	32	PPB	15 PPB
032-29A	Room 9 Sink Faucet	7/20/2016	7/29/2016	1607975-29A	LEAD	900	PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Pringle Elementary School

032-30A	Room 9 Drinking Fountain	7/20/2016	7/28/2016	1607975-30A	LEAD	4	PPB	15 PPB
032-31A	Room 8 Sink Faucet	7/20/2016	7/28/2016	1607975-31A	LEAD	36	PPB	15 PPB
032-32A	Room 8 Drinking Fountain	7/20/2016	7/28/2016	1607975-32A	LEAD	9	PPB	15 PPB
032-33A	Room 7 Sink Faucet	7/20/2016	7/28/2016	1607975-33A	LEAD	13	PPB	15 PPB
032-34A	Room 7 Drinking Fountain	7/20/2016	7/28/2016	1607975-34A	LEAD	5	PPB	15 PPB
032-35A	Food Service Food Prep Sink Faucet	7/20/2016	7/28/2016	1607975-35A	LEAD	<1.0	PPB	15 PPB
032-36A	Room 15 Sink Faucet	7/20/2016	7/28/2016	1607975-36A	LEAD	11	PPB	15 PPB
032-37A	Room 15 Drinking Fountain	7/20/2016	7/28/2016	1607975-37A	LEAD	2	PPB	15 PPB
032-38A	Room 23 Sink Faucet	7/20/2016	7/28/2016	1607975-38A	LEAD	<1.0	PPB	15 PPB
032-39A	Room 23 Drinking Fountain	7/20/2016	7/28/2016	1607975-39A	LEAD	3	PPB	15 PPB
032-40A	Room 22 Sink Faucet	7/20/2016	7/28/2016	1607975-40A	LEAD	2	PPB	15 PPB
032-41A	Room 22 Drinking Fountain	7/20/2016	7/28/2016	1607975-41A	LEAD	2	PPB	15 PPB
032-42A	Room 21 Sink Faucet	7/20/2016	7/28/2016	1607975-42A	LEAD	1	PPB	15 PPB
032-43A	Room 21 Drinking Fountain	7/20/2016	7/28/2016	1607975-43A	LEAD	4	PPB	15 PPB
032-44A	Room 20 Sink Faucet	7/20/2016	7/28/2016	1607975-44A	LEAD	4	PPB	15 PPB
032-45A	Room 20 Drinking Fountain	7/20/2016	7/28/2016	1607975-45A	LEAD	5	PPB	15 PPB
032-46A	Room 19 Sink Faucet	7/20/2016	7/28/2016	1607975-46A	LEAD	5	PPB	15 PPB
032-47A	Room 19 Drinking Fountain	7/20/2016	7/28/2016	1607975-47A	LEAD	3	PPB	15 PPB
032-48A	Room 18 Sink Faucet	7/20/2016	7/28/2016	1607975-48A	LEAD	3	PPB	15 PPB
032-49A	Room 18 Drinking Fountain	7/20/2016	7/28/2016	1607975-49A	LEAD	4	PPB	15 PPB
032-50A	Primary Den Drinking Fountain	7/20/2016	7/28/2016	1607975-50A	LEAD	1	PPB	15 PPB
032-51A	Room 2 Sink Faucet	7/20/2016	7/28/2016	1607975-51A	LEAD	6	PPB	15 PPB
032-52A	Room 2 Drinking Fountain	7/20/2016	7/28/2016	1607975-52A	LEAD	10	PPB	15 PPB
032-53A	Room 1 Sink Faucet	7/20/2016	7/28/2016	1607975-53A	LEAD	13	PPB	15 PPB
032-54A	Room 1 Drinking Fountain	7/20/2016	7/28/2016	1607975-54A	LEAD	5	PPB	15 PPB
032-55A	Room DLC 16 Sink Faucet	7/20/2016	7/28/2016	1607975-55A	LEAD	11	PPB	15 PPB
032-56A	Room DLC 16 Drinking Fountain	7/20/2016	7/28/2016	1607975-56A	LEAD	6	PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
Pringle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
032-01B Music Room Sink Faucet	7/20/16 8:18	8/16/2016	1607976-01A	LEAD	2 PPB	15 PPB
032-03B Room 25 Drinking Fountain	7/20/16 8:24	8/16/2016	1607976-03A	LEAD	2 PPB	15 PPB
032-08B Health Room Sink Faucet	7/20/16 8:13	8/16/2016	1607976-08A	LEAD	6 PPB	15 PPB
032-09B Health Room Drinking Fountain	7/20/16 8:15	8/16/2016	1607976-09A	LEAD	16 PPB	15 PPB
032-15B Room 4 Sink Faucet	7/20/16 8:56	8/16/2016	1607976-15A	LEAD	2 PPB	15 PPB
032-19B Room 14 Sink Faucet	7/20/16 9:12	8/16/2016	1607976-19A	LEAD	4 PPB	15 PPB
032-21B Room 13 Sink Faucet	7/20/16 9:17	8/16/2016	1607976-21A	LEAD	3 PPB	15 PPB
032-23B Room 12 Sink Faucet	7/20/16 9:23	8/16/2016	1607976-23A	LEAD	7 PPB	15 PPB
032-25B Room 11 Sink Faucet	7/20/16 9:30	8/16/2016	1607976-25A	LEAD	64 PPB	15 PPB
032-27B Room 10 Sink Faucet	7/20/16 9:45	8/16/2016	1607976-27A	LEAD	37 PPB	15 PPB
032-28B Room 10 Drinking Faucet	7/20/16 9:47	8/16/2016	1607976-28A	LEAD	1 PPB	15 PPB
032-29B Room 9 Sink Faucet	7/20/16 9:51	8/16/2016	1607976-29A	LEAD	5 PPB	15 PPB
032-31B Room 8 Sink Faucet	7/20/16 9:58	8/16/2016	1607976-31A	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (C) Sample Data
Pringle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
032-01C Music Room Sink Faucet	9/22/2016 4:48	9/26/2016	57933	LEAD	9 PPB	15 PPB
032-03C Room 25 Drinking Fountain	9/22/2016 4:51	9/26/2016	57934	LEAD	2 PPB	15 PPB
032-08C Health Room Sink Faucet	9/22/2016 4:54	9/26/2016	57935	LEAD	98 PPB	15 PPB
032-09C Health Room Drinking Fountain	9/22/2016 4:55	9/26/2016	57936	LEAD	18 PPB	15 PPB
032-15C Room 4 Sink Faucet	9/22/2016 4:59	9/26/2016	57937	LEAD	5 PPB	15 PPB
032-19C Room 14 Sink Faucet	9/22/2016 5:02	9/26/2016	57938	LEAD	3 PPB	15 PPB
032-21C Room 13 Sink Faucet	9/22/2016 5:04	9/26/2016	57939	LEAD	9 PPB	15 PPB
032-23C Room 12 Sink Faucet	9/22/2016 5:06	9/26/2016	57940	LEAD	3 PPB	15 PPB
032-25C Room 11 Sink Faucet	9/22/2016 5:08	9/26/2016	57941	LEAD	111 PPB	15 PPB
032-27C Room 10 Sink Faucet	9/22/2016 5:11	9/26/2016	57942	LEAD	65 PPB	15 PPB
032-28C Room 10 Drinking Fountain	9/22/2016 5:11	9/26/2016	57943	LEAD	2 PPB	15 PPB
032-29C Room 9 Sink Faucet	9/22/2016 5:14	9/26/2016	57944	LEAD	16 PPB	15 PPB
032-31C Room 8 Sink Faucet	9/22/2016 5:16	9/26/2016	57945	LEAD	289 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
 Lead Water Sampling Results
 Flushed (D) Sample Data
 Pringle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
032-08D Health Room Sink Faucet	9/21/2016 4:55	10/3/2016	59928	LEAD	4 PPB	15 PPB
032-09D Health Room Drinking Fountain	9/21/2016 4:56	10/3/2016	59929	LEAD	3 PPB	15 PPB
032-25D Room 11 Sink Faucet	9/21/2016 5:09	10/3/2016	59930	LEAD	1 PPB	15 PPB
032-27D Room 10 Sink Faucet	9/21/2016 5:12	10/3/2016	59931	LEAD	<1 PPB	15 PPB
032-29D Room 9 Sink Faucet	9/21/2016 5:15	10/3/2016	59932	LEAD	<1 PPB	15 PPB
032-31D Room 8 Sink Faucet	9/21/2016 5:17	10/3/2016	59933	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
 Lead Water Sampling Results
 First Draw (E) Sample Data
 Pringle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
032-08E Health Room Sink Faucet	4/6/2017 7:17	4/11/2017	18118	LEAD	55 PPB	15 PPB
032-09E Health Room Drinking Fountain	4/6/2017 7:19	4/11/2017	18119	LEAD	8 PPB	15 PPB
032-25E Room 11 Sink Faucet	4/6/2017 7:24	4/11/2017	18120	LEAD	36 PPB	15 PPB
032-27E Room 10 Sink Faucet	4/6/2017 7:26	4/11/2017	18121	LEAD	5 PPB	15 PPB
032-29E Room 9 Sink Faucet	4/6/2017 7:29	4/11/2017	18122	LEAD	2 PPB	15 PPB
032-31E Room 8 Sink Faucet	4/6/2017 7:31	4/11/2017	18123	LEAD	4 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (G) Sample Data
Pringle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
032-25G Room 11 Sink Faucet	9/1/2017 8:01	9/5/2017	50663	LEAD	8 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (I) Sample Data
Pringle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
032-08I Health Room Sink Faucet	9/1/2017 7:57	9/5/2017	50662	LEAD	6 PPB	15 PPB
032-09I Health Room Drinking Fountain	9/1/2017 7:58	9/5/2017	50664	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level