

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Roberts High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
46-01A Room 126 Sink Faucet	8/5/2016 10:33	8/23/2016	49999	COPPER	0.5 PPM	1.3 PPM
46-02A Room 132 Sink Faucet	8/5/2016 10:36	8/23/2016	50000	COPPER	0.3 PPM	1.3 PPM
46-03A Room 133/134 Sink Faucet (Kitchen)	8/5/2016 10:39	8/23/2016	50001	COPPER	0.5 PPM	1.3 PPM
46-04A Room 133/134 Sink Faucet (Classroom)	8/5/2016 10:39	8/23/2016	50002	COPPER	0.4 PPM	1.3 PPM
46-05A Gymnasium Drinking Fountain (Left)	8/5/2016 10:41	8/23/2016	50003	COPPER	0.6 PPM	1.3 PPM
46-06A Gymnasium Drinking Fountain (Right)	8/5/2016 10:43	8/23/2016	50004	COPPER	0.3 PPM	1.3 PPM
46-07A Staff Room Drinking Fountain	8/5/2016 10:50	8/23/2016	50005	COPPER	0.6 PPM	1.3 PPM
46-08A Staff Room Sink Faucet	8/5/2016 10:51	8/23/2016	50006	COPPER	0.2 PPM	1.3 PPM
46-09A Room 202 Sink Faucet	8/5/2016 10:54	8/23/2016	50007	COPPER	0.2 PPM	1.3 PPM
46-10A Room 202 Drinking Fountain	8/5/2016 10:54	8/23/2016	50008	COPPER	0.2 PPM	1.3 PPM
46-11A Room 205 Sink Faucet	8/5/2016 10:57	8/23/2016	50009	COPPER	0.4 PPM	1.3 PPM
46-12A Room 205 Drinking Fountain	8/5/2016 10:57	8/23/2016	50010	COPPER	0.6 PPM	1.3 PPM
46-13A Double-Wide Kitchen Sink Faucet	8/5/2016 11:01	8/23/2016	50011	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level