

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Scott Elementary School

Sample Identification # and Location		Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results		Action Level
049-01A	Kitchen Sink Faucet	7/28/16 15:03	8/3/2016	1608009-01A	LEAD	20	PPB	15 PPB
049-02A	Cafeteria Sink Faucet	7/28/16 15:04	8/3/2016	1608009-02A	LEAD	10	PPB	15 PPB
049-03A	Cafeteria Drinking Fountain	7/28/16 15:04	8/3/2016	1608009-03A	LEAD	4	PPB	15 PPB
049-04A	Break Room Sink Faucet	7/28/16 15:00	8/3/2016	1608009-04A	LEAD	150	PPB	15 PPB
049-05A	MRS Power Room Sink Faucet	7/28/16 15:10	8/3/2016	1608009-05A	LEAD	120	PPB	15 PPB
049-06A	MRS Power Room Sink Faucet	7/28/16 15:10	8/3/2016	1608009-06A	LEAD	6	PPB	15 PPB
049-07A	Music Room Sink Faucet	7/28/16 15:46	8/3/2016	1608009-07A	LEAD	2	PPB	15 PPB
049-08A	Music Room Drinking Fountain	7/28/16 15:46	8/3/2016	1608009-08A	LEAD	8	PPB	15 PPB
049-09A	Music Room Sink Faucet	7/28/16 15:48	8/2/2016	1608009-09A	LEAD	3	PPB	15 PPB
049-10A	Room A7 Sink Faucet	7/28/16 15:06	8/2/2016	1608009-10A	LEAD	17	PPB	15 PPB
049-11A	Hall Drinking Fountain 1	7/28/16 15:16	8/3/2016	1608009-11A	LEAD	4	PPB	15 PPB
049-12A	Room A1 Sink Faucet	7/28/16 15:12	8/2/2016	1608009-12A	LEAD	5	PPB	15 PPB
049-13A	Room A1 Drinking Fountain	7/28/16 15:12	8/3/2016	1608009-13A	LEAD	3	PPB	15 PPB
049-14A	Room A2 Sink Faucet	7/28/16 15:13	8/3/2016	1608009-14A	LEAD	4	PPB	15 PPB
049-15A	Room A2 Drinking Fountain	7/28/16 15:13	8/3/2016	1608009-15A	LEAD	3	PPB	15 PPB
049-16A	Room A3 Sink Faucet	7/28/16 15:18	8/2/2016	1608009-16A	LEAD	10	PPB	15 PPB
049-17A	Room A3 Drinking Fountain	7/28/16 15:18	8/3/2016	1608009-17A	LEAD	6	PPB	15 PPB
049-18A	Room A4 Sink Faucet	7/28/16 15:19	8/2/2016	1608009-18A	LEAD	5	PPB	15 PPB
049-19A	Room A4 Drinking Fountain	7/28/16 15:19	8/3/2016	1608009-19A	LEAD	3	PPB	15 PPB
049-20A	Room A5 Sink Faucet	7/28/16 15:22	8/3/2016	1608009-20A	LEAD	4	PPB	15 PPB
049-21A	Room A5 Drinking Fountain	7/28/16 15:22	8/3/2016	1608009-21A	LEAD	3	PPB	15 PPB
049-22A	Room A5 Sink Faucet	7/28/16 16:04	8/3/2016	1608009-22A	LEAD	4	PPB	15 PPB
049-23A	Room A6 Sink Faucet	7/28/16 15:30	8/3/2016	1608009-23A	LEAD	3	PPB	15 PPB
049-24A	Room A6 Sink Faucet	7/28/16 15:31	8/2/2016	1608009-24A	LEAD	3	PPB	15 PPB
049-25A	Room A6 Drinking Fountain	7/28/16 15:31	8/3/2016	1608009-25A	LEAD	2	PPB	15 PPB
049-26A	Hall Drinking Fountain 2	7/28/16 15:26	8/3/2016	1608009-26A	LEAD	2	PPB	15 PPB
049-27A	Main Office Sink Faucet	7/28/16 15:38	8/2/2016	1608009-27A	LEAD	6	PPB	15 PPB
049-28A	Craft Room Sink Faucet	7/28/16 15:40	8/3/2016	1608009-28A	LEAD	3	PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Scott Elementary School

049-29A	Media Room Drinking Fountain	7/28/16 15:42	8/3/2016	1608009-29A	LEAD	16	PPB	15 PPB
049-30A	Hall Drinking Fountain 3	7/28/16 15:20	8/3/2016	1608009-30A	LEAD	21	PPB	15 PPB
049-31A	Room B1 Sink Faucet	7/28/16 15:22	8/2/2016	1608009-31A	LEAD	4	PPB	15 PPB
049-32A	Room B1 Drinking Fountain	7/28/16 15:22	8/3/2016	1608009-32A	LEAD	2	PPB	15 PPB
049-33A	Room B2 Sink Faucet	7/28/16 15:24	8/2/2016	1608009-33A	LEAD	7	PPB	15 PPB
049-34A	Room B2 Drinking Fountain	7/28/16 15:24	8/3/2016	1608009-34A	LEAD	8	PPB	15 PPB
049-35A	Room B3 Sink Faucet	7/28/16 15:28	8/3/2016	1608009-35A	LEAD	1	PPB	15 PPB
049-36A	Room B3 Drinking Fountain	7/28/16 15:28	8/3/2016	1608009-36A	LEAD	3	PPB	15 PPB
049-37A	Room B4 Sink Faucet	7/28/16 15:30	8/3/2016	1608009-37A	LEAD	1	PPB	15 PPB
049-38A	Room B4 Drinking Fountain	7/28/16 15:30	8/3/2016	1608009-38A	LEAD	2	PPB	15 PPB
049-39A	Room B5 Sink Faucet	7/28/16 15:48	8/3/2016	1608009-39A	LEAD	1	PPB	15 PPB
049-40A	Room B5 Drinking Fountain	7/28/16 15:48	8/3/2016	1608009-40A	LEAD	1	PPB	15 PPB
049-41A	Room B6 Sink Faucet	7/28/16 15:34	8/4/2016	1608009-41A	LEAD	3	PPB	15 PPB
049-42A	Room B6 Drinking Fountain	7/28/16 15:34	8/4/2016	1608009-42A	LEAD	3	PPB	15 PPB
049-43A	Hall Drinking Fountain 4	7/28/16 16:48	8/4/2016	1608009-43A	LEAD	35	PPB	15 PPB
049-44A	Room C1 Sink Faucet	7/28/16 15:38	8/4/2016	1608009-44A	LEAD	3	PPB	15 PPB
049-45A	Room C1 Drinking Fountain	7/28/16 15:38	8/4/2016	1608009-45A	LEAD	2	PPB	15 PPB
049-46A	Room C2 Sink Faucet	7/28/16 15:40	8/2/2016	1608009-46A	LEAD	4	PPB	15 PPB
049-47A	Room C2 Drinking Fountain	7/28/16 15:40	8/4/2016	1608009-47A	LEAD	5	PPB	15 PPB
049-48A	Room C3 Sink Faucet	7/28/16 15:44	8/4/2016	1608009-48A	LEAD	3	PPB	15 PPB
049-49A	Room C3 Drinking Fountain	7/28/16 15:44	8/4/2016	1608009-49A	LEAD	1	PPB	15 PPB
049-50A	Room C4 Sink Faucet	7/28/16 15:46	8/2/2016	1608009-50A	LEAD	2	PPB	15 PPB
049-51A	Room C4 Drinking Fountain	7/28/16 15:46	8/4/2016	1608009-51A	LEAD	3	PPB	15 PPB
049-52A	Room C5 Sink Faucet	7/28/16 15:41	8/2/2016	1608009-52A	LEAD	3	PPB	15 PPB
049-53A	Room C5 Drinking Fountain	7/28/16 15:41	8/4/2016	1608009-53A	LEAD	3	PPB	15 PPB
049-54A	Room C6 Sink Faucet	7/28/16 15:46	8/4/2016	1608009-54A	LEAD	4	PPB	15 PPB
049-55A	Room C6 Drinking Fountain	7/28/16 15:46	8/4/2016	1608009-55A	LEAD	7	PPB	15 PPB
049-56A	Room N2 Drinking Fountain	7/28/16 16:22	8/5/2016	1608009-56A	LEAD	<1.0	PPB	15 PPB
049-57A	Room N6 Sink Faucet	7/28/16 16:25	8/2/2016	1608009-57A	LEAD	6	PPB	15 PPB
049-58A	Room N6 Drinking Fountain	7/28/16 16:25	8/4/2016	1608009-58A	LEAD	4	PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Scott Elementary School

049-59A	Room N7 Sink Faucet	7/28/16 16:29	8/4/2016	1608009-59A	LEAD	5	PPB	15 PPB
049-60A	Room N7 Drinking Fountain	7/28/16 16:29	8/4/2016	1608009-60A	LEAD	4	PPB	15 PPB
049-61A	Room N8 Sink Faucet	7/28/16 16:34	8/4/2016	1608009-61A	LEAD	<1.0	PPB	15 PPB
049-62A	Room N8 Drinking Fountain	7/28/16 16:34	8/4/2016	1608009-62A	LEAD	<1.0	PPB	15 PPB
049-63A	Room N9 Sink Faucet	7/28/16 16:36	8/4/2016	1608009-63A	LEAD	<1.0	PPB	15 PPB
049-64A	Room N9 Drinking Fountain	7/28/16 16:36	8/4/2016	1608009-64A	LEAD	<1.0	PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Copper is 15 PPB

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
Flushed (B) Sample Data  
Scott Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
049-01B Kitchen Sink Faucet	7/28/16 15:04	8/24/2016	1608010-01A	LEAD	6 PPB	15 PPB
049-04B Break Room Sink Faucet	7/28/16 15:01	8/24/2016	1608010-04A	LEAD	40 PPB	15 PPB
049-05B MRS Power Room Sink Faucet	7/28/16 15:11	8/24/2016	1608010-05A	LEAD	47 PPB	15 PPB
049-10B Room A7 Sink Faucet	7/28/16 15:07	8/24/2016	1608010-10A	LEAD	6 PPB	15 PPB
049-29B Media Room Drinking Fountain	7/28/16 15:43	8/24/2016	1608010-29A	LEAD	6 PPB	15 PPB
049-30B Hall Drinking Fountain 3	7/28/16 15:21	8/24/2016	1608010-30A	LEAD	29 PPB	15 PPB
049-43B Hall Drinking Fountain 4	7/28/16 16:49	8/24/2016	1608010-43A	LEAD	23 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
Flushed (D) Sample Data  
Scott Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
049-43D Hall Drinking Fountain 4	11/18/2016 5:47	2/1/2017	4392	LEAD	16 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (C) Sample Data  
Scott Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
049-01C Kitchen Sink Faucet	11/18/2016 5:31	11/22/2016	70415	LEAD	3 PPB	15 PPB
049-04C Break Room Sink Faucet	11/18/2016 5:34	11/22/2016	70416	LEAD	12 PPB	15 PPB
049-05C MRS Power Room Sink Faucet	11/18/2016 5:37	11/22/2016	70417	LEAD	11 PPB	15 PPB
049-10C Room A7 Sink Faucet	11/18/2016 5:39	11/22/2016	70418	LEAD	4 PPB	15 PPB
049-29C Media Room Drinking Fountain	11/18/2016 5:42	11/22/2016	70419	LEAD	5 PPB	15 PPB
049-30C Hall Drinking Fountain 3	11/18/2016 5:44	11/22/2016	70420	LEAD	10 PPB	15 PPB
049-43C Hall Drinking Fountain 4	11/18/2016 5:46	11/22/2016	70421	LEAD	44 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (E) Sample Data  
Scott Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
049-43E Hall Drinking Fountain 4	4/6/2017 8:13	4/11/2017	18162	LEAD	21 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
 Lead Water Sampling Results  
 First Draw (A) Sample Data  
 Scott Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
049-01-2A Kitchen Sink Faucet	9/1/17 6:07	9/5/2017	50746	LEAD	4 PPB	15 PPB
049-02-2A Cafeteria Sink Faucet	9/1/17 6:09	9/5/2017	50747	LEAD	2 PPB	15 PPB
049-03-2A Cafeteria Drinking Fountain	9/1/17 6:10	9/5/2017	50748	LEAD	<1 PPB	15 PPB
049-04-2A Break Room Sink Faucet	9/1/17 6:12	9/5/2017	50749	LEAD	<1 PPB	15 PPB
049-05-2A MRS Power Room Sink Faucet	9/1/17 6:15	9/5/2017	50750	LEAD	<1 PPB	15 PPB
049-06-2A MRS Power Room Sink Faucet	9/1/17 6:15	9/5/2017	50751	LEAD	2 PPB	15 PPB
049-07-2A Music Room Sink Faucet	9/1/17 6:18	9/5/2017	50752	LEAD	3 PPB	15 PPB
049-09-2A Music Room Sink Faucet	9/1/17 6:18	9/5/2017	50753	LEAD	2 PPB	15 PPB
049-10-2A Room A7 Sink Faucet	9/1/17 6:20	9/5/2017	50754	LEAD	<1 PPB	15 PPB
049-11-2A Hall Drinking Fountain 1	9/1/17 6:22	9/5/2017	50755	LEAD	2 PPB	15 PPB
049-12-2A Room A1 Sink Faucet	9/1/17 6:24	9/5/2017	50756	LEAD	2 PPB	15 PPB
049-13-2A Room A1 Drinking Fountain	9/1/17 6:25	9/5/2017	50757	LEAD	4 PPB	15 PPB
049-14-2A Room A2 Sink Faucet	9/1/17 6:27	9/5/2017	50758	LEAD	2 PPB	15 PPB
049-15-2A Room A2 Drinking Fountain	9/1/17 6:28	9/5/2017	50759	LEAD	3 PPB	15 PPB
049-16-2A Room A3 Sink Faucet	9/1/17 6:30	9/5/2017	50760	LEAD	2 PPB	15 PPB
049-17-2A Room A3 Drinking Fountain	9/1/17 6:31	9/5/2017	50761	LEAD	<1 PPB	15 PPB
049-18-2A Room A4 Sink Faucet	9/1/17 6:33	9/5/2017	50762	LEAD	2 PPB	15 PPB
049-19-2A Room A4 Drinking Fountain	9/1/17 6:34	9/5/2017	50763	LEAD	1 PPB	15 PPB
049-20-2A Room A5 Sink Faucet	9/1/17 6:36	9/5/2017	50764	LEAD	1 PPB	15 PPB
049-21-2A Room A5 Drinking Fountain	9/1/17 6:37	9/5/2017	50765	LEAD	<1 PPB	15 PPB
049-22-2A Room A5 Sink Faucet	9/1/17 6:39	9/5/2017	50766	LEAD	1 PPB	15 PPB
049-23-2A Room A6 Sink Faucet	9/1/17 6:41	9/5/2017	50767	LEAD	2 PPB	15 PPB
049-24-2A Room A6 Sink Faucet	9/1/17 6:41	9/5/2017	50768	LEAD	1 PPB	15 PPB
049-25-2A Room A6 Drinking Fountain	9/1/17 6:42	9/5/2017	50769	LEAD	<1 PPB	15 PPB



Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Scott Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
049-26-2A Hall Drinking Fountain 2	9/1/17 6:44	9/5/2017	50770	LEAD	3 PPB	15 PPB
049-27-2A Main Office Sink Faucet	9/1/17 6:46	9/5/2017	50771	LEAD	<1 PPB	15 PPB
049-28-2A Craft Room Sink Faucet	9/1/17 6:48	9/5/2017	50772	LEAD	2 PPB	15 PPB
049-29-2A Media Room Drinking Fountain	9/1/17 6:50	9/5/2017	50773	LEAD	<1 PPB	15 PPB
049-30-2A Hall Drinking Fountain 3	9/1/17 6:52	9/5/2017	50774	LEAD	2 PPB	15 PPB
049-31-2A Room B1 Sink Faucet	9/1/17 6:54	9/5/2017	50775	LEAD	2 PPB	15 PPB
049-32-2A Room B1 Drinking Fountain	9/1/17 6:55	9/5/2017	50776	LEAD	<1 PPB	15 PPB
049-33-2A Room B2 Sink Faucet	9/1/17 6:56	9/5/2017	50777	LEAD	1 PPB	15 PPB
049-34-2A Room B2 Drinking Fountain	9/1/17 6:57	9/5/2017	50778	LEAD	<1 PPB	15 PPB
049-35-2A Room B3 Sink Faucet	9/1/17 6:59	9/5/2017	50779	LEAD	1 PPB	15 PPB
049-36-2A Room B3 Drinking Fountain	9/1/17 7:00	9/5/2017	50780	LEAD	<1 PPB	15 PPB
049-37-2A Room B4 Sink Faucet	9/1/17 7:02	9/5/2017	50781	LEAD	<1 PPB	15 PPB
049-38-2A Room B4 Drinking Fountain	9/1/17 7:03	9/5/2017	50782	LEAD	<1 PPB	15 PPB
049-39-2A Room B5 Sink Faucet	9/1/17 7:05	9/5/2017	50783	LEAD	<1 PPB	15 PPB
049-40-2A Room B5 Drinking Fountain	9/1/17 7:06	9/5/2017	50784	LEAD	1 PPB	15 PPB
049-41-2A Room B6 Sink Faucet	9/1/17 7:08	9/5/2017	50785	LEAD	<1 PPB	15 PPB
049-42-2A Room B6 Drinking Fountain	9/1/17 7:08	9/5/2017	50786	LEAD	<1 PPB	15 PPB
049-43-2A Hall Drinking Fountain 4	9/1/17 7:10	9/5/2017	50787	LEAD	<1 PPB	15 PPB
049-44-2A Room C1 Sink Faucet	9/1/17 7:12	9/5/2017	50788	LEAD	1 PPB	15 PPB
049-45-2A Room C1 Drinking Fountain	9/1/17 7:13	9/5/2017	50789	LEAD	<1 PPB	15 PPB
049-46-2A Room C2 Sink Faucet	9/1/17 7:15	9/5/2017	50790	LEAD	1 PPB	15 PPB
049-47-2A Room C2 Drinking Fountain	9/1/17 7:16	9/5/2017	50791	LEAD	<1 PPB	15 PPB
049-48-2A Room C3 Sink Faucet	9/1/17 7:18	9/5/2017	50792	LEAD	<1 PPB	15 PPB
049-49-2A Room C3 Drinking Fountain	9/1/17 7:17	9/5/2017	50793	LEAD	<1 PPB	15 PPB

Salem-Keizer Public Schools  
 Lead Water Sampling Results  
 First Draw (A) Sample Data  
 Scott Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
049-50-2A Room C4 Sink Faucet	9/1/17 7:21	9/5/2017	50794	LEAD	<1 PPB	15 PPB
049-51-2A Room C4 Drinking Fountain	9/1/17 7:22	9/5/2017	50795	LEAD	<1 PPB	15 PPB
049-52-2A Room C5 Sink Faucet	9/1/17 7:24	9/5/2017	50796	LEAD	<1 PPB	15 PPB
049-53-2A Room C5 Drinking Fountain	9/1/17 7:25	9/5/2017	50797	LEAD	<1 PPB	15 PPB
049-54-2A Room C6 Sink Faucet	9/1/17 7:27	9/5/2017	50798	LEAD	<1 PPB	15 PPB
049-55-2A Room C6 Drinking Fountain	9/1/17 7:28	9/5/2017	50799	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Scott Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
049-65A Gym Hall Drinking Fountain	12/15/2017 6:12:00AM	12/19/2017	79340	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**