

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
South Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
50-01A North Dining Room Drinking Fountain	7/30/16 12:31 PM	8/5/2016	1608182-01A	LEAD	<1.0 PPB	15 PPB
50-02A North Dining Snack Shack Sink Faucet	7/30/16 12:32 PM	8/6/2016	1608182-02A	LEAD	4 PPB	15 PPB
50-03A Kitchen Side Wall Sink Faucet	7/30/16 12:30 PM	8/5/2016	1608182-03A	LEAD	<1.0 PPB	15 PPB
50-04A Kitchen Center Sink Faucet	7/30/16 12:34 PM	8/6/2016	1608182-04A	LEAD	17 PPB	15 PPB
50-05A Kitchen Back Wall Sink Faucet	7/30/16 1:10 PM	8/5/2016	1608182-05A	LEAD	4 PPB	15 PPB
50-06A Cafeteria Drinking Fountain (Left)	7/30/16 12:37 PM	8/5/2016	1608182-06A	LEAD	<1.0 PPB	15 PPB
50-07A Cafeteria Drinking Fountain (Right)	7/30/16 12:37 PM	8/5/2016	1608182-07A	LEAD	<1.0 PPB	15 PPB
50-08A Room 18 Drinking Fountain	7/30/16 4:33 PM	8/5/2016	1608182-08A	LEAD	<1.0 PPB	15 PPB
50-09A Room 10 Sink Faucet (Left)	7/30/16 12:44 PM	8/5/2016	1608182-09A	LEAD	2 PPB	15 PPB
50-10A Room 10 Sink Faucet (Right)	7/30/16 12:44 PM	8/5/2016	1608182-10A	LEAD	2 PPB	15 PPB
50-11A Room B-3 Sink Faucet (Left)	7/30/16 1:01 PM	8/5/2016	1608182-11A	LEAD	<1.0 PPB	15 PPB
50-12A Room B-3 Sink Faucet (Right)	7/30/16 1:01 PM	8/5/2016	1608182-12A	LEAD	1 PPB	15 PPB
50-13A Auxillary Gymnasium Drinking Fountain	7/30/16 1:44 PM	8/7/2016	1608182-13A	LEAD	10 PPB	15 PPB
50-14A Room 100 Sink Faucet	7/30/16 1:46 PM	8/5/2016	1608182-14A	LEAD	<1.0 PPB	15 PPB
50-15A Room 185 Sink Faucet	7/30/16 1:53 PM	8/5/2016	1608182-15A	LEAD	2 PPB	15 PPB
50-16A Hall Drinking Fountain 1	7/30/16 1:52 PM	8/6/2016	1608182-16A	LEAD	1 PPB	15 PPB
50-17A Room 182 Sink Faucet	7/30/16 1:48 PM	8/6/2016	1608182-17A	LEAD	2 PPB	15 PPB
50-18A Hall Drinking Fountain 2	7/30/16 1:50 PM	8/6/2016	1608182-18A	LEAD	<1.0 PPB	15 PPB
50-19A Staff Room Sink Faucet (Left)	7/30/16 1:55 PM	8/6/2016	1608182-19A	LEAD	<1.0 PPB	15 PPB
50-20A Staff Room Sink Faucet (Right)	7/30/16 1:55 PM	8/6/2016	1608182-20A	LEAD	<1.0 PPB	15 PPB
50-22A Auditorium Hall W Drinking Fountain	7/30/16 1:57 PM	8/6/2016	1608182-21A	LEAD	<1.0 PPB	15 PPB
50-23A Hall Outside Theater Sink Faucet	7/30/16 1:59 PM	8/6/2016	1608182-22A	LEAD	<1.0 PPB	15 PPB
50-24A Room 151 Sink Faucet (Left)	7/30/16 2:02 PM	8/6/2016	1608182-23A	LEAD	4 PPB	15 PPB
50-25A Room 151 Sink Faucet (Right)	7/30/16 2:02 PM	8/6/2016	1608182-24A	LEAD	3 PPB	15 PPB
50-26A Auditorium Hall South Drinking Fountain 3	7/30/16 2:02 PM	8/6/2016	1608182-25A	LEAD	3 PPB	15 PPB
50-27A Room 146 Sink Faucet	7/30/16 2:10 PM	8/6/2016	1608182-26A	LEAD	2 PPB	15 PPB
50-28A Hall Drinking Fountain Near Custodial Office 4	7/30/16 2:10 PM	8/6/2016	1608182-27A	LEAD	<1.0 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
South Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
50-29A Custodial Office Sink Faucet	7/30/16 2:13 PM	8/6/2016	1608182-28A	LEAD	4 PPB	15 PPB
50-30A Main Office by Conference Room Sink Faucet	7/30/16 2:21 PM	8/6/2016	1608182-29A	LEAD	<1.0 PPB	15 PPB
50-31A Student Store Sink Faucet	7/30/16 2:23 PM	8/6/2016	1608182-30A	LEAD	<1.0 PPB	15 PPB
50-32A Hall by Student Store Drinking Fountain 5	7/30/16 2:26 PM	8/6/2016	1608182-31A	LEAD	<1.0 PPB	15 PPB
50-33A Hall South Drinking Fountain 6	7/30/16 2:30 PM	8/6/2016	1608182-32A	LEAD	<1.0 PPB	15 PPB
50-34A Room 111 Sink Faucet	7/30/16 2:31 PM	8/6/2016	1608182-33A	LEAD	6 PPB	15 PPB
50-35A Room 111 Drinking Fountain	7/30/16 2:31 PM	8/6/2016	1608182-34A	LEAD	14 PPB	15 PPB
50-36A Room 111/112 Work Room Sink Faucet	7/30/16 2:32 PM	8/6/2016	1608182-35A	LEAD	<1.0 PPB	15 PPB
50-37A Room 112 Sink Faucet	7/30/16 2:34 PM	8/6/2016	1608182-36A	LEAD	5 PPB	15 PPB
50-38A Room 128 Sink Faucet 1	7/30/16 2:37 PM	8/6/2016	1608182-37A	LEAD	3 PPB	15 PPB
50-39A Room 128 Sink Faucet 2	7/30/16 2:38 PM	8/6/2016	1608182-38A	LEAD	1 PPB	15 PPB
50-40A Room 128 Sink Faucet 3	7/30/16 2:39 PM	8/6/2016	1608182-39A	LEAD	2 PPB	15 PPB
50-41A Room 128 Sink Faucet 4	7/30/16 2:39 PM	8/6/2016	1608182-40A	LEAD	3 PPB	15 PPB
50-42A Room 128 Sink Faucet 5	7/30/16 2:40 PM	8/6/2016	1608182-41A	LEAD	4 PPB	15 PPB
50-43A Room 128 Sink Faucet 6	7/30/16 2:40 PM	8/6/2016	1608182-42A	LEAD	5 PPB	15 PPB
50-44A Room 128 Sink Faucet 7	7/30/16 2:41 PM	8/6/2016	1608182-43A	LEAD	<1.0 PPB	15 PPB
50-45A Hall South Near Room 113 Drinking Fountain 7	7/30/16 2:51 PM	8/6/2016	1608182-44A	LEAD	1 PPB	15 PPB
50-46A Girl's Locker Room Drinking Fountain (Left)	7/30/16 2:53 PM	8/6/2016	1608182-45A	LEAD	4 PPB	15 PPB
50-47A Girl's Locker Room Drinking Fountain (Right)	7/30/16 2:54 PM	8/6/2016	1608182-46A	LEAD	25 PPB	15 PPB
50-48A Gymnasium Southwest Side Drinking Fountain	7/30/16 2:58 PM	8/6/2016	1608182-47A	LEAD	<1.0 PPB	15 PPB
50-49A Gymnasium Southeast Corner Drinking Fountain	7/30/16 3:02 PM	8/6/2016	1608182-48A	LEAD	<1.0 PPB	15 PPB
50-50A Gymnasium Hall Drinking Fountain	7/30/16 2:58 PM	8/6/2016	1608182-49A	LEAD	<1.0 PPB	15 PPB
50-51A Boy's Locker Room Drinking Fountain (Left)	7/30/16 3:06 PM	8/6/2016	1608182-50A	LEAD	<1.0 PPB	15 PPB
50-52A Boy's Locker Room Drinking Fountain (Right)	7/30/16 3:07 PM	8/6/2016	1608182-51A	LEAD	<1.0 PPB	15 PPB
50-53A Boy's Locker Room Back Wall Drinking Fountain	7/30/16 3:11 PM	8/6/2016	1608182-52A	LEAD	<1.0 PPB	15 PPB
50-54A Team Locker Room Drinking Fountain (Left)	7/30/16 3:06 PM	8/6/2016	1608182-53A	LEAD	6 PPB	15 PPB
50-55A Team Locker Room Drinking Fountain (Right)	7/30/16 3:06 PM	8/6/2016	1608182-54A	LEAD	<1.0 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
South Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
50-56A Team Locker Room Drinking Fountain Back	7/30/16 3:11 PM	8/6/2016	1608182-55A	LEAD	2 PPB	15 PPB
50-57A Training Room Sink Faucet	7/30/16 3:15 PM	8/6/2016	1608182-56A	LEAD	<1.0 PPB	15 PPB
50-58A 2nd Floor Hall Drinking Fountain 8	7/30/16 3:33 PM	8/6/2016	1608182-57A	LEAD	<1.0 PPB	15 PPB
50-59A West Balcony Gymnasium Drinking Fountain	7/30/16 3:32 PM	8/6/2016	1608182-58A	LEAD	<1.0 PPB	15 PPB
50-60A Hall Drinking Fountain 9	7/30/16 3:35 PM	8/6/2016	1608182-59A	LEAD	<1.0 PPB	15 PPB
50-61A 2nd Floor Hall Southwest Corner Drinking Fountain 10	7/30/16 3:42 PM	8/6/2016	1608182-60A	LEAD	9 PPB	15 PPB
50-62A 2nd Floor Hall East Drinking Fountain 11	7/30/16 3:39 PM	8/6/2016	1608182-61A	LEAD	<1.0 PPB	15 PPB
50-63A Room 234 Sink Faucet	7/30/16 3:40 PM	8/6/2016	1608182-62A	LEAD	9 PPB	15 PPB
50-64A Hall Northeast Drinking Fountain 12	7/30/16 3:43 PM	8/6/2016	1608182-63A	LEAD	<1.0 PPB	15 PPB
50-65A Room 239 Sink Faucet	7/30/16 3:47 PM	8/6/2016	1608182-64A	LEAD	13 PPB	15 PPB
50-66A Room 251 Sink Faucet	7/30/16 3:47 PM	8/6/2016	1608182-65A	LEAD	3 PPB	15 PPB
50-67A Room 250 Sink Faucet	7/30/16 3:49 PM	8/6/2016	1608182-66A	LEAD	10 PPB	15 PPB
50-68A Room 240 Sink Faucet	7/30/16 3:49 PM	8/6/2016	1608182-67A	LEAD	5 PPB	15 PPB
50-69A Room 241 Sink Faucet	7/30/16 3:52 PM	8/6/2016	1608182-68A	LEAD	4 PPB	15 PPB
50-70A Room 242 Sink Faucet	7/30/16 3:54 PM	8/6/2016	1608182-69A	LEAD	14 PPB	15 PPB
50-71A Room 243 Sink Faucet	7/30/16 3:55 PM	8/6/2016	1608182-70A	LEAD	6 PPB	15 PPB
50-72A Room 244 Sink Faucet	7/30/16 3:58 PM	8/6/2016	1608182-71A	LEAD	<1.0 PPB	15 PPB
50-73A 2nd Hall Drinking Fountain 13	7/30/16 4:00 PM	8/6/2016	1608182-72A	LEAD	5 PPB	15 PPB
50-74A 2nd Floor Hall Drinking Fountain 14	7/30/16 4:03 PM	8/6/2016	1608182-73A	LEAD	5 PPB	15 PPB
50-75A 2nd Floor Hall Drinking Fountain 15	7/30/16 4:03 PM	8/6/2016	1608182-74A	LEAD	<1.0 PPB	15 PPB
50-76A 2nd Floor Hall Near Room 244 Drinking Fountain 16	7/30/16 3:57 PM	8/6/2016	1608182-75A	LEAD	4 PPB	15 PPB
50-77A Concession Stand Sink Faucet	7/30/16 4:20 PM	8/6/2016	1608182-76A	LEAD	6 PPB	15 PPB
50-78A Room B-3 Drinking Fountain	7/30/16 1:09 PM	8/6/2016	1608182-77A	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
 Lead Water Sampling Results
 Flushed (B) Sample Data
 South Salem High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Tested For	Result	Action Level
50-04B Kitchen Center Sink Faucet	7/30/16 12:35 AM	8/24/2016	1608183-04A	LEAD	<1 PPB	15 PPB
50-47B Girls' Locker Room Drinking Fountain (Right)	7/30/16 12:35 AM	8/24/2016	1608183-46A	LEAD	3 PPB	15 PPB
EPA Action Level for Lead in Schools is 20 PPB						
SKPS Action Level for Lead is 15 PPB						
Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level						

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (C) Sample Data
South Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
50-04C Kitchen Center Sink Faucet	1/20/2017 5:17	1/23/2017	3128	LEAD	<1.0 PPB	15 PPB
50-47C Girl's Locker Room Drinking Fountain (Right)	1/20/2017 5:30	1/23/2017	3129	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
 Lead Water Sampling Results
 First Draw (A) Sample Data
 South Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
50-79A Training Room Whirlpool Wall Mount Faucet	6/9/2017 6:14:00AM	6/13/2017	30993	LEAD	7 PPB	15 PPB
50-80A Training Room Ice Machine	6/9/2017 6:16:00AM	6/13/2017	30994	LEAD	<1 PPB	15 PPB
50-81A Receiving Room Sink Faucet	6/9/2017 6:40:00AM	6/13/2017	30995	LEAD	1 PPB	15 PPB
50-82A Boiler Room Sink Faucet	6/9/2017 6:42:00AM	6/13/2017	30996	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level