

Salem Keizer School District
Copper Water Sampling Results
First Draw (A) Sample Data
Stephens Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
052-01A Kitchen Ice Maker	7/27/16 10:36	8/3/16 11:12	607284201	COPPER	0.1 PPM	1.3 PPM
052-02A Kitchen Food Prep Sink Faucet	7/27/16 10:34	8/3/16 11:13	607284202	COPPER	0.0 PPM	1.3 PPM
052-03A Hallway Drinking Fountain 1	7/27/16 10:30	8/3/16 11:13	607284203	COPPER	0.3 PPM	1.3 PPM
052-04A Hallway Drinking Fountain 2	7/27/16 10:31	8/3/16 11:13	607284204	COPPER	0.4 PPM	1.3 PPM
052-05A Concessions/Student Store Sink	7/27/16 10:42	8/3/16 11:13	607284205	COPPER	0.2 PPM	1.3 PPM
052-06A Gymnasium Drinking Fountain	7/27/16 10:46	8/3/16 11:14	607284206	COPPER	0.3 PPM	1.3 PPM
052-07A Hallway Drinking Fountain 3	7/27/16 10:48	8/3/16 11:14	607284207	COPPER	0.5 PPM	1.3 PPM
052-08A Auxillary Gymnasium Drinking Fountain 1	7/27/16 10:55	8/3/16 11:14	607284208	COPPER	0.5 PPM	1.3 PPM
052-09A Auxillary Gymnasium Drinking Fountain 2	7/27/16 10:56	8/3/16 11:15	607284209	COPPER	0.6 PPM	1.3 PPM
052-10A Auxillary Gymnasium Drinking Fountain 3	7/27/16 10:53	8/3/16 11:21	607284210	COPPER	0.4 PPM	1.3 PPM
052-11A Technology 128 Drinking Fountain	7/27/16 11:00	8/3/16 11:21	607284211	COPPER	0.7 PPM	1.3 PPM
052-12A Band 129 Drinking Fountain	7/27/16 11:02	8/3/16 11:22	607284212	COPPER	0.3 PPM	1.3 PPM
052-13A Home Economics Sink Faucet 1	7/27/16 11:11	8/3/16 11:24	607284213	COPPER	0.3 PPM	1.3 PPM
052-14A Home Economics Sink Faucet 2	7/27/16 11:12	8/3/16 11:24	607284214	COPPER	0.4 PPM	1.3 PPM
052-15A Home Economics Sink Faucet 3	7/27/16 11:13	8/3/16 11:24	607284215	COPPER	0.6 PPM	1.3 PPM
052-16A Home Economics Sink Faucet 4	7/27/16 11:14	8/3/16 11:25	607284216	COPPER	0.4 PPM	1.3 PPM
052-17A Home Economics Sink Faucet 5	7/27/16 11:15	8/3/16 11:25	607284217	COPPER	0.3 PPM	1.3 PPM
052-18A Home Economics Sink Faucet 6	7/27/16 11:16	8/3/16 11:25	607284218	COPPER	0.3 PPM	1.3 PPM
052-21A Choir 130 Drinking Fountain	7/27/16 11:20	8/3/16 11:26	607284219	COPPER	0.3 PPM	1.3 PPM
052-22A Hallway Drinking Fountain 4	7/27/16 11:23	8/3/16 11:33	607284220	COPPER	0.3 PPM	1.3 PPM
052-23A Hallway Drinking Fountain 5	7/27/16 11:24	8/3/16 11:33	607284221	COPPER	0.1 PPM	1.3 PPM
052-24A Room 124 Drinking Fountain	7/27/16 11:25	8/3/16 11:33	607284222	COPPER	0.3 PPM	1.3 PPM
052-25A Room 124 Sink Faucet	7/27/16 11:25	8/3/16 11:34	607284223	COPPER	0.3 PPM	1.3 PPM
052-26A Room 123 Sink Faucet	7/27/16 11:28	8/3/16 11:34	607284224	COPPER	0.2 PPM	1.3 PPM
052-27A Room 123 Drinking Fountain	7/27/16 11:28	8/3/16 11:34	607284225	COPPER	0.1 PPM	1.3 PPM
052-28A Nurse Sink Faucet	7/27/16 11:32	8/3/16 11:34	607284226	COPPER	0.2 PPM	1.3 PPM
052-29A Office Sink Faucet	7/27/16 11:33	8/3/16 11:35	607284227	COPPER	0.4 PPM	1.3 PPM
052-30A Room 121 Drinking Fountain	7/27/16 11:35	8/3/16 11:35	607284228	COPPER	0.1 PPM	1.3 PPM
052-31A Room 121 Sink Faucet	7/27/16 11:35	8/3/16 11:35	607284229	COPPER	0.3 PPM	1.3 PPM
052-32A Room 100 Drinking Fountain	7/27/16 11:39	8/3/16 11:40	607284230	COPPER	0.4 PPM	1.3 PPM
052-33A Room 100 Sink Faucet	7/27/16 11:39	8/3/16 11:40	607284231	COPPER	0.4 PPM	1.3 PPM
052-34A Room 101 Drinking Fountain	7/27/16 11:44	8/3/16 11:41	607284232	COPPER	0.1 PPM	1.3 PPM
052-35A Room 101 Sink Faucet	7/27/16 11:44	8/3/16 11:41	607284233	COPPER	0.5 PPM	1.3 PPM
052-36A Room 120 Sink Faucet	7/27/16 11:48	8/3/16 11:41	607284234	COPPER	0.1 PPM	1.3 PPM
052-37A Room 120 Drinking Fountain	7/27/16 11:48	8/3/16 11:41	607284235	COPPER	0.4 PPM	1.3 PPM
052-38A Staff Lounge 102 Sink Faucet	7/27/16 11:52	8/3/16 11:41	607284236	COPPER	0.3 PPM	1.3 PPM
052-39A Room 119 Sink Faucet	7/27/16 11:53	8/3/16 11:42	607284237	COPPER	0.3 PPM	1.3 PPM
052-40A Hallway Drinking Fountain 6	7/27/16 12:02	8/3/16 11:42	607284238	COPPER	0.4 PPM	1.3 PPM
052-41A Hallway Drinking Fountain 7	7/27/16 12:03	8/3/16 13:22	607284239	COPPER	0.3 PPM	1.3 PPM
052-42A Room 104 Sink Faucet	7/27/16 12:05	8/3/16 11:47	607284240	COPPER	0.3 PPM	1.3 PPM
052-44A Room 105 Sink Faucet	7/27/16 12:07	8/3/16 11:48	607284241	COPPER	0.4 PPM	1.3 PPM
052-45A Room 105 Drinking Fountain	7/27/16 12:07	8/3/16 11:48	607284242	COPPER	0.5 PPM	1.3 PPM
052-46A Room 106 Drinking Fountain	7/27/16 12:10	8/3/16 11:48	607284243	COPPER	0.5 PPM	1.3 PPM
052-47A Room 106 Sink Faucet	7/27/16 12:10	8/3/16 11:48	607284244	COPPER	0.3 PPM	1.3 PPM
052-48A Room 107 Sink Faucet	7/27/16 12:14	8/3/16 11:48	607284245	COPPER	0.5 PPM	1.3 PPM
052-49A Room 107 Drinking Fountain	7/27/16 12:14	8/3/16 11:48	607284246	COPPER	0.4 PPM	1.3 PPM
052-50A Room 108 Drinking Fountain	7/27/16 12:17	8/3/16 11:49	607284247	COPPER	0.5 PPM	1.3 PPM
052-51A Room 108 Sink Faucet	7/27/16 12:17	8/3/16 11:49	607284248	COPPER	0.4 PPM	1.3 PPM
052-52A Room 109 Sink Faucet	7/27/16 12:19	8/3/16 11:50	607284249	COPPER	0.3 PPM	1.3 PPM
052-53A Room 109 Drinking Fountain	7/27/16 12:19	8/3/16 11:54	607284250	COPPER	0.3 PPM	1.3 PPM
052-54A Room 112 Drinking Fountain	7/27/16 12:29	8/3/16 11:54	607284251	COPPER	0.4 PPM	1.3 PPM
052-55A Room 112 Sink Faucet	7/27/16 12:29	8/3/16 11:54	607284252	COPPER	0.4 PPM	1.3 PPM
052-56A Room 113 Sink Faucet	7/27/16 12:32	8/3/16 11:55	607284253	COPPER	0.4 PPM	1.3 PPM

Salem Keizer School District
Copper Water Sampling Results
A (First Draw) Sample Data
Stephens Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
052-57A Room 113 Drinking Fountain	7/27/16 12:32	8/3/16 11:55	607284254	COPPER	0.3 PPM	1.3 PPM
052-58A Room 114 Drinking Fountain	7/27/16 12:35	8/3/16 11:55	607284255	COPPER	0.3 PPM	1.3 PPM
052-59A Room 114 Sink Faucet	7/27/16 12:35	8/3/16 11:55	607284256	COPPER	0.4 PPM	1.3 PPM
052-60A Hallway Drinking Fountain 8	7/27/16 12:35	8/3/16 11:55	607284257	COPPER	0.4 PPM	1.3 PPM
052-61A Hallway Drinking Fountain 9	7/27/16 12:35	8/3/16 11:56	607284258	COPPER	0.4 PPM	1.3 PPM
052-62A Room 115 Sink Faucet	7/27/16 12:22	8/3/16 11:56	607284259	COPPER	0.4 PPM	1.3 PPM
052-63A Room 115 Drinking Fountain	7/27/16 12:22	8/3/16 12:03	607284260	COPPER	0.4 PPM	1.3 PPM
052-64A Room 116 Sink Faucet	7/27/16 12:39	8/3/16 12:03	607284261	COPPER	0.5 PPM	1.3 PPM
052-65A Room 116 Drinking Fountain	7/27/16 12:39	8/3/16 12:04	607284262	COPPER	0.4 PPM	1.3 PPM
052-66A Room 117 Drinking Fountain	7/27/16 12:28	8/3/16 12:04	607284263	COPPER	0.4 PPM	1.3 PPM
052-67A Room 117 Sink Faucet	7/27/16 12:27	8/3/16 12:04	607284264	COPPER	0.3 PPM	1.3 PPM
052-68A Room 217 Drinking Fountain	7/27/16 10:30	8/3/16 12:04	607284265	COPPER	0.4 PPM	1.3 PPM
052-69A Room 217 Sink Faucet	7/27/16 10:31	8/3/16 12:04	607284266	COPPER	0.4 PPM	1.3 PPM
052-70A Room 216 Drinking Fountain	7/27/16 10:35	8/3/16 12:05	607284267	COPPER	0.5 PPM	1.3 PPM
052-71A Room 216 Sink Faucet	7/27/16 10:36	8/3/16 12:05	607284268	COPPER	0.5 PPM	1.3 PPM
052-72A Hallway Drinking Fountain 10	7/27/16 10:40	8/3/16 12:06	607284269	COPPER	0.5 PPM	1.3 PPM
052-73A Hallway Drinking Fountain 11	7/27/16 10:40	8/3/16 12:17	607284270	COPPER	0.4 PPM	1.3 PPM
052-74A Room 215 Sink Faucet	7/27/16 10:49	8/3/16 12:18	607284271	COPPER	0.6 PPM	1.3 PPM
052-75A Room 215 Drinking Fountain	7/27/16 10:50	8/3/16 12:18	607284272	COPPER	0.7 PPM	1.3 PPM
052-76A Room 214 Drinking Fountain	7/27/16 10:53	8/3/16 12:18	607284273	COPPER	0.4 PPM	1.3 PPM
052-77A Room 214 Sink Faucet	7/27/16 10:54	8/3/16 12:18	607284274	COPPER	0.6 PPM	1.3 PPM
052-78A Room 213 Sink Faucet	7/27/16 10:59	8/3/16 12:18	607284275	COPPER	0.4 PPM	1.3 PPM
052-79A Room 213 Drinking Fountain	7/27/16 10:59	8/3/16 12:19	607284276	COPPER	0.4 PPM	1.3 PPM
052-80A Room 212 Drinking Fountain	7/27/16 11:02	8/3/16 12:19	607284277	COPPER	0.3 PPM	1.3 PPM
052-81A Room 212 Sink Faucet	7/27/16 11:03	8/3/16 12:19	607284278	COPPER	0.3 PPM	1.3 PPM
052-82A Hallway Drinking Fountain 12	7/27/16 11:49	8/3/16 12:19	607284279	COPPER	0.5 PPM	1.3 PPM
052-83A Hallway Drinking Fountain 13	7/27/16 11:50	8/3/16 12:21	607284280	COPPER	0.4 PPM	1.3 PPM
052-84A Room 204 Sink Faucet	7/27/16 11:36	8/3/16 12:22	607284281	COPPER	0.3 PPM	1.3 PPM
052-85A Room 204 Drinking Fountain	7/27/16 11:36	8/3/16 12:22	607284282	COPPER	0.4 PPM	1.3 PPM
052-86A Room 205 Sink Faucet	7/27/16 11:45	8/3/16 12:22	607284283	COPPER	0.5 PPM	1.3 PPM
052-87A Room 205 Drinking Fountain	7/27/16 11:45	8/3/16 12:22	607284284	COPPER	0.5 PPM	1.3 PPM
052-88A Room 206 Drinking Fountain	7/27/16 11:41	8/3/16 12:23	607284285	COPPER	0.5 PPM	1.3 PPM
052-89A Room 206 Sink Faucet	7/27/16 11:42	8/3/16 12:23	607284286	COPPER	0.4 PPM	1.3 PPM
052-90A Room 207 Sink Faucet	7/27/16 11:15	8/3/16 12:23	607284287	COPPER	0.4 PPM	1.3 PPM
052-91A Room 207 Drinking Fountain	7/27/16 11:16	8/3/16 12:23	607284288	COPPER	0.4 PPM	1.3 PPM
052-92A Room 208 Drinking Fountain	7/27/16 11:20	8/3/16 12:24	607284289	COPPER	0.5 PPM	1.3 PPM
052-93A Room 208 Sink Faucet	7/27/16 11:21	8/3/16 12:26	607284290	COPPER	0.5 PPM	1.3 PPM
052-94A Room 209 Sink Faucet	7/27/16 11:24	8/3/16 12:26	607284291	COPPER	0.5 PPM	1.3 PPM
052-95A Room 209 Drinking Fountain	7/27/16 11:24	8/3/16 12:26	607284292	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem Keizer School District
Copper Water Sampling Results
First Draw (A) Sample Data
Stephens Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
052-43A Room 104 Drinking Fountain	9/30/2016 5:55	10/3/2016	59710	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level