

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Sumpter Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
054-01A Gymnasium Drinking Fountain	7/29/16 8:52	8/5/16 13:06	608012801	COPPER	0.2 PPM	1.3 PPM
054-02A Hallway Drinking Fountain 1	7/29/16 8:54	8/5/16 13:06	608012802	COPPER	0.3 PPM	1.3 PPM
054-03A Store Room Sink Faucet	7/29/16 8:59	8/5/16 13:06	608012803	COPPER	0.5 PPM	1.3 PPM
054-04A Music Room Sink Faucet	7/29/16 9:02	8/5/16 13:06	608012804	COPPER	0.3 PPM	1.3 PPM
054-05A Music Room Drinking Fountain	7/29/16 9:02	8/5/16 13:06	608012805	COPPER	0.6 PPM	1.3 PPM
054-06A Hallway Drinking Fountain 2	7/29/16 9:07	8/5/16 13:06	608012806	COPPER	0.2 PPM	1.3 PPM
054-07A Kitchen Food Prep Sink Faucet	7/29/16 9:09	8/5/16 13:06	608012807	COPPER	0.2 PPM	1.3 PPM
054-08A Faculty Lounge Sink Faucet	7/29/16 9:13	8/5/16 13:06	608012808	COPPER	0.1 PPM	1.3 PPM
054-09A Classroom A7 Sink Faucet	7/29/16 9:15	8/5/16 13:06	608012809	COPPER	0.4 PPM	1.3 PPM
054-10A Boys Bathroom Drinking Fountain	7/29/16 9:17	8/5/16 13:06	608012810	COPPER	0.2 PPM	1.3 PPM
054-11A Classroom A1 Sink Faucet	7/29/16 9:20	8/5/16 13:07	608012811	COPPER	0.2 PPM	1.3 PPM
054-12A Classroom A1 Drinking Fountain	7/29/16 9:20	8/5/16 13:07	608012812	COPPER	0.3 PPM	1.3 PPM
054-13A Classroom A2 Sink Faucet	7/29/16 9:24	8/5/16 13:07	608012813	COPPER	0.3 PPM	1.3 PPM
054-14A Classroom A2 Drinking Fountain	7/29/16 9:24	8/5/16 13:07	608012814	COPPER	0.3 PPM	1.3 PPM
054-15A Classroom A3 Sink Faucet	7/29/16 9:28	8/5/16 13:07	608012815	COPPER	0.3 PPM	1.3 PPM
054-16A Classroom A3 Drinking Fountain	7/29/16 9:28	8/5/16 13:07	608012816	COPPER	0.3 PPM	1.3 PPM
054-17A Classroom A4 Sink Faucet	7/29/16 9:33	8/5/16 13:07	608012817	COPPER	0.3 PPM	1.3 PPM
054-18A Classroom A4 Drinking Fountain	7/29/16 9:33	8/5/16 13:08	608012818	COPPER	0.4 PPM	1.3 PPM
054-19A Classroom A5 Sink Faucet	7/29/16 9:37	8/5/16 13:08	608012819	COPPER	0.4 PPM	1.3 PPM
054-20A Classroom A5 Drinking Fountain	7/29/16 9:37	8/5/16 13:08	608012820	COPPER	0.4 PPM	1.3 PPM
054-21A Classroom A6 Sink Faucet	7/29/16 9:41	8/5/16 13:08	608012821	COPPER	0.2 PPM	1.3 PPM
054-22A Classroom A6 Drinking Fountain	7/29/16 9:41	8/5/16 13:08	608012822	COPPER	0.3 PPM	1.3 PPM
054-23A Girls Bathroom Drinking Fountain	7/29/16 9:44	8/5/16 13:08	608012823	COPPER	0.2 PPM	1.3 PPM
054-24A Nurse Office Sink Faucet	7/29/16 9:47	8/5/16 13:08	608012824	COPPER	0.2 PPM	1.3 PPM
054-26A LRC Sink Faucet	7/29/16 9:56	8/5/16 13:08	608012825	COPPER	0.1 PPM	1.3 PPM
054-27A Hallway Drinking Fountain 3	7/29/16 10:00	8/5/16 13:08	608012826	COPPER	0.3 PPM	1.3 PPM
054-28A Classroom B1 Sink Faucet	7/29/16 10:03	8/5/16 13:08	608012827	COPPER	0.3 PPM	1.3 PPM
054-29A Classroom B1 Drinking Fountain	7/29/16 10:04	8/5/16 13:08	608012828	COPPER	0.2 PPM	1.3 PPM
054-30A Classroom B2 Sink Faucet	7/29/16 10:10	8/5/16 13:08	608012829	COPPER	0.3 PPM	1.3 PPM
054-31A Classroom B2 Drinking Fountain	7/29/16 10:10	8/5/16 13:08	608012830	COPPER	0.3 PPM	1.3 PPM
054-32A Classroom B3 Sink Faucet	7/29/16 10:14	8/5/16 13:08	608012831	COPPER	0.3 PPM	1.3 PPM
054-33A Classroom B3 Drinking Fountain	7/29/16 10:14	8/5/16 13:08	608012832	COPPER	0.2 PPM	1.3 PPM
054-34A Classroom B4 Sink Faucet	7/29/16 10:17	8/5/16 13:08	608012833	COPPER	0.3 PPM	1.3 PPM
054-35A Classroom B4 Drinking Fountain	7/29/16 10:17	8/5/16 13:08	608012834	COPPER	0.4 PPM	1.3 PPM
054-36A Classroom B5 Sink Faucet	7/29/16 10:21	8/5/16 13:08	608012835	COPPER	0.3 PPM	1.3 PPM
054-37A Classroom B5 Drinking Fountain	7/29/16 10:21	8/5/16 13:08	608012836	COPPER	0.3 PPM	1.3 PPM
054-38A Classroom B6 Sink Faucet	7/29/16 10:25	8/5/16 13:08	608012837	COPPER	0.4 PPM	1.3 PPM
054-39A Classroom B6 Drinking Fountain	7/29/16 10:25	8/5/16 13:08	608012838	COPPER	0.5 PPM	1.3 PPM
054-40A Hallway Drinking Fountain 4	7/29/16 10:28	8/5/16 13:08	608012839	COPPER	0.3 PPM	1.3 PPM
054-41A Classroom C1 Sink Faucet	7/29/16 10:31	8/5/16 13:08	608012840	COPPER	0.4 PPM	1.3 PPM
054-42A Classroom C1 Drinking Fountain	7/29/16 10:31	8/5/16 13:08	608012841	COPPER	0.6 PPM	1.3 PPM
054-43A Classroom C2 Sink Faucet	7/29/16 10:34	8/5/16 13:08	608012842	COPPER	0.2 PPM	1.3 PPM
054-44A Classroom C2 Drinking Fountain	7/29/16 10:34	8/5/16 13:08	608012843	COPPER	0.4 PPM	1.3 PPM
054-45A Classroom C3 Sink Faucet	7/29/16 10:39	8/5/16 13:09	608012844	COPPER	0.4 PPM	1.3 PPM
054-46A Classroom C3 Drinking Fountain	7/29/16 10:39	8/5/16 13:09	608012845	COPPER	0.3 PPM	1.3 PPM
054-47A Classroom C4 Sink Faucet	7/29/16 10:42	8/5/16 13:09	608012846	COPPER	0.3 PPM	1.3 PPM
054-48A Classroom C4 Drinking Fountain	7/29/16 10:42	8/5/16 13:09	608012847	COPPER	0.4 PPM	1.3 PPM
054-49A Classroom C5 Sink Faucet	7/29/16 10:45	8/5/16 13:09	608012848	COPPER	0.2 PPM	1.3 PPM
054-50A Classroom C5 Drinking Fountain	7/29/16 10:45	8/5/16 13:09	608012849	COPPER	0.2 PPM	1.3 PPM

Salem-Keizer Public Schools  
 Copper Water Sampling Results  
 First Draw (A) Sample Data  
 Sumpter Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
054-51A Classroom C6 Sink Faucet	7/29/16 10:50	8/5/16 13:09	608012850	COPPER	0.3 PPM	1.3 PPM
054-52A Classroom C6 Drinking Fountain	7/29/16 10:50	8/5/16 13:09	608012851	COPPER	0.2 PPM	1.3 PPM
054-53A Portable M1 Sink Faucet	7/29/16 10:59	8/5/16 13:09	608012852	COPPER	0.1 PPM	1.3 PPM
054-54A Portable M1 Drinking Fountain	7/29/16 10:59	8/5/16 13:09	608012853	COPPER	0.0 PPM	1.3 PPM
054-55A Portable M2 Sink Faucet	7/29/16 11:03	8/5/16 13:09	608012854	COPPER	0.1 PPM	1.3 PPM
054-56A Portable M2 Drinking Fountain	7/29/16 11:03	8/5/16 13:09	608012855	COPPER	0.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Copper Water Sampling Results  
Flushed (B) Sample Data  
Sumpter Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
054-03B Store Room Sink Faucet	7/29/16 9:00	8/24/16 12:48	608174001	COPPER	0.4 PPM	1.3 PPM
054-04B Music Room Sink Faucet	7/29/16 9:03	8/24/16 12:48	608174002	COPPER	0.4 PPM	1.3 PPM
054-34B Classroom B4 Sink Faucet	7/29/16 10:18	8/24/16 12:48	608174003	COPPER	0.3 PPM	1.3 PPM
054-39B Classroom B6 Drinking Fountain	7/29/16 10:26	8/25/16 14:40	608174004	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (C) Sample Data  
Sumpter Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
054-03C Store Room Sink Faucet	10/20/2016 5:42	10/21/2016	64455	COPPER	0.3 PPM	1.3 PPM
054-04C Music Room Sink Faucet	10/20/2016 5:44	10/21/2016	64456	COPPER	0.7 PPM	1.3 PPM
054-34C Classroom B4 Sink Faucet	10/20/2016 5:48	10/21/2016	64457	COPPER	0.3 PPM	1.3 PPM
054-39C Classroom B6 Drinking Fountain	10/20/2016 5:50	10/21/2016	64458	COPPER	0.6 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

**SKPS Action Level for Copper is 1.3 PPM**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**