

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Swegle Elementary School

Sample Identification # and Location		Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
055-01A	Hall Drinking Fountain 1	7/28/16 8:01	8/2/2016	1608007-01A	COPPER	0.4 PPM	1.3 PPM
055-02A	Room 10 Sink Faucet	7/28/16 8:14	8/2/2016	1608007-02A	COPPER	0.2 PPM	1.3 PPM
055-03A	Room 10 Drinking Fountain	7/28/16 8:14	8/2/2016	1608007-03A	COPPER	0.4 PPM	1.3 PPM
055-04A	Kitchen Sink Faucet (1)	7/28/16 8:11	8/3/2016	1608007-04A	COPPER	0.4 PPM	1.3 PPM
055-05A	Kitchen Sink Faucet (2)	7/28/16 8:10	8/2/2016	1608007-05A	COPPER	0.3 PPM	1.3 PPM
055-06A	Hall Drinking Fountain 2	7/28/16 8:19	8/2/2016	1608007-06A	COPPER	0.3 PPM	1.3 PPM
055-07A	Room 9 Drinking Fountain	7/28/16 8:29	8/2/2016	1608007-07A	COPPER	0.3 PPM	1.3 PPM
055-08A	Room 9 Sink Faucet	7/28/16 8:28	8/3/2016	1608007-08A	COPPER	0.3 PPM	1.3 PPM
055-09A	Room 8 Drinking Fountain	7/28/16 8:51	8/3/2016	1608007-09A	COPPER	0.2 PPM	1.3 PPM
055-10A	Room 8 Sink Faucet	7/28/16 8:51	8/2/2016	1608007-10A	COPPER	0.2 PPM	1.3 PPM
055-11A	Hal Drinking Fountain 3	7/28/16 8:53	8/2/2016	1608007-11A	COPPER	0.1 PPM	1.3 PPM
055-12A	Hall Drinking Fountain 4	7/28/16 8:53	8/2/2016	1608007-12A	COPPER	0.5 PPM	1.3 PPM
055-13A	Room 7 Drinking Fountain	7/28/16 8:58	8/2/2016	1608007-13A	COPPER	0.2 PPM	1.3 PPM
055-14A	Room 7 Sink Faucet	7/28/16 8:58	8/2/2016	1608007-14A	COPPER	0.5 PPM	1.3 PPM
055-15A	Room 6 Drinking Fountain	7/28/16 9:01	8/2/2016	1608007-15A	COPPER	0.1 PPM	1.3 PPM
055-16A	Room 6 Sink Faucet	7/28/16 9:02	8/2/2016	1608007-16A	COPPER	0.2 PPM	1.3 PPM
055-17A	Room 4 Sink Faucet	7/28/16 9:03	8/2/2016	1608007-17A	COPPER	0.2 PPM	1.3 PPM
055-18A	Room 4 Drinking Fountain	7/28/16 9:03	8/2/2016	1608007-18A	COPPER	0.4 PPM	1.3 PPM
055-19A	Room 5 Sink Faucet	7/28/16 9:10	8/2/2016	1608007-19A	COPPER	0.1 PPM	1.3 PPM
055-20A	Room 5 Drinking Fountain	7/28/16 9:10	8/2/2016	1608007-20A	COPPER	0.4 PPM	1.3 PPM
055-21A	Custodian Office Sink Faucet	7/28/16 9:21	8/3/2016	1608007-21A	COPPER	0.4 PPM	1.3 PPM
055-22A	Room 3 Sink Faucet	7/28/16 9:25	8/3/2016	1608007-22A	COPPER	0.1 PPM	1.3 PPM
055-23A	Room 3 Drinking Fountain	7/28/16 9:25	8/3/2016	1608007-23A	COPPER	0.4 PPM	1.3 PPM
055-24A	Hall Drinking Fountain 5	7/28/16 9:14	8/3/2016	1608007-24A	COPPER	0.2 PPM	1.3 PPM
055-25A	Room 2 Sink Faucet	7/28/16 9:31	8/3/2016	1608007-25A	COPPER	0.2 PPM	1.3 PPM
055-26A	Room 2 Drinking Fountain	7/28/16 9:30	8/3/2016	1608007-26A	COPPER	0.5 PPM	1.3 PPM
055-27A	Room 1 Sink Faucet	7/28/16 10:11	8/3/2016	1608007-27A	COPPER	0.2 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Swegle Elementary School

055-28A	Room 1 Drinking Fountain	7/28/16 10:11	8/3/2016	1608007-28A	COPPER	0.2 PPM	1.3 PPM
055-29A	Staff Room Sink Faucet	7/28/16 10:29	8/3/2016	1608007-29A	COPPER	0.2 PPM	1.3 PPM
055-30A	Room 11 Sink Faucet	7/28/16 10:38	8/3/2016	1608007-30A	COPPER	0.2 PPM	1.3 PPM
055-31A	Room 11 Drinking Fountain	7/28/16 10:38	8/3/2016	1608007-31A	COPPER	0.3 PPM	1.3 PPM
055-32A	Room 12 Sink Faucet	7/28/16 10:37	8/3/2016	1608007-32A	COPPER	0.3 PPM	1.3 PPM
055-33A	Room 12 Drinking Fountain	7/28/16 10:37	8/3/2016	1608007-33A	COPPER	0.3 PPM	1.3 PPM
055-34A	Hall Drinking Fountain 6	7/28/16 10:49	8/4/2016	1608007-34A	COPPER	1.1 PPM	1.3 PPM
055-35A	Hall Drinking Fountain 7	7/28/16 10:49	8/4/2016	1608007-35A	COPPER	1.1 PPM	1.3 PPM
055-36A	Media Center Sink Faucet	7/28/16 10:39	8/3/2016	1608007-36A	COPPER	0.7 PPM	1.3 PPM
055-37A	Room 13 Sink Faucet	7/28/16 10:58	8/3/2016	1608007-37A	COPPER	0.4 PPM	1.3 PPM
055-38A	Room 13 Drinking Fountain	7/28/16 10:57	8/3/2016	1608007-38A	COPPER	0.5 PPM	1.3 PPM
055-39A	Book Storage Sink Faucet	7/28/16 11:04	8/3/2016	1608007-39A	COPPER	0.7 PPM	1.3 PPM
055-40A	Book Storage Drinking Fountain	7/28/16 11:04	8/3/2016	1608007-40A	COPPER	0.4 PPM	1.3 PPM
055-41A	Room 14 Sink Faucet	7/28/16 11:07	8/3/2016	1608007-41A	COPPER	0.3 PPM	1.3 PPM
055-42A	Room 14 Drinking Fountain	7/28/16 11:07	8/3/2016	1608007-42A	COPPER	0.4 PPM	1.3 PPM
055-43A	Room 15 Drinking Fountain	7/28/16 11:22	8/3/2016	1608007-43A	COPPER	0.1 PPM	1.3 PPM
055-44A	Room 15 Sink Faucet	7/28/16 11:22	8/3/2016	1608007-44A	COPPER	0.8 PPM	1.3 PPM
055-45A	Room 16 Sink Faucet	7/28/16 11:26	8/3/2016	1608007-45A	COPPER	0.5 PPM	1.3 PPM
055-46A	Room 16 Drinking Fountain	7/28/16 11:25	8/3/2016	1608007-46A	COPPER	0.5 PPM	1.3 PPM
055-47A	Room 17 Sink Faucet	7/28/16 11:26	8/3/2016	1608007-47A	COPPER	0.5 PPM	1.3 PPM
055-48A	Room 17 Drinking Fountain	7/28/16 11:30	8/3/2016	1608007-48A	COPPER	0.5 PPM	1.3 PPM
055-49A	Room 18 Sink Faucet	7/28/16 11:32	8/3/2016	1608007-49A	COPPER	0.5 PPM	1.3 PPM
055-50A	Room 18 Drinking Fountain	7/28/16 11:32	8/3/2016	1608007-50A	COPPER	0.5 PPM	1.3 PPM
055-51A	Room 19 Sink Faucet	7/28/16 11:35	8/3/2016	1608007-51A	COPPER	0.5 PPM	1.3 PPM
055-52A	Room 19 Drinking Fountain	7/28/16 11:36	8/3/2016	1608007-52A	COPPER	0.6 PPM	1.3 PPM
055-53A	Room 20 Sink Faucet	7/28/16 11:42	8/3/2016	1608007-53A	COPPER	0.5 PPM	1.3 PPM
055-54A	Room 20 Drinking Fountain	7/28/16 11:42	8/3/2016	1608007-54A	COPPER	0.4 PPM	1.3 PPM
005-55A	Hall Drinking Fountain 8	7/28/16 11:56	8/3/2016	1608007-55A	COPPER	0.4 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Swegle Elementary School

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
Flushed (B) Sample Data
Swegle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
055-47B Room 17 Sink Faucet	7/28/16 11:31	8/24/2016	1608008-47A	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (C) Sample Data
Swegle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
055-47C Room 17 Sink Faucet	10/14/2016 6:17	10/18/2016	63273	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (E) Sample Data
Swegle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
055-47E Room 17 Sink Faucet	4/6/2017 7:57	4/11/2017	18163	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (G) Sample Data
Swegle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
055-47G Room 17 Sink Faucet	5/18/2018 7:00	5/22/2018	36126	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level